

TUKIALIK BAY, NL, Canada

WMO: 711790

Lat: 54.716N

Lon: 58.358W

Elev: 683

StdP: 93.39

Time Zone: -4.00 (NAA)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-31.1	-28.8	N/A	N/A	N/A	N/A	N/A	N/A	33.2	-5.7	30.9	-8.8	10.7	250	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	20.9	N/A	18.4	N/A	16.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.2	24.6	21.8	DB	-32.5	24.1	3.5	2.1	-35.0	25.6	-37.1	26.8	-39.0	28.0	-41.6	29.5	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-3.6	-16.3	-17.2	-12.8	-6.8	-0.7	4.9	9.5	9.7	4.9	-0.5	-6.8	-12.1	(6)	
	DBStd	10.74	6.77	7.21	6.91	4.94	4.19	5.55	4.64	4.18	4.10	4.59	4.50	6.19	(7)	
	HDD10.0	5101	817	761	708	505	333	173	67	58	162	328	504	685	(8)	
	HDD18.3	8014	1075	994	967	755	589	404	276	269	403	584	754	943	(9)	
	CDD10.0	133	0	0	0	0	1	21	52	48	9	2	0	0	(10)	
	CDD18.3	4	0	0	0	0	0	2	2	1	0	0	0	0	(11)	
	CDH23.3	9	0	0	0	0	0	4	4	1	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	9.7	11.6	11.3	11.2	11.0	9.4	8.1	7.8	7.9	8.6	9.3	9.6	10.5	(14)	
(15) Precipitation	PrecAvg	966	87	81	75	65	65	72	93	96	80	86	86	81	(15)	
	PrecMax	1179	149	144	128	120	129	147	133	164	134	144	155	139	(16)	
	PrecMin	862	28	15	25	35	16	35	61	50	37	40	24	35	(17)	
	PrecStd	73	28	29	24	20	26	23	20	25	25	27	29	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.4	1.5	0.7	7.2	15.2	23.7	23.7	22.5	18.3	14.2	5.5	2.2	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	-2.0	0.1	-0.6	3.7	11.8	19.8	20.8	19.9	15.7	11.5	3.0	-0.5	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	-3.8	-3.0	-1.7	1.4	8.5	16.1	18.3	17.8	13.7	8.7	0.3	-2.1	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	-6.2	-6.3	-3.0	-0.2	5.6	13.6	16.4	16.2	11.5	6.4	-1.0	-3.6	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
(31) Mean Daily Temperature Range	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
	5% DB	MDBR	6.5	6.3	5.8	5.6	5.0	6.5	6.7	6.7	5.8	4.0	4.8	5.3	(35)	
		MCDBR	7.6	7.9	5.1	7.1	9.6	10.1	8.8	8.8	8.8	6.3	6.8	4.9	(36)	
(40) Clear-Sky Solar Irradiance	taub	taud	2.279	2.286	2.223	2.134	2.280	2.427	2.438	2.493	2.542	2.570	2.436	2.234	(41)	
		Ebn at Noon	759	871	920	912	909	907	883	883	868	819	742	660	(42)	
	Edh at Noon		53	76	104	132	122	107	104	93	77	59	46	45	(43)	
															(44)	
(44) All-Sky Solar Radiation	RadAvg	0.77	1.68	3.03	4.47	5.20	5.01	4.71	3.97	2.94	1.54	0.77	0.51		(44)	
	RadStd	0.12	0.28	0.44	0.36	0.64	0.50	0.33	0.33	0.23	0.10	0.07	0.06		(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page