

WRECKHOUSE, NL, Canada

WMO: 711800

Lat: 47.7136N

Lon: 59.3062W

Elev: 32

StdP: 100.94

Time Zone: -3.50 (NAF)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.9	-11.4	-16.9	0.9	-12.6	-15.0	1.0	-11.1	27.6	-0.3	24.8	0.6	8.8	280	0.804

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	23.6	19.6	22.3	18.9	21.2	18.3	20.6	22.8	19.7	21.7	19.0	20.8	6.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	22.0	18.9	13.8	21.2	18.1	13.1	20.4	59.6	22.9	56.7	21.8	54.1	20.8	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	18.8	16.1	DB	-15.1	26.9	2.6	1.4	-17.0	27.9	-18.5	28.7	-20.0	29.4	-21.9	30.4
			WB	-16.0	22.4	2.6	0.5	-17.8	22.8	-19.3	23.1	-20.8	23.4	-22.6	23.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-3.6	-4.3	-2.3	2.3	7.1	11.5	16.5	17.2	13.1	8.4	4.2	-0.4	(6)
(7)		DBStd	8.13	3.87	4.00	3.96	3.57	3.43	3.46	2.74	2.31	3.21	3.33	3.80	3.78	(7)
(8)		HDD10.0	2144	421	402	382	231	104	22	0	0	9	72	179	323	(8)
(9)		HDD18.3	4582	679	635	640	480	349	206	70	49	158	308	424	581	(9)
(10)		CDD10.0	636	0	0	0	1	14	67	202	223	102	22	4	0	(10)
(11)		CDD18.3	30	0	0	0	0	0	1	13	14	2	0	0	0	(11)
(12)		CDH23.3	49	0	0	0	0	0	4	28	18	0	0	0	0	(12)
(13)		CDH26.7	2	0	0	0	0	0	1	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	6.9	9.1	8.9	7.9	7.1	5.6	5.4	4.8	4.7	5.7	6.7	7.8	8.9	(14)
(15)	Precipitation	PrecAvg	1348	121	95	88	91	89	89	106	104	119	131	130	145	(15)
(16)		PrecMax	1746	184	208	176	166	153	157	201	193	244	225	201	359	(16)
(17)		PrecMin	950	36	38	29	19	16	33	26	41	47	53	59	67	(17)
(18)		PrecStd	210	43	36	42	40	38	35	38	40	45	47	41	58	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	7.9	8.9	15.1	19.5	23.4	25.7	25.4	22.3	19.0	15.5	11.7	(19)
(20)			MCWB	9.6	7.3	7.6	10.7	14.7	17.6	20.7	20.8	19.2	16.3	14.4	10.5	(20)
(21)		2%	DB	6.4	5.0	6.6	12.2	16.9	20.8	23.9	23.5	20.6	16.8	13.7	9.1	(21)
(22)			MCWB	5.4	3.6	5.1	9.3	11.6	16.4	19.8	19.7	18.2	14.6	12.5	8.1	(22)
(23)		5%	DB	3.6	2.9	4.8	9.9	14.9	19.1	22.5	22.2	19.4	15.2	12.2	7.1	(23)
(24)			MCWB	2.7	1.9	3.1	7.7	11.0	15.3	18.9	19.2	17.4	13.5	11.2	6.0	(24)
(25)		10%	DB	1.7	1.0	3.0	7.9	13.0	17.5	21.2	21.3	18.3	13.8	10.3	5.1	(25)
(26)			MCWB	0.9	0.2	1.5	5.7	9.8	14.2	18.2	18.7	16.5	12.2	9.1	4.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	7.6	7.6	12.1	15.5	19.4	21.9	21.7	20.2	17.6	14.7	10.8	(27)
(28)			MCD B	10.9	7.8	8.3	13.2	18.3	21.9	25.0	24.2	21.6	18.6	15.6	11.5	(28)
(29)		2%	WB	5.7	4.2	5.4	9.4	13.2	17.5	20.7	20.7	18.7	15.0	12.8	8.1	(29)
(30)			MCD B	6.4	4.8	6.2	11.0	15.2	19.6	23.1	22.7	20.2	16.1	13.6	9.1	(30)
(31)		5%	WB	2.9	1.9	3.1	7.4	11.2	16.0	19.7	20.0	17.7	13.5	11.2	5.9	(31)
(32)			MCD B	3.6	2.6	4.3	9.1	13.8	18.7	21.9	21.8	19.1	14.8	12.2	6.9	(32)
(33)		10%	WB	1.0	0.2	1.5	5.6	9.5	14.6	18.8	19.2	16.5	12.0	9.2	4.0	(33)
(34)			MCD B	1.6	0.9	2.6	7.4	12.3	17.1	20.8	21.0	17.9	13.4	10.0	4.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.3	5.7	6.2	6.7	7.8	7.8	7.1	6.9	6.8	6.1	5.6	4.9	(35)
(36)			MCDBR	8.5	8.6	8.3	9.7	10.6	10.1	8.8	7.9	7.1	7.7	7.9	7.9	(36)
(37)			MCWBR	8.4	8.3	7.3	7.7	7.0	6.8	5.5	5.5	5.6	7.0	8.0	7.8	(37)
(38)		5% WB	MCDBR	8.4	8.7	8.3	9.3	9.4	9.0	7.0	7.0	6.8	7.6	8.1	8.0	(38)
(39)			MCWBR	8.5	8.6	7.7	8.0	7.1	6.5	4.8	5.2	5.7	7.2	8.2	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.302	0.331	0.353	0.364	0.386	0.414	0.396	0.367	0.351	0.321	0.304	(40)	
(41)		taud	2.352	2.400	2.342	2.392	2.438	2.397	2.361	2.415	2.473	2.453	2.460	2.381	(41)	
(42)		Ebn at Noon	764	864	887	900	899	878	846	847	841	795	748	720	(42)	
(43)		Edh at Noon	71	84	104	110	109	115	117	107	92	80	65	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.81	1.57	2.96	4.15	5.15	5.27	5.03	4.59	3.52	2.16	1.08	0.64	(44)	
(45)		RadStd	0.08	0.17	0.31	0.34	0.42	0.57	0.41	0.29	0.23	0.14	0.13	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.29	N/A	N/A	N/A	N/A

Nomenclature: See separate page