

GASPE, QC, Canada

WMO: 711880

Lat: 48.7769N

Lon: 64.4781W

Elev: 34

StdP: 100.92

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.3	-21.9	-30.2	0.2	-23.2	-27.6	0.3	-21.1	12.4	-4.9	10.6	-5.7	2.2	270	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	28.0	19.7	25.9	18.9	24.1	17.9	21.0	26.0	19.9	24.3	18.9	22.8	4.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	23.8	18.1	13.1	22.3	17.2	12.3	21.2	61.1	26.1	57.2	24.4	53.8	22.9	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.5	7.5	-28.3	32.4	2.4	1.7	-30.0	33.6	-31.4	34.7	-32.7	35.6	-34.5	36.9
			-28.6	23.2	2.3	1.1	-30.2	24.0	-31.6	24.6	-32.9	25.2	-34.6	26.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-10.5	-10.1	-5.1	1.5	7.7	13.5	17.5	16.8	12.3	6.3	0.3	-5.9	(6)
(7)		DBStd	10.64	5.95	5.92	5.43	3.55	3.62	3.87	2.99	2.95	3.70	3.78	4.56	5.06	(7)
(8)		HDD10.0	2954	636	564	467	257	92	9	0	0	17	128	291	493	(8)
(9)		HDD18.3	5373	894	797	725	507	330	153	52	66	184	374	540	752	(9)
(10)		CDD10.0	677	0	0	0	1	21	114	232	210	86	13	2	0	(10)
(11)		CDD18.3	54	0	0	0	0	1	8	24	18	3	0	0	0	(11)
(12)		CDH23.3	571	0	0	0	0	21	108	227	174	39	3	0	0	(12)
(13)		CDH26.7	125	0	0	0	0	4	28	48	37	8	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.4	3.4	3.5	3.4	3.0	2.9	2.6	2.5	2.7	3.1	3.2	3.4	(14)
(15)	Precipitation	PrecAvg	1143	83	85	99	72	88	87	101	102	88	121	97	121	(15)
(16)		PrecMax	1496	127	148	261	159	172	180	163	223	196	281	170	407	(16)
(17)		PrecMin	795	13	23	26	24	27	24	31	20	11	29	41	35	(17)
(18)		PrecStd	156	29	32	52	41	38	34	38	45	42	51	34	66	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.8	6.8	9.5	15.9	26.5	30.1	30.6	30.3	27.5	22.4	16.1	8.2	(19)
(20)			MCWB	6.9	5.5	5.7	8.6	16.1	20.5	20.9	20.8	19.7	15.6	13.9	7.3	(20)
(21)		2%	DB	3.2	3.0	6.2	12.0	21.3	26.3	27.8	27.2	23.7	17.7	12.4	4.8	(21)
(22)			MCWB	2.0	1.7	3.2	7.3	13.6	17.9	20.0	19.7	17.8	13.7	10.1	3.6	(22)
(23)		5%	DB	0.8	0.9	4.2	9.4	17.9	23.6	25.8	25.1	21.4	15.2	9.2	2.9	(23)
(24)			MCWB	-0.3	-0.3	1.4	5.2	11.6	16.9	19.3	18.6	16.6	11.5	7.1	1.7	(24)
(25)		10%	DB	-1.4	-1.0	2.3	7.3	15.3	21.4	24.0	23.3	19.4	12.8	6.8	1.1	(25)
(26)			MCWB	-2.5	-2.1	0.3	3.8	10.0	15.5	18.1	17.7	15.1	9.9	5.0	0.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	5.8	6.5	11.2	17.5	21.3	22.7	22.1	20.8	16.5	14.2	7.3	(27)
(28)			MCD B	7.8	6.7	8.8	14.2	23.9	27.5	28.3	27.8	25.4	20.4	16.0	8.2	(28)
(29)		2%	WB	2.1	1.9	3.5	7.7	14.4	19.3	21.3	20.7	18.7	14.1	10.4	3.9	(29)
(30)			MCD B	3.1	2.6	5.7	10.9	19.8	24.3	26.2	25.5	22.7	17.2	11.9	4.4	(30)
(31)		5%	WB	-0.1	-0.2	1.9	5.8	12.5	17.7	20.1	19.6	17.3	12.1	7.4	1.9	(31)
(32)			MCD B	0.7	0.7	3.7	9.0	17.0	22.3	24.3	23.8	20.7	14.7	8.8	2.7	(32)
(33)		10%	WB	-2.4	-2.0	0.5	4.1	10.5	16.1	19.0	18.5	15.7	10.2	5.2	0.4	(33)
(34)			MCD B	-1.5	-1.0	2.0	6.7	14.4	20.4	22.8	22.2	18.6	12.3	6.5	1.0	(34)
(35)	Mean Daily Temperature Range	MDBR	9.9	10.5	9.7	8.8	11.3	11.7	11.4	11.5	11.4	9.2	7.4	7.6	(35)	
(36)		5% DB	MCD BR	11.9	10.5	11.4	13.1	17.4	16.2	14.7	14.8	14.8	13.5	10.5	9.0	(36)
(37)			MCWBR	11.4	9.6	8.8	8.9	10.4	9.0	8.0	8.2	9.4	9.5	9.1	8.5	(37)
(38)			MCD BR	11.8	9.5	10.2	12.1	15.4	14.3	12.6	12.7	13.0	12.3	9.9	8.7	(38)
(39)		5% WB	MCWBR	11.5	9.0	8.3	8.9	9.7	8.6	7.5	7.6	8.9	9.3	9.1	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.275	0.279	0.310	0.351	0.363	0.382	0.412	0.383	0.357	0.338	0.305	0.282	(40)	
(41)		taud	2.357	2.301	2.298	2.347	2.414	2.364	2.331	2.404	2.462	2.492	2.497	2.403	(41)	
(42)		Ebn at Noon	794	878	903	897	897	879	844	856	846	803	759	737	(42)	
(43)		Edh at Noon	67	89	107	114	111	118	120	107	92	76	60	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.16	2.01	3.27	4.38	5.13	5.59	5.37	4.71	3.58	2.20	1.15	0.84	(44)	
(45)		RadStd	0.10	0.19	0.28	0.37	0.37	0.45	0.47	0.27	0.28	0.16	0.14	0.08	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (15 neighbors)	N/A	N/A	+1.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page