

POINTE DE L'ISLET, QC, Canada

WMO: 711900

Lat: 48.1356N

Lon: 69.7164W

Elev: 23

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.8	-2.3	-14.8	2.5	-5.6	-10.8	3.1	-0.4	50.7	3.2	46.9	4.3	25.0	300	0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	73.4	62.0	70.4	60.6	67.9	59.6	65.0	69.9	63.0	67.5	61.3	65.7	13.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.1	86.4	67.4	61.1	80.4	65.4	59.3	75.5	63.6	30.0	70.2	28.5	67.5	27.3	65.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.4	33.9	28.8	DB	-7.6	82.1	4.3	3.7	-10.7	84.8	-13.2	86.9	-15.7	88.9	-18.8	91.6	(4)
(5)			WB	-9.0	70.0	4.0	1.8	-11.8	71.3	-14.2	72.4	-16.4	73.3	-19.3	74.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.8	15.6	17.3	25.9	36.9	48.0	56.8	60.7	60.1	53.6	44.2	33.9	22.7		
	DBStd	17.38	10.65	9.62	8.94	6.10	5.45	4.95	4.28	4.02	4.95	5.44	7.18	9.23		
	HDD50	4771	1066	914	746	394	105	5	0	0	19	194	483	845		
	HDD65	9228	1531	1334	1211	844	527	251	144	157	342	645	932	1310		
	CDD50	1041	0	0	0	1	43	208	333	314	127	14	1	0		
	CDD65	23	0	0	0	0	0	3	12	7	1	0	0	0		
	CDH74	89	0	0	0	0	5	25	40	17	2	0	0	0		
	CDH80	9	0	0	0	0	1	3	4	1	0	0	0	0		
	WSAvg	11.8	16.4	15.2	13.9	12.2	10.0	9.5	8.8	8.9	9.4	10.7	12.2	14.7		
	PrecAvg	40.6	2.7	2.6	2.6	3.2	3.3	3.6	4.4	4.2	3.9	4.1	3.2	3.4		
(15) Precipitation	PrecMax	49.1	4.8	4.4	5.0	7.6	6.2	7.3	10.6	7.9	10.3	8.7	5.0	9.5		
	PrecMin	31.7	0.2	1.4	1.2	0.6	1.2	1.4	2.1	1.9	2.0	1.3	1.7	1.0		
	PrecStd	4.9	1.2	0.8	1.0	1.6	1.3	1.5	2.2	1.9	1.9	1.8	0.9	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	39.8	46.7	57.1	71.0	77.6	78.4	76.4	71.5	63.1	54.2	43.9		
		MCWB	39.8	36.5	40.4	46.6	55.6	61.8	65.7	64.6	63.0	55.7	50.0	40.8		
	2%	DB	37.2	35.9	41.8	50.4	64.0	71.2	73.7	71.7	66.8	57.6	48.2	39.4		
		MCWB	35.7	33.8	37.3	42.0	52.3	58.4	62.9	62.3	59.7	52.2	44.2	36.9		
	5%	DB	34.0	33.7	38.7	46.8	59.1	67.7	70.4	69.0	63.6	54.1	45.3	37.0		
		MCWB	32.1	31.9	34.8	40.1	50.3	57.1	61.2	60.9	57.4	49.7	42.3	34.9		
	10%	DB	30.5	31.3	36.6	44.1	55.7	64.5	67.8	66.5	60.7	51.5	42.7	34.8		
		MCWB	28.5	29.5	33.5	38.2	48.2	56.0	60.2	59.9	55.5	47.4	40.0	32.9		
	0.4%	WB	40.3	37.8	42.6	48.1	59.0	66.0	68.3	67.3	65.1	57.2	50.9	41.0		
		MCDB	41.5	38.9	45.7	51.7	65.4	72.9	73.5	72.4	69.3	61.1	53.7	42.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.7	34.2	38.2	43.7	54.4	62.0	65.4	64.3	61.0	53.1	45.0	37.3		
		MCDB	37.1	35.4	40.6	48.5	60.0	67.0	70.4	68.5	65.1	56.6	47.1	39.0		
	5%	WB	32.4	32.1	35.9	41.2	51.6	59.8	63.3	62.6	58.5	50.5	42.5	35.3		
		MCDB	34.0	33.7	37.8	45.1	56.7	65.0	68.0	66.8	62.3	53.7	44.9	36.9		
	10%	WB	28.6	29.4	33.8	39.3	49.1	57.6	61.4	61.0	56.3	48.1	40.2	33.0		
		MCDB	30.3	31.2	36.1	42.7	53.9	62.7	65.8	65.3	59.8	51.0	42.5	34.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.5	12.0	11.4	10.9	12.7	13.8	13.9	13.2	11.5	8.6	7.8	9.3		
		MCDBR	14.7	11.5	12.6	15.8	20.3	19.3	18.0	16.8	16.0	13.4	11.3	10.7		
		MCWBR	14.0	10.8	10.0	10.3	11.1	10.0	9.7	9.5	10.7	9.8	10.0	10.0		
		MCDBR	13.9	11.2	11.7	14.2	17.4	17.4	17.1	15.9	15.4	13.4	11.1	10.6		
	5% WB	MCWBR	13.8	10.7	10.2	10.4	11.6	11.4	11.4	10.8	11.5	10.7	10.2	10.2		
(40) Clear-Sky Solar Irradiance	taub		0.269	0.281	0.320	0.363	0.371	0.388	0.415	0.394	0.372	0.335	0.300	0.275		
	taud		2.318	2.279	2.229	2.265	2.344	2.360	2.308	2.371	2.422	2.501	2.456	2.342		
	Ebn at Noon		256	279	283	281	283	278	267	269	264	258	244	238		
	Edh at Noon		23	30	37	39	38	38	39	35	30	24	20	20		
(44) All-Sky Solar Radiation	RadAvg		411	704	1078	1402	1625	1739	1709	1469	1133	662	361	276		
	RadStd		47	82	82	116	158	121	168	97	79	57	38	26		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page