

ALMA FUNDY NATL PARK, NB, Canada

WMO: 711910

Lat: 45.597N

Lon: 64.953W

Elev: 140

StdP: 14.62

Time Zone: -4.00 (NAA)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.3	1.9	-13.2	2.7	-0.8	-8.3	3.5	5.2	12.3	22.6	11.1	22.0	4.0	350	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.2	76.9	66.0	74.5	64.9	72.3	64.1	69.3	73.4	67.7	71.6	66.0	70.1	4.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.9	102.9	72.0	66.1	96.7	70.1	64.4	91.1	68.4	33.5	73.1	32.2	71.6	30.9	70.1	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.9	7.6	DB	-8.8	83.4	4.3	3.1	-11.9	85.6	-14.4	87.4	-16.8	89.2	-19.9	91.5	
			WB	-9.7	73.5	4.3	1.2	-12.7	74.4	-15.2	75.1	-17.6	75.7	-20.7	76.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	22.0	22.4	29.3	40.4	50.1	57.8	64.1	64.3	58.7	48.6	39.1	28.0	(6)
(7)		DBStd	16.75	10.72	9.54	8.38	5.94	5.07	4.56	3.47	3.42	5.74	6.80	8.45	9.98	(7)
(8)		HDD50	3772	869	772	640	293	61	3	0	0	4	108	339	683	(8)
(9)		HDD65	7793	1334	1192	1105	739	462	220	56	52	198	509	778	1148	(9)
(10)		CDD50	1531	0	0	0	5	65	236	438	445	266	65	11	0	(10)
(11)		CDD65	75	0	0	0	0	0	3	29	32	10	1	0	0	(11)
(12)		CDH74	256	0	0	0	0	5	21	121	87	22	0	0	0	(12)
(13)		CDH80	14	0	0	0	0	0	0	7	4	3	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.5	3.5	3.5	3.3	3.0	2.5	2.2	2.3	2.7	3.0	3.3	3.5	(14)
(15)	Precipitation	PrecAvg	56.5	5.1	4.3	5.0	4.2	4.5	4.4	3.9	3.3	4.6	5.5	5.6	6.1	(15)
(16)		PrecMax	73.7	8.9	8.5	11.3	7.5	9.6	10.2	7.5	6.9	12.1	11.1	10.7	12.6	(16)
(17)		PrecMin	41.3	2.2	1.2	1.3	1.5	1.4	1.3	1.2	0.4	0.8	1.2	2.1	2.1	(17)
(18)		PrecStd	7.4	1.7	1.7	2.1	1.3	1.9	2.4	1.7	1.7	2.6	2.5	2.0	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.7	48.7	52.9	62.7	72.4	77.0	80.6	79.2	76.8	70.1	62.3	54.0	(19)
(20)			MCWB	52.0	47.0	43.2	52.9	58.8	64.7	68.3	67.3	67.5	62.2	59.8	52.4	(20)
(21)		2%	DB	45.9	42.5	47.2	58.0	66.5	72.8	77.2	76.3	72.7	65.0	58.6	49.4	(21)
(22)			MCWB	44.7	39.7	41.9	50.2	56.0	62.4	66.3	65.8	64.9	59.8	55.8	48.0	(22)
(23)		5%	DB	41.4	38.5	43.8	54.0	62.8	69.6	74.7	74.1	70.0	62.1	55.5	45.8	(23)
(24)			MCWB	39.4	35.9	39.2	48.0	53.8	59.8	65.1	65.2	63.3	58.4	53.0	43.9	(24)
(25)		10%	DB	36.6	35.8	40.5	50.5	59.4	66.9	72.0	71.9	67.6	59.7	52.2	42.2	(25)
(26)			MCWB	34.8	33.7	36.6	44.5	52.1	59.6	64.4	64.5	62.5	55.9	49.6	40.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.5	46.9	47.0	58.0	62.6	68.4	72.0	71.4	70.4	65.7	60.6	53.3	(27)
(28)			MCDWB	51.2	48.6	49.5	59.6	67.1	72.8	77.9	75.6	74.6	67.6	61.8	54.2	(28)
(29)		2%	WB	43.8	40.1	43.6	53.0	58.7	65.5	69.3	69.1	67.4	61.5	56.7	48.2	(29)
(30)			MCDWB	44.6	41.7	46.2	55.3	63.2	69.6	73.4	73.4	70.5	63.6	57.7	49.2	(30)
(31)		5%	WB	38.8	36.3	40.0	48.8	55.9	63.2	67.6	67.4	65.4	58.9	53.2	44.2	(31)
(32)			MCDWB	40.2	37.9	42.7	52.4	60.6	67.2	71.9	71.5	68.4	61.4	54.7	45.3	(32)
(33)		10%	WB	34.7	33.8	36.9	45.5	53.7	60.7	65.8	65.7	63.5	56.5	49.6	40.4	(33)
(34)			MCDWB	36.0	35.1	39.9	49.5	57.9	65.0	70.2	70.0	66.8	58.8	51.8	41.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.4	16.1	15.6	15.7	17.3	16.4	16.9	16.2	16.5	15.1	13.8	13.8	(35)
(36)			MCDBR	20.5	16.6	18.0	21.8	23.7	22.2	21.0	19.2	17.8	16.8	16.7	16.7	(36)
(37)			MCWBR	19.7	14.4	13.6	15.1	14.2	13.1	12.3	10.9	11.2	12.6	15.1	16.2	(37)
(38)		5% WB	MCDWB	19.1	16.3	16.7	18.8	19.5	17.9	17.6	15.3	15.2	14.7	15.1	16.2	(38)
(39)			MCWBR	19.2	15.2	14.6	15.3	13.8	12.5	12.1	10.2	10.9	12.5	14.8	16.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.290	0.289	0.323	0.350	0.373	0.399	0.428	0.397	0.363	0.331	0.310	0.290	(40)	
(41)		taud	2.418	2.429	2.406	2.382	2.361	2.335	2.290	2.372	2.448	2.534	2.504	2.470	(41)	
(42)		Ebn at Noon	260	285	288	289	284	276	266	270	271	267	252	249	(42)	
(43)		Edh at Noon	23	27	32	36	38	39	40	36	30	24	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	460	727	1094	1364	1583	1713	1758	1570	1251	797	446	346	(44)	
(45)		RadStd	41	55	69	128	164	144	117	108	94	83	49	26	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.72	N/A	N/A	+86	N/A	

Nomenclature: See separate page