

PEMBROKE, ON, Canada

WMO: 711960

Lat: 45.8603N

Lon: 77.2525W

Elev: 162

StdP: 99.39

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.8	-21.1	-28.4	0.3	-24.4	-24.9	0.4	-20.4	24.8	-1.1	23.1	-5.6	2.1	300	0.738

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	28.3	19.3	26.3	18.9	24.4	18.0	21.4	25.6	20.3	24.3	19.2	22.9	3.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.0	23.8	18.8	13.9	22.4	17.8	13.0	21.2	63.0	25.8	59.2	24.3	55.4	22.9	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.1	18.3	15.7	DB	-22.1	28.9	8.9	2.9	-28.5	31.0	-33.7	32.7	-38.7	34.3	-45.2	36.4	(4)
(5)			WB	-24.2	22.7	8.7	1.8	-30.4	23.9	-35.5	25.0	-40.4	26.0	-46.7	27.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-7.4	-6.9	-3.4	2.3	8.5	13.0	17.6	17.1	13.5	7.9	2.1	-3.4	(6)	
	DBStd	9.99	7.03	6.12	4.84	3.73	5.31	5.15	3.90	3.10	3.76	3.76	4.46	6.04	(7)	
	HDD10.0	2535	538	472	414	233	96	28	2	0	8	89	239	416	(8)	
	HDD18.3	4894	797	705	673	481	309	172	60	60	152	324	488	674	(9)	
	CDD10.0	763	0	0	0	3	49	118	237	219	113	23	1	0	(10)	
	CDD18.3	81	0	0	0	0	4	12	37	21	7	0	0	0	(11)	
	CDH23.3	632	0	0	0	1	46	111	309	125	39	2	0	0	(12)	
	CDH26.7	143	0	0	0	0	9	25	79	23	7	0	0	0	(13)	
(14) Wind	WSAvg	6.2	8.1	7.6	6.8	6.1	5.2	5.4	4.6	5.1	5.7	6.1	7.3	6.8	(14)	
(15) Precipitation	PrecAvg	777	51	41	44	58	68	73	85	81	76	73	64	60	(15)	
	PrecMax	950	92	80	129	104	103	136	164	130	137	117	104	92	(16)	
	PrecMin	641	18	16	13	17	33	17	20	21	36	12	20	18	(17)	
	PrecStd	75	21	16	26	24	21	27	40	21	29	29	21	19	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	7.2	9.0	18.6	27.9	29.6	31.7	29.2	27.2	21.3	14.5	9.8	(19)	
		MCWB	8.9	6.1	7.0	10.3	17.9	19.6	21.3	18.9	20.7	16.1	12.0	8.9	(20)	
	2%	DB	5.2	4.2	6.2	13.6	24.2	26.4	28.9	26.4	24.0	17.9	12.3	7.0	(21)	
		MCWB	4.5	3.4	3.7	8.4	15.4	18.2	19.8	19.2	18.8	14.8	10.5	6.3	(22)	
	5%	DB	2.2	2.4	4.2	10.3	21.0	23.8	26.8	24.4	21.6	15.8	10.1	4.5	(23)	
		MCWB	1.4	1.5	2.3	6.5	14.2	17.0	19.3	18.5	17.9	13.2	8.8	3.7	(24)	
	10%	DB	0.6	1.0	2.7	8.0	17.8	21.4	24.7	22.5	19.4	13.7	8.1	2.9	(25)	
		MCWB	-0.3	0.1	1.2	4.8	12.6	16.1	18.7	17.8	16.5	11.7	6.9	2.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	6.0	7.7	13.9	20.0	21.7	23.4	21.7	22.0	18.0	13.0	8.9	(27)	
		MCDB	9.4	6.5	8.7	17.0	25.0	26.4	29.3	25.9	25.9	19.7	13.7	9.4	(28)	
	2%	WB	4.5	3.6	4.3	9.6	17.6	20.0	21.7	20.5	20.0	15.4	10.9	6.2	(29)	
		MCDB	5.1	4.2	5.3	12.1	21.9	23.9	26.1	24.1	23.1	17.2	11.9	6.9	(30)	
	5%	WB	1.6	1.7	2.6	7.4	15.3	18.2	20.5	19.5	18.2	13.5	8.9	3.8	(31)	
		MCDB	2.1	2.2	3.8	10.1	19.3	22.1	25.0	22.9	20.7	15.3	10.1	4.3	(32)	
	10%	WB	-0.2	0.2	1.3	5.0	13.1	16.6	19.3	18.5	16.7	11.8	7.1	2.2	(33)	
		MCDB	0.5	0.8	2.5	7.7	18.0	20.7	23.6	21.4	19.1	13.5	8.1	2.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	7.3	6.8	6.6	8.4	8.5	9.3	8.0	7.8	6.4	6.0	5.6	(35)	
		MCDBR	9.3	7.9	8.9	12.4	14.9	13.0	13.6	12.0	12.0	10.9	9.2	7.2	(36)	
	5% WB	MCWBR	9.5	7.4	7.3	8.2	7.2	6.2	6.3	6.1	7.0	7.7	8.1	7.6	(37)	
		MCWBR	9.3	7.5	7.7	10.8	11.9	10.8	11.3	9.8	10.2	9.6	8.4	6.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.268	0.285	0.318	0.352	0.370	0.410	0.406	0.393	0.369	0.342	0.308	0.273	(40)	
		taud	2.359	2.301	2.351	2.383	2.388	2.294	2.322	2.355	2.417	2.477	2.498	2.397	(41)	
	Ebn at Noon		844	895	912	906	897	858	857	855	847	822	793	797	(42)	
		Edn at Noon	73	95	105	112	116	128	123	115	99	81	66	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.35	2.31	3.67	4.55	5.17	5.69	5.65	4.94	3.85	2.26	1.34	0.98	(44)	
	RadStd		0.19	0.27	0.32	0.39	0.46	0.43	0.47	0.28	0.36	0.23	0.15	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page