

PORT AUX BASQUES, NL, Canada

WMO: 711970

Lat: 47.5734N

Lon: 59.1531W

Elev: 130

StdP: 14.63

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.5	10.8	-1.0	5.2	8.9	2.7	6.3	12.2	56.9	18.6	52.3	20.5	24.2	300	0.853

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	69.9	65.0	67.9	63.7	66.2	62.6	66.1	68.4	64.6	66.9	63.3	65.4	12.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	93.7	67.5	63.6	88.5	66.1	62.2	84.1	64.8	31.0	68.5	29.8	67.0	28.8	65.6	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.1	40.0	35.2	3.4	74.5	5.1	2.1	-0.3	76.0	-3.3	77.2	-6.2	78.3	-9.9	79.8
			2.5	68.5	5.3	2.4	-1.3	70.2	-4.4	71.6	-7.4	73.0	-11.2	74.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.2	24.8	23.3	27.3	34.4	42.6	50.1	58.6	61.7	54.7	46.4	38.2	30.9	
	DBStd	13.83	6.45	7.51	6.70	4.74	4.37	4.47	3.52	3.44	4.69	4.95	5.95	6.16	
	HDD50	4073	781	746	703	467	233	51	0	0	12	133	356	591	
	HDD65	8696	1246	1166	1168	917	695	446	199	112	310	576	805	1056	
	CDD50	862	0	0	0	0	3	56	267	361	152	22	1	0	
	CDD65	10	0	0	0	0	0	0	1	8	1	0	0	0	
	CDH74	2	0	0	0	0	0	0	0	2	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	15.8	21.2	20.5	17.5	16.3	13.8	12.8	11.4	10.5	12.6	15.4	17.5	20.3	
Precipitation	PrecAvg	61.5	6.0	4.9	4.4	4.8	4.8	4.6	4.3	4.8	4.7	5.9	6.3	7.2	
	PrecMax	73.2	9.9	12.0	9.5	9.9	9.0	8.9	11.0	9.7	8.2	9.6	9.7	14.6	
	PrecMin	49.3	3.1	0.9	1.5	1.4	1.5	1.1	1.2	0.8	1.3	1.5	3.0	2.5	
	PrecStd	6.7	1.7	2.2	1.9	2.2	2.0	2.0	2.2	2.2	1.6	2.0	1.8	2.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	43.8	43.5	50.8	59.0	66.6	71.2	73.4	69.5	60.6	53.8	47.1	
		MCWB	41.7	41.8	40.0	46.0	50.4	58.2	64.3	67.1	64.9	57.4	52.3	45.7	
	2%	DB	39.6	38.5	39.5	45.8	55.0	62.7	68.4	70.9	66.0	58.1	51.3	44.4	
		MCWB	38.8	37.1	37.0	41.6	48.6	55.5	63.4	65.8	62.8	55.7	50.3	43.1	
	5%	DB	36.9	35.6	37.5	42.9	51.9	59.5	66.3	69.1	63.5	56.0	49.5	42.3	
		MCWB	35.5	34.1	35.4	39.9	47.0	54.4	62.2	64.8	60.7	53.7	48.4	41.1	
	10%	DB	34.3	33.6	35.5	40.8	49.4	57.1	64.4	67.4	61.8	53.9	47.3	40.1	
		MCWB	33.0	32.1	33.6	38.4	45.3	52.6	60.9	63.7	59.3	51.7	46.0	38.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.1	42.0	40.5	46.7	53.1	60.3	66.7	68.9	65.7	59.0	52.8	46.3
			MCDB	42.4	43.1	42.6	49.1	56.8	63.1	68.8	71.3	67.9	59.7	53.4	46.8
2%		WB	38.9	37.5	37.7	42.7	50.0	57.3	64.7	67.1	63.5	56.2	50.6	43.6	
		MCDB	39.4	38.2	39.0	44.1	53.3	60.6	66.9	69.4	65.3	57.5	51.1	44.2	
5%		WB	35.9	34.3	35.8	40.5	47.9	55.3	63.1	65.6	61.6	54.2	48.6	41.2	
		MCDB	36.7	35.2	37.2	42.3	50.8	58.2	65.1	67.9	63.0	55.6	49.3	42.2	
10%		WB	33.2	32.3	33.9	38.6	46.2	53.4	61.6	64.4	60.0	52.1	46.2	38.9	
		MCDB	34.1	33.3	35.2	40.6	48.6	56.3	63.6	66.6	61.5	53.6	47.0	40.1	
Mean Daily Temperature Range	5% DB	MDBR	9.3	9.7	9.1	8.7	10.3	10.0	8.9	9.6	10.2	9.1	8.4	8.2	
		MCDBR	12.3	11.5	9.7	11.9	14.8	14.5	12.1	11.5	11.2	10.5	10.1	10.5	
		MCWBR	12.9	11.6	9.0	9.3	10.5	9.8	8.9	8.8	9.1	9.7	10.9	11.4	
	5% WB	MCDBR	12.5	11.8	9.6	11.0	12.2	12.5	10.5	10.1	9.6	9.8	9.9	10.6	
		MCWBR	13.3	12.3	9.4	9.5	9.5	9.2	8.3	8.3	8.6	9.7	10.9	11.7	
Clear-Sky Solar Irradiance	taub	0.306	0.302	0.331	0.353	0.363	0.385	0.414	0.396	0.368	0.349	0.321	0.304		
	taud	2.350	2.395	2.343	2.391	2.442	2.403	2.403	2.361	2.415	2.474	2.462	2.464	2.379	
	Ebn at Noon	243	274	282	285	285	279	268	269	267	253	238	229		
	Edh at Noon	23	27	33	35	35	36	37	34	29	25	21	20		
All-Sky Solar Radiation	RadAvg	263	511	952	1330	1636	1666	1590	1458	1128	692	346	208		
	RadStd	24	57	100	103	138	186	129	95	73	45	41	23		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+2.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.52	N/A	N/A	N/A	N/A

Nomenclature: See separate page