

PORT AUX BASQUES, NL, Canada

WMO: 711970

Lat: 47.5734N

Lon: 59.1531W

Elev: 40

StdP: 100.85

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-13.6	-11.8	-18.4	0.7	-12.9	-16.3	0.9	-11.0	25.4	-7.5	23.4	-6.4	10.8	300	0.853

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	21.1	18.3	20.0	17.6	19.0	17.0	19.0	20.2	18.1	19.4	17.4	18.6	5.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	19.7	17.6	12.6	18.9	16.8	12.0	18.2	54.1	20.3	51.5	19.4	49.1	18.6	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	17.9	15.7	DB	-15.9	23.6	2.8	1.1	-17.9	24.4	-19.6	25.1	-21.2	25.7	-23.3	26.6	(4)
(5)			WB	-16.4	20.3	2.9	1.4	-18.5	21.2	-20.2	22.0	-21.9	22.8	-24.0	23.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-4.0	-4.8	-2.6	1.3	5.9	10.1	14.8	16.5	12.6	8.0	3.4	-0.6	(6)
(7)		DBStd	7.68	3.58	4.17	3.72	2.63	2.43	2.48	1.96	1.91	2.60	2.75	3.31	3.42	(7)
(8)		HDD10.0	2263	434	414	391	259	129	28	0	0	7	74	198	328	(8)
(9)		HDD18.3	4831	692	648	649	509	386	248	111	62	172	320	447	587	(9)
(10)		CDD10.0	479	0	0	0	0	2	31	148	201	84	12	1	0	(10)
(11)		CDD18.3	6	0	0	0	0	0	0	1	4	1	0	0	0	(11)
(12)		CDH23.3	1	0	0	0	0	0	0	0	1	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	7.1	9.5	9.1	7.8	7.3	6.2	5.7	5.1	4.7	5.6	6.9	7.8	9.1	(14)
(15)	Precipitation	PrecAvg	1562	153	124	113	121	121	117	110	123	119	150	159	182	(15)
(16)		PrecMax	1860	251	305	241	252	228	225	280	246	209	245	246	370	(16)
(17)		PrecMin	1251	79	23	38	36	38	27	31	21	32	38	77	64	(17)
(18)		PrecStd	169	42	57	48	55	50	50	56	57	40	51	46	65	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	6.6	6.4	10.4	15.0	19.2	21.8	23.0	20.8	15.9	12.1	8.4	(19)
(20)			MCWB	5.4	5.4	4.4	7.8	10.2	14.6	18.0	19.5	18.3	14.1	11.3	7.6	(20)
(21)		2%	DB	4.2	3.6	4.2	7.6	12.8	17.1	20.2	21.6	18.9	14.5	10.7	6.9	(21)
(22)			MCWB	3.8	2.8	2.8	5.3	9.2	13.1	17.5	18.8	17.1	13.1	10.2	6.2	(22)
(23)		5%	DB	2.7	2.0	3.1	6.1	11.1	15.3	19.1	20.6	17.5	13.3	9.7	5.7	(23)
(24)			MCWB	2.0	1.1	1.9	4.4	8.3	12.4	16.8	18.2	15.9	12.0	9.1	5.1	(24)
(25)		10%	DB	1.3	0.9	2.0	4.9	9.6	13.9	18.0	19.7	16.6	12.2	8.5	4.5	(25)
(26)			MCWB	0.6	0.1	0.9	3.6	7.4	11.5	16.1	17.6	15.2	11.0	7.8	3.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	5.6	4.7	8.1	11.7	15.7	19.3	20.5	18.7	15.0	11.6	8.0	(27)
(28)			MADB	5.8	6.1	5.9	9.5	13.8	17.3	20.4	21.8	20.0	15.4	11.9	8.2	(28)
(29)		2%	WB	3.8	3.0	3.2	5.9	10.0	14.1	18.2	19.5	17.5	13.5	10.3	6.4	(29)
(30)			MADB	4.1	3.5	3.9	6.7	11.9	15.9	19.4	20.8	18.5	14.2	10.6	6.8	(30)
(31)		5%	WB	2.1	1.3	2.1	4.7	8.8	13.0	17.3	18.7	16.5	12.3	9.2	5.1	(31)
(32)			MADB	2.6	1.8	2.9	5.7	10.4	14.5	18.4	19.9	17.2	13.1	9.6	5.7	(32)
(33)		10%	WB	0.6	0.2	1.1	3.7	7.9	11.9	16.5	18.0	15.5	11.2	7.9	3.8	(33)
(34)			MADB	1.2	0.7	1.8	4.8	9.2	13.5	17.6	19.2	16.4	12.0	8.4	4.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.2	5.4	5.0	4.8	5.7	5.5	4.9	5.3	5.7	5.0	4.6	4.5	(35)
(36)			MADB	6.8	6.4	5.4	6.6	8.2	8.0	6.7	6.4	6.2	5.8	5.6	5.8	(36)
(37)			MCWBR	7.2	6.5	5.0	5.2	5.8	5.5	5.0	4.9	5.0	5.4	6.0	6.3	(37)
(38)		5% WB	MADB	6.9	6.5	5.3	6.1	6.8	6.9	5.9	5.6	5.3	5.4	5.5	5.9	(38)
(39)			MCWBR	7.4	6.8	5.2	5.3	5.3	5.1	4.6	4.6	4.8	5.4	6.1	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.302	0.331	0.353	0.363	0.385	0.414	0.396	0.368	0.349	0.321	0.304	(40)	
(41)		taud	2.350	2.395	2.343	2.391	2.442	2.403	2.361	2.415	2.474	2.462	2.464	2.379	(41)	
(42)		Ebn at Noon	767	865	888	900	900	879	846	847	842	798	750	722	(42)	
(43)		Edh at Noon	72	85	104	110	109	114	118	107	92	80	65	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.83	1.61	3.00	4.19	5.16	5.25	5.01	4.59	3.56	2.18	1.09	0.66	(44)	
(45)		RadStd	0.08	0.18	0.31	0.32	0.43	0.58	0.41	0.30	0.23	0.14	0.13	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.29	N/A	N/A	N/A	N/A

Nomenclature: See separate page