

VICTORIA HARTLAND, BC, Canada

WMO: 712027

Lat: 48.530N

Lon: 123.460W

Elev: 506

StdP: 14.43

Time Zone: -8.00 (NAP)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.3	29.1	12.7	10.7	30.2	19.5	14.9	34.7	25.9	33.1	22.8	37.1	8.9	0	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	83.2	65.7	79.9	64.2	76.7	63.1	67.9	79.6	66.2	76.7	64.5	73.6	7.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.7	89.9	72.3	62.1	84.9	70.2	60.7	80.7	68.4	32.4	79.7	31.1	77.0	29.8	73.7	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.7	17.8	15.3	DB	22.3	89.3	4.8	3.9	18.9	92.2	16.1	94.4	13.4	96.6	10.0	99.5	
			WB	20.3	68.9	5.6	3.4	16.3	71.4	13.0	73.4	9.9	75.3	5.8	77.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	41.2	42.5	44.4	48.6	54.4	59.8	65.1	64.7	60.1	51.1	44.4	40.4
	DBStd	10.30	5.98	4.62	4.90	5.46	5.84	5.67	5.63	4.88	5.07	4.43	5.60	5.45
	HDD50	1297	275	213	184	89	19	1	0	0	1	38	179	298
	HDD65	5124	737	631	640	493	335	179	68	68	162	431	618	762
	CDD50	1822	3	2	9	46	154	296	467	455	305	73	11	1
	CDD65	173	0	0	0	0	5	24	70	57	17	0	0	0
	CDH74	1320	0	0	0	2	37	203	584	402	92	0	0	0
	CDH80	284	0	0	0	0	3	49	157	68	7	0	0	0
Wind	WSAvg	5.6	6.3	6.3	6.2	5.6	5.4	5.5	5.2	5.0	5.0	5.3	5.7	6.3
Precipitation	PrecAvg	36.2	5.7	3.6	3.2	1.9	1.4	1.1	0.7	1.1	1.6	4.0	6.1	5.9
	PrecMax	47.1	9.5	8.9	6.4	4.1	3.0	2.6	1.6	3.5	5.1	12.2	13.3	9.4
	PrecMin	25.5	2.4	0.7	0.9	0.2	0.2	0.3	0.1	0.1	0.2	0.6	2.3	2.6
	PrecStd	5.7	1.9	1.7	1.2	0.9	0.7	0.5	0.4	0.9	1.2	2.4	3.0	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	55.9	60.8	70.1	78.6	85.8	89.9	85.7	80.8	68.2	58.2	54.1
		MCWB	53.4	50.6	53.3	55.6	60.0	63.3	68.4	66.0	63.6	58.1	55.7	52.7
	2%	DB	52.5	52.8	56.5	65.5	73.1	79.8	84.3	81.6	76.6	63.2	55.6	51.2
		MCWB	51.1	49.0	51.0	54.6	57.7	63.1	67.0	65.4	62.0	55.9	54.0	50.0
	5%	DB	50.6	50.7	53.8	61.4	68.9	74.9	80.0	78.7	73.0	60.1	53.5	49.2
		MCWB	49.2	47.3	49.4	52.4	56.9	61.6	64.9	64.3	61.0	54.9	51.9	47.9
	10%	DB	48.6	48.7	51.5	57.5	64.8	70.5	76.6	75.2	69.3	57.6	51.6	47.5
		MCWB	47.3	45.8	47.6	50.4	55.1	59.5	63.5	62.8	59.5	53.6	50.1	46.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	52.8	55.3	59.3	63.3	66.8	71.1	69.9	66.4	62.1	57.3	53.1
		MCDB	54.8	54.3	57.5	67.9	72.3	80.2	84.0	80.6	76.8	64.3	57.7	53.7
	2%	WB	51.7	50.3	52.5	55.8	60.6	64.6	68.4	67.8	64.4	58.8	54.7	50.4
		MCDB	52.4	51.7	55.2	62.9	68.8	76.1	81.1	78.2	73.0	60.9	55.2	51.0
	5%	WB	49.6	48.2	50.4	53.7	58.5	62.4	66.6	66.0	62.5	56.4	52.4	48.4
		MCDB	50.3	49.8	53.0	59.2	66.0	72.4	78.0	75.4	70.5	58.5	53.0	48.9
	10%	WB	47.7	46.5	48.5	51.6	56.3	60.3	64.6	64.2	60.7	54.1	50.3	46.5
		MCDB	48.4	48.0	50.8	56.6	63.4	68.6	74.0	72.6	66.6	56.5	51.2	47.1
Mean Daily Temperature Range	5% DB	MDBR	7.3	9.3	11.1	13.7	15.5	16.1	17.9	17.3	15.2	10.8	8.2	7.1
		MCDBR	8.4	11.4	13.4	19.2	21.3	22.3	22.6	22.3	20.1	14.0	9.8	8.2
	5% WB	MCWBR	6.7	7.9	8.6	10.5	10.6	10.1	10.0	9.8	9.7	8.5	7.5	6.8
		MCWBR	7.9	9.7	12.5	16.7	18.5	20.0	21.2	20.4	17.9	12.1	8.5	7.6
Clear-Sky Solar Irradiance	taub	0.313	0.311	0.326	0.353	0.371	0.351	0.343	0.347	0.333	0.326	0.319	0.308	
	taud	2.537	2.566	2.536	2.448	2.414	2.486	2.547	2.531	2.569	2.572	2.525	2.509	
	Ebn at Noon	243	272	285	285	283	289	290	284	278	262	237	228	
	Edh at Noon	19	23	27	33	35	33	31	30	26	22	19	17	
All-Sky Solar Radiation	RadAvg	293	573	896	1361	1741	1903	2079	1752	1246	685	351	235	
	RadStd	39	77	105	127	137	180	146	114	102	76	55	31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	-2.70	N/A	N/A	N/A	N/A	N/A	+742	+979	-320	N/A
(47) Regional (74 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page