

VICTORIA HARTLAND, BC, Canada

WMO: 712027

Lat: 48.530N

Lon: 123.460W

Elev: 154

StdP: 99.49

Time Zone: -8.00 (NAP)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.7	-1.6	-10.7	1.5	-1.0	-6.9	2.1	1.5	11.6	0.6	10.2	2.8	4.0	0	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	28.5	18.7	26.6	17.9	24.8	17.3	20.0	26.5	19.0	24.9	18.0	23.1	3.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	12.8	22.4	16.7	12.1	21.2	15.9	11.5	20.2	57.6	26.5	54.4	25.0	51.4	23.2	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.0	6.8	DB	-5.4	31.9	2.6	2.2	-7.3	33.4	-8.8	34.7	-10.3	35.9	-12.2	37.5	(4)
(5)			WB	-6.5	20.5	3.1	1.9	-8.7	21.9	-10.5	23.0	-12.3	24.1	-14.5	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	5.1	5.8	6.9	9.2	12.4	15.5	18.4	18.1	15.6	10.6	6.9	4.7		
	DBStd	5.72	3.32	2.57	2.72	3.03	3.24	3.15	3.13	2.71	2.82	2.46	3.11	3.03		
	HDD10.0	721	153	118	102	49	11	0	0	1	21	99	166			
	HDD18.3	2847	409	351	356	274	186	99	38	38	90	239	343	423		
	CDD10.0	1012	2	1	5	26	86	164	259	253	169	41	6	1		
	CDD18.3	96	0	0	0	0	3	13	39	32	9	0	0	0		
	CDH23.3	733	0	0	0	1	21	113	324	223	51	0	0	0		
	CDH26.7	158	0	0	0	0	2	27	87	38	4	0	0	0		
(14) Wind	WSAvg	2.5	2.8	2.8	2.8	2.5	2.4	2.4	2.3	2.2	2.2	2.4	2.5	2.8		
(15) Precipitation	PrecAvg	920	144	91	82	49	35	29	17	27	40	101	154	150		
	PrecMax	1196	242	225	163	105	75	65	41	88	129	309	339	240		
	PrecMin	648	61	17	23	6	5	8	2	3	4	15	58	66		
	PrecStd	144	48	42	30	24	19	13	10	22	31	60	77	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	13.3	16.0	21.1	25.9	29.9	32.1	29.8	27.1	20.1	14.5	12.3		
		MCWB	11.9	10.3	11.8	13.1	15.6	17.4	20.2	18.9	17.6	14.5	13.2	11.5		
	2%	DB	11.4	11.5	13.6	18.6	22.9	26.6	29.1	27.6	24.8	17.3	13.1	10.7		
		MCWB	10.6	9.5	10.5	12.6	14.3	17.3	19.4	18.6	16.7	13.3	12.2	10.0		
	5%	DB	10.3	10.4	12.1	16.3	20.5	23.8	26.7	26.0	22.8	15.6	12.0	9.6		
		MCWB	9.5	8.5	9.6	11.3	13.8	16.4	18.3	18.0	16.1	12.7	11.0	8.8		
	10%	DB	9.2	9.3	10.8	14.2	18.2	21.4	24.8	24.0	20.7	14.2	10.9	8.6		
		MCWB	8.5	7.7	8.7	10.2	12.8	15.3	17.5	17.1	15.3	12.0	10.1	7.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	11.5	13.0	15.2	17.4	19.3	21.7	21.0	19.1	16.7	14.1	11.7		
		MCDB	12.7	12.4	14.2	19.9	22.4	26.8	28.9	27.0	24.9	17.9	14.3	12.1		
	2%	WB	10.9	10.2	11.4	13.2	15.9	18.1	20.2	19.9	18.0	14.9	12.6	10.2		
		MCDB	11.3	10.9	12.9	17.2	20.5	24.5	27.3	25.7	22.8	16.1	12.9	10.6		
	5%	WB	9.8	9.0	10.2	12.0	14.7	16.9	19.2	18.9	17.0	13.5	11.3	9.1		
		MCDB	10.2	9.9	11.7	15.1	18.9	22.5	25.5	24.1	21.4	14.7	11.7	9.4		
	10%	WB	8.7	8.1	9.1	10.9	13.5	15.7	18.1	17.9	15.9	12.3	10.2	8.1		
		MCDB	9.1	8.9	10.4	13.6	17.4	20.3	23.3	22.6	19.2	13.6	10.7	8.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	5.1	6.2	7.6	8.6	8.9	10.0	9.6	8.4	6.0	4.6	4.0		
		MCDBR	4.7	6.3	7.4	10.7	11.8	12.4	12.6	12.4	11.1	7.8	5.4	4.5		
	5% WB	MCWBR	3.7	4.4	4.8	5.8	5.9	5.6	5.6	5.4	5.4	4.7	4.2	3.8		
		MCWBR	4.4	5.4	6.9	9.3	10.3	11.1	11.8	11.3	9.9	6.7	4.7	4.2		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.311	0.326	0.353	0.371	0.351	0.343	0.347	0.333	0.326	0.319	0.308		
		taud	2.537	2.566	2.536	2.448	2.414	2.486	2.547	2.531	2.569	2.572	2.525	2.509		
	Ebn at Noon		766	859	897	898	891	910	913	895	877	826	748	719		
		Edh at Noon	60	72	86	104	111	104	97	94	83	70	60	55		
(44) All-Sky Solar Radiation	RadAvg		0.92	1.81	2.83	4.29	5.49	6.00	6.55	5.52	3.93	2.16	1.11	0.74		
	RadStd		0.12	0.24	0.33	0.40	0.43	0.57	0.46	0.36	0.32	0.24	0.17	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (74 neighbors)										
		-1.50	N/A	N/A	N/A	N/A	N/A	+412	+544	-178	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page