

SQUAMISH, BC, Canada

WMO: 712070

Lat: 49.780N

Lon: 123.160W

Elev: 176

StdP: 14.60

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	18.6	22.6	-1.8	5.0	24.8	5.7	7.4	30.7	20.0	29.4	16.8	32.3	6.0	20	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.7	85.3	64.6	81.7	63.7	78.3	62.8	66.7	80.4	65.2	77.9	63.8	75.5	7.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.1	83.8	69.1	60.5	79.2	67.6	59.3	75.9	66.7	31.3	80.9	30.2	78.2	29.1	75.6	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.1	11.6	9.9	DB	14.6	92.7	4.2	3.8	11.5	95.4	9.1	97.6	6.7	99.7	3.7	102.5	(4)
(5)			WB	12.7	68.8	3.4	2.4	10.2	70.5	8.2	71.9	6.3	73.2	3.8	74.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	35.4	38.3	42.1	48.1	55.0	59.8	65.0	64.7	58.7	49.0	40.3	34.2	(6)
(7)		DBStd	11.93	5.56	4.78	4.96	4.97	5.50	5.01	4.80	4.39	4.94	4.78	5.68	5.59	(7)
(8)		HDD50	1997	452	329	249	94	16	0	0	0	1	76	292	488	(8)
(9)		HDD65	5869	917	749	710	508	313	171	57	58	198	495	740	953	(9)
(10)		CDD50	1736	0	0	4	36	170	295	465	457	262	45	2	0	(10)
(11)		CDD65	135	0	0	0	0	2	16	58	50	9	0	0	0	(11)
(12)		CDH74	1877	0	0	1	15	95	271	747	605	143	0	0	0	(12)
(13)		CDH80	491	0	0	0	2	13	80	218	152	26	0	0	0	(13)
(14)	Wind	WSAvg	3.6	3.2	3.6	3.8	4.0	4.1	4.2	4.2	3.8	3.2	2.9	3.1	3.2	(14)
(15)	Precipitation	PrecAvg	81.1	11.4	7.8	8.5	4.8	3.1	2.7	2.0	2.6	4.2	9.5	12.8	11.6	(15)
(16)		PrecMax	110.1	22.0	19.3	16.1	10.6	6.2	5.8	4.4	9.2	10.1	22.2	26.9	19.1	(16)
(17)		PrecMin	60.9	4.4	0.4	1.9	0.7	0.8	1.0	0.5	0.4	1.2	0.0	4.6	4.8	(17)
(18)		PrecStd	12.7	3.8	4.2	3.4	2.3	1.4	1.3	1.2	2.0	2.4	4.6	6.3	3.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.6	55.7	65.3	75.3	81.7	87.7	91.5	88.5	83.3	69.5	56.2	50.0	(19)
(20)			MCWB	45.0	44.4	50.3	55.1	59.3	63.7	66.9	64.9	62.3	54.7	53.3	47.4	(20)
(21)		2%	DB	46.6	51.0	58.2	67.9	76.3	81.6	85.7	84.2	78.2	64.5	52.5	45.7	(21)
(22)			MCWB	44.1	43.8	47.4	52.6	58.4	62.2	65.9	65.0	61.4	53.6	49.6	44.2	(22)
(23)		5%	DB	44.3	47.7	53.9	62.9	72.1	76.0	81.5	80.5	73.5	59.6	49.9	43.1	(23)
(24)			MCWB	42.8	43.2	45.5	50.0	57.0	61.0	64.5	64.2	60.7	52.7	47.9	41.8	(24)
(25)		10%	DB	42.2	45.1	50.3	58.5	67.5	71.5	77.8	76.9	69.2	56.7	47.8	40.9	(25)
(26)			MCWB	41.0	41.8	44.5	48.6	55.7	59.5	63.5	63.3	59.3	52.5	46.3	39.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.4	48.9	52.3	57.2	61.8	65.8	69.9	68.2	65.5	59.5	54.4	48.6	(27)
(28)			MCD B	48.3	51.1	60.7	73.0	75.8	81.6	84.0	81.2	77.8	64.4	55.5	49.7	(28)
(29)		2%	WB	44.8	45.9	49.5	54.1	59.9	63.6	67.3	66.4	63.4	56.7	50.6	44.4	(29)
(30)			MCD B	45.8	48.8	55.0	64.4	72.6	77.7	81.8	79.2	73.7	59.6	51.8	45.4	(30)
(31)		5%	WB	43.1	44.2	47.3	51.9	58.3	61.6	65.6	65.1	61.8	54.7	48.6	42.2	(31)
(32)			MCD B	44.0	46.6	51.9	60.2	69.3	73.6	78.7	77.3	70.8	57.9	49.6	43.1	(32)
(33)		10%	WB	41.3	42.6	45.6	49.9	56.4	59.9	64.0	63.7	60.0	53.0	46.8	40.2	(33)
(34)			MCD B	42.1	44.5	49.1	56.2	65.5	69.9	75.9	74.8	67.4	56.0	47.8	40.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.6	12.4	14.6	18.1	19.7	18.1	20.7	20.6	18.9	13.9	9.5	7.5	(35)
(36)			MCDBR	11.5	17.4	22.6	28.3	29.5	28.7	29.1	28.8	28.1	21.5	12.8	10.2	(36)
(37)			MCWBR	8.7	10.7	12.3	14.2	13.8	12.5	11.7	11.9	12.7	11.8	9.3	8.3	(37)
(38)		5% WB	MCD BR	9.8	13.4	18.0	23.0	24.0	24.8	25.7	24.8	23.3	15.6	9.7	9.3	(38)
(39)			MCWBR	8.0	9.3	10.9	12.3	12.1	11.3	11.2	11.1	11.6	9.8	8.0	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.305	0.331	0.370	0.385	0.379	0.375	0.377	0.355	0.340	0.315	0.297	(40)	
(41)		taud	2.252	2.326	2.266	2.185	2.248	2.350	2.389	2.406	2.467	2.476	2.378	2.292	(41)	
(42)		Ebn at Noon	226	265	277	276	277	279	279	272	267	251	227	215	(42)	
(43)		Edh at Noon	23	27	35	42	41	38	36	34	29	24	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	266	538	789	1253	1653	1709	1923	1652	1132	626	306	213	(44)	
(45)		RadStd	47	84	121	149	154	219	188	134	103	97	62	36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+153	+56
(47) Regional (61 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page