

SALMON ARM, BC, Canada

WMO: 712180

Lat: **50.7030N**Lon: **119.2906W**Elev: **351**StdP: **97.18**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.2	-13.2	-21.0	0.6	-16.3	-16.9	0.9	-12.5	8.3	-7.1	7.0	-7.1	1.5	210	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	31.8	20.2	30.0	19.5	28.2	18.6	21.7	29.7	20.4	28.3	19.3	26.7	1.6	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	14.1	26.4	17.5	13.1	24.4	16.4	12.2	23.0	64.8	29.8	60.4	28.5	56.4	26.7	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.2	4.7	3.5	-20.3	34.9	4.5	1.9	-23.6	36.3	-26.2	37.4	-28.8	38.5	-32.1	39.9		
(5)			-20.5	24.2	4.8	1.5	-23.9	25.3	-26.7	26.1	-29.4	26.9	-32.9	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-2.1	-1.0	3.8	8.8	13.7	17.1	20.5	19.5	14.4	7.6	2.3	-2.1
	DBStd	8.87	5.05	4.62	3.73	2.87	3.23	2.93	2.89	2.80	3.02	3.15	4.30	4.74
	HDD10.0	1636	376	309	192	56	6	0	0	0	3	86	232	376
	HDD18.3	3722	634	543	449	286	147	58	13	21	123	332	482	634
	CDD10.0	1122	0	0	1	20	121	213	326	294	134	13	1	0
	CDD18.3	164	0	0	0	0	3	20	80	57	4	0	0	0
	CDH23.3	2202	0	0	0	3	89	294	1001	732	83	0	0	0
	CDH26.7	733	0	0	0	0	14	81	386	239	13	0	0	0
Wind	WSAvg	1.3	1.2	1.2	1.4	1.6	1.5	1.4	1.5	1.4	1.2	1.2	1.3	1.3
Precipitation	PrecAvg	516	64	36	30	27	39	48	33	34	36	48	53	68
	PrecMax	755	88	66	57	54	107	105	121	74	92	100	129	122
	PrecMin	344	33	15	15	7	2	10	0	4	4	3	11	13
	PrecStd	94	14	12	11	11	23	24	27	20	26	25	33	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	9.5	15.9	22.5	28.3	31.8	34.7	33.1	28.2	19.2	13.0	8.0
		MCWB	4.7	5.8	9.7	14.0	18.1	20.2	21.2	20.2	17.8	13.7	8.5	4.9
	2%	DB	5.3	7.2	13.2	19.6	25.9	29.0	32.5	31.0	25.8	16.5	10.5	5.7
		MCWB	3.5	4.6	7.9	11.9	16.7	19.2	20.5	20.0	17.8	12.1	8.0	3.7
	5%	DB	3.8	5.6	11.4	17.4	23.6	26.8	30.8	29.3	23.5	14.7	8.9	4.1
		MCWB	2.8	3.5	7.0	10.5	15.0	17.8	19.9	19.2	16.3	10.9	7.0	2.8
	10%	DB	2.7	4.2	9.6	15.4	21.3	24.5	28.9	27.6	21.3	13.1	7.6	2.9
		MCWB	2.0	2.8	5.9	9.5	14.0	16.7	18.9	18.4	15.1	10.1	6.2	2.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	6.7	10.5	15.0	19.5	22.2	23.8	22.9	19.9	14.9	10.2	5.7
		MCDB	7.2	8.9	14.4	20.6	26.8	30.0	32.1	30.4	25.7	18.1	11.7	6.9
	2%	WB	4.0	5.2	8.8	12.9	17.5	20.3	22.0	21.3	18.2	13.2	8.7	4.2
		MCDB	4.9	6.5	12.0	18.2	23.8	27.5	30.5	28.9	24.1	15.3	9.8	5.1
	5%	WB	2.9	4.0	7.6	11.5	16.0	18.5	20.7	20.1	17.0	11.7	7.5	3.0
		MCDB	3.6	5.1	10.4	16.1	21.8	25.3	29.0	27.8	22.0	13.8	8.5	3.8
	10%	WB	2.2	3.0	6.4	10.2	14.7	17.2	19.5	18.9	15.8	10.4	6.4	2.0
		MCDB	2.7	3.9	9.0	14.3	20.3	23.1	27.4	26.2	20.4	12.5	7.4	2.7
Mean Daily Temperature Range	5% DB	MDBR	5.4	7.6	9.7	12.3	13.0	12.6	14.7	14.9	12.8	9.4	6.1	5.2
		MCDBR	5.7	8.4	12.0	16.0	17.4	17.4	18.5	18.1	16.2	11.7	7.6	5.7
		MCWBR	4.5	6.0	7.3	9.2	9.7	9.6	9.5	9.5	9.5	7.5	5.3	4.5
	5% WB	MCDBR	5.3	7.3	10.9	14.7	15.7	16.3	17.6	17.3	15.3	10.5	6.7	5.4
	MCWBR	4.2	5.5	7.1	8.9	9.2	9.5	9.7	9.6	9.5	7.2	4.9	4.3	
Clear-Sky Solar Irradiance	taub	0.295	0.285	0.318	0.348	0.372	0.371	0.365	0.375	0.350	0.334	0.303	0.273	
	taud	2.250	2.350	2.364	2.369	2.360	2.396	2.446	2.413	2.466	2.479	2.446	2.369	
	Ebn at Noon	719	856	886	894	883	885	885	857	844	789	726	707	
	Edh at Noon	70	82	98	110	116	113	106	104	89	73	58	54	
All-Sky Solar Radiation	RadAvg	0.81	1.79	2.95	4.38	5.28	5.53	6.22	5.34	3.63	1.98	0.87	0.62	
	RadStd	0.09	0.18	0.33	0.37	0.45	0.55	0.54	0.34	0.33	0.27	0.11	0.08	