

HOLLAND ROCK, BC, Canada

WMO: 712190

Lat: **54.172N**Lon: **130.361W**Elev: **21**StdP: **14.68**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.1	26.2	2.4	6.2	28.1	8.9	8.7	30.2	40.4	42.7	36.4	42.8	15.9	60	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	62.1	57.1	60.2	56.4	59.0	55.9	58.4	60.1	57.5	59.1	56.6	58.3	10.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.4	70.4	59.4	56.5	68.0	58.5	55.6	65.9	57.8	25.3	60.4	24.7	59.3	24.2	58.5	62.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.3	31.8	28.1	19.4	69.3	6.3	4.4	14.9	72.5	11.2	75.0	7.6	77.5	3.0	80.7		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	39.6	39.3	40.1	44.0	48.1	52.0	55.0	56.0	53.8	48.9	43.5	40.0		
	DBStd	7.42	6.60	5.13	5.31	3.71	3.28	2.73	2.13	2.17	2.70	3.46	4.78	5.41		
	HDD50	1768	323	299	308	184	77	7	0	0	3	60	196	311		
	HDD65	6672	788	719	773	630	524	390	311	281	337	499	644	776		
	CDD50	574	0	0	0	4	18	67	154	185	116	26	3	1		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.4	16.2	14.0	15.0	12.5	10.4	9.3	8.3	8.2	10.2	13.1	15.6	16.6		
	PrecAvg	107.7	11.4	7.7	8.9	7.3	4.9	4.3	4.6	6.8	10.4	14.9	13.3	12.7		
(15) Precipitation	PrecMax	136.1	16.8	12.6	16.0	14.1	11.6	7.2	8.0	12.1	21.4	21.1	25.0	28.4		
	PrecMin	82.7	4.7	4.5	5.0	3.9	2.1	2.2	2.2	2.7	3.8	7.7	8.0	4.8		
	PrecStd	14.4	3.1	2.7	2.8	2.5	2.6	1.4	1.7	2.8	4.3	3.8	3.9	5.1		
	PrecStd	14.4	3.1	2.7	2.8	2.5	2.6	1.4	1.7	2.8	4.3	3.8	3.9	5.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	51.3	52.9	61.4	63.0	65.4	62.4	65.3	64.1	59.1	54.7	53.1		
		MCWB	45.9	46.5	44.8	48.0	50.5	57.0	57.9	59.7	59.1	51.9	48.0	45.9		
	2%	DB	49.6	48.8	49.5	53.5	56.2	59.1	60.2	61.7	60.7	56.4	52.3	50.3		
		MCWB	45.3	44.9	44.6	47.8	50.8	55.2	56.8	58.1	56.1	51.5	48.0	45.2		
	5%	DB	48.2	47.2	47.5	50.3	53.6	57.0	59.1	60.1	58.6	54.8	50.9	48.6		
		MCWB	44.4	43.8	43.3	46.2	50.0	53.7	56.3	57.1	55.0	50.7	47.4	44.3		
	10%	DB	46.8	45.5	46.0	48.4	52.2	55.5	58.2	58.9	57.2	53.3	49.5	46.9		
		MCWB	43.4	42.7	42.5	44.8	49.3	52.8	55.6	56.5	54.2	49.9	46.3	43.5		
	0.4%	WB	48.5	48.2	48.4	50.0	52.9	57.7	58.4	59.6	60.7	55.2	50.3	47.6		
		MCDB	50.9	50.6	50.5	52.6	56.5	60.8	60.2	61.4	63.7	56.6	52.6	51.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.7	46.2	46.0	48.3	51.4	55.7	57.5	58.5	58.0	53.8	48.8	45.7		
		MCDB	49.2	49.0	48.5	51.2	54.1	58.5	59.1	59.9	60.1	55.6	51.2	48.9		
	5%	WB	45.2	44.8	44.6	46.6	50.6	54.5	56.7	57.8	56.5	52.0	47.5	44.7		
		MCDB	47.8	47.4	47.5	49.2	53.0	56.8	58.4	59.2	58.3	53.8	49.9	47.7		
	10%	WB	43.8	43.4	43.3	45.3	49.8	53.4	56.0	57.0	55.3	50.8	46.2	43.5		
		MCDB	46.5	46.1	46.1	48.0	52.0	55.5	57.6	58.4	56.9	52.9	48.7	46.3		
	5% DB	MDBR	5.8	5.7	6.0	6.2	5.8	5.1	4.6	5.2	5.5	5.5	5.6	5.6		
		MCDBR	7.0	7.1	7.5	9.3	8.6	7.4	6.1	7.0	7.7	6.9	6.8	7.4		
		MCWBR	4.6	4.1	4.5	5.0	4.9	3.9	3.8	4.1	4.6	4.4	5.0	4.8		
		MCWBR	6.5	5.9	6.2	7.7	6.9	6.4	5.7	6.1	6.8	5.5	6.1	6.5		
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.8	4.3	4.9	5.1	4.5	4.1	4.0	4.2	4.9	4.4	5.1	5.0		
		MCWBR	4.8	4.3	4.9	5.1	4.5	4.1	4.0	4.2	4.9	4.4	5.1	5.0		
	Clear-Sky Solar Irradiance	taub	0.302	0.309	0.337	0.372	0.360	0.383	0.368	0.366	0.358	0.339	0.314	0.292		
		taud	2.366	2.467	2.397	2.313	2.434	2.396	2.485	2.508	2.503	2.463	2.343	2.308		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	209	253	267	271	281	275	277	272	259	236	199	184		
		Edh at Noon	17	22	29	36	34	35	32	29	26	22	17	15		
(44) All-Sky Solar Radiation	RadStd	RadAvg	165	423	751	1205	1541	1626	1490	1288	848	467	216	133		
		RadStd	22	74	97	75	145	125	171	111	97	68	30	22		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page