

HOLLAND ROCK, BC, Canada

WMO: 712190

Lat: **54.172N**Lon: **130.361W**Elev: **7**StdP: **101.25**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.0	-3.2	-16.4	0.9	-2.2	-12.8	1.2	-1.0	18.1	5.9	16.3	6.0	7.1	60	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.9	16.7	13.9	15.7	13.5	15.0	13.3	14.7	15.6	14.1	15.1	13.7	14.6	4.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.1	15.2	13.6	9.7	14.7	13.1	9.4	14.3	41.0	15.8	39.6	15.2	38.4	14.7	16.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.2	14.2	12.6	-7.0	20.7	3.5	2.4	-9.5	22.5	-11.6	23.9	-13.6	25.3	-16.1	27.0		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	4.2	4.1	4.5	6.7	8.9	11.1	12.8	13.3	12.1	9.4	6.4	4.4
	DBStd	4.12	3.67	2.85	2.95	2.06	1.82	1.52	1.18	1.20	1.50	1.92	2.66	3.01
	HDD10.0	982	179	166	171	102	43	4	0	0	2	33	109	173
	HDD18.3	3707	438	399	429	350	291	217	173	156	187	277	358	431
	CDD10.0	319	0	0	0	2	10	37	86	103	64	14	2	1
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.6	7.3	6.3	6.7	5.6	4.6	4.1	3.7	3.7	4.5	5.8	7.0	7.4
Precipitation	PrecAvg	2736	290	196	227	185	125	109	116	172	263	379	338	323
	PrecMax	3457	427	319	407	358	294	184	203	307	544	536	634	722
	PrecMin	2101	119	114	126	100	53	55	57	69	96	195	203	121
	PrecStd	366	78	68	70	64	65	35	42	71	108	97	100	129
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	10.7	11.6	16.3	17.2	18.6	16.9	18.5	17.8	15.1	12.6	11.7
		MCWB	7.7	8.0	7.1	8.9	10.3	13.9	14.4	15.4	15.1	11.1	8.9	7.7
	2%	DB	9.8	9.4	9.7	12.0	13.4	15.0	15.7	16.5	16.0	13.6	11.3	10.2
		MCWB	7.4	7.2	7.0	8.8	10.4	12.9	13.8	14.5	13.4	10.8	8.9	7.4
	5%	DB	9.0	8.4	8.6	10.1	12.0	13.9	15.1	15.6	14.8	12.7	10.5	9.2
		MCWB	6.9	6.5	6.3	7.9	10.0	12.0	13.5	14.0	12.8	10.4	8.5	6.8
	10%	DB	8.2	7.5	7.8	9.1	11.2	13.1	14.5	14.9	14.0	11.8	9.7	8.3
		MCWB	6.3	5.9	5.8	7.1	9.6	11.6	13.1	13.6	12.3	9.9	7.9	6.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.0	9.1	10.0	11.6	14.3	14.7	15.3	15.9	12.9	10.2	8.7
		MCDB	10.5	10.3	10.3	11.4	13.6	16.0	15.7	16.3	17.6	13.7	11.5	10.8
	2%	WB	8.2	7.9	7.8	9.0	10.8	13.2	14.1	14.7	14.4	12.1	9.3	7.6
		MCDB	9.6	9.5	9.2	10.7	12.3	14.7	15.1	15.5	15.6	13.1	10.6	9.4
	5%	WB	7.3	7.1	7.0	8.1	10.4	12.5	13.7	14.3	13.6	11.1	8.6	7.0
		MCDB	8.8	8.6	8.6	9.6	11.7	13.8	14.6	15.1	14.6	12.1	9.9	8.7
	10%	WB	6.6	6.3	6.3	7.4	9.9	11.9	13.3	13.9	12.9	10.5	7.9	6.4
		MCDB	8.0	7.8	7.8	8.9	11.1	13.0	14.2	14.7	13.9	11.6	9.3	7.9
Mean Daily Temperature Range	5% DB	MDBR	3.2	3.2	3.4	3.4	3.2	2.9	2.5	2.9	3.1	3.0	3.1	3.1
		MCDBR	3.9	3.9	4.2	5.2	4.8	4.1	3.4	3.9	4.3	3.8	3.8	4.1
		MCWBR	2.6	2.3	2.5	2.8	2.7	2.2	2.1	2.3	2.5	2.4	2.8	2.7
	5% WB	MCDBR	3.6	3.3	3.5	4.3	3.9	3.6	3.2	3.4	3.8	3.0	3.4	3.6
	MCWBR	2.7	2.4	2.7	2.8	2.5	2.3	2.2	2.3	2.7	2.5	2.8	2.8	
Clear-Sky Solar Irradiance	taub	0.302	0.309	0.337	0.372	0.360	0.383	0.368	0.366	0.358	0.339	0.314	0.292	
	taud	2.366	2.467	2.397	2.313	2.434	2.396	2.485	2.508	2.503	2.463	2.343	2.308	
	Ebn at Noon	659	797	843	855	887	866	874	856	815	743	628	581	
	Edh at Noon	55	69	91	113	106	111	100	92	82	69	55	47	
All-Sky Solar Radiation	RadAvg	0.52	1.33	2.37	3.80	4.86	5.13	4.70	4.06	2.67	1.47	0.68	0.42	
	RadStd	0.07	0.23	0.31	0.24	0.46	0.39	0.54	0.35	0.31	0.21	0.10	0.07	