

LUCY ISLAND LIGHTSTATION, BC, Canada

WMO: 712200

Lat: 54.296N

Lon: 130.609W

Elev: 74

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.1	26.4	1.9	6.1	26.1	10.2	9.3	30.9	52.6	43.1	49.1	42.2	12.3	50	0.783

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.1	63.8	58.2	61.8	57.7	60.2	56.8	59.9	62.2	58.8	61.0	57.8	59.9	7.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.7	73.9	60.7	57.5	70.8	59.8	56.6	68.5	59.0	26.3	62.2	25.6	61.2	25.0	60.2	63.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max			Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 45.2	40.2	35.0		19.0	70.0	6.1	4.3	14.6	73.1	11.0	75.6	7.5	78.0	3.1	81.1	
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	38.9	39.0	40.4	44.4	48.8	52.7	55.8	56.7	53.8	48.4	42.8	39.8
	DBStd	7.70	6.06	5.04	4.75	3.60	3.62	3.17	2.85	2.59	2.95	3.42	5.03	5.06
	HDD50	1802	345	307	297	172	65	8	1	0	4	69	217	317
	HDD65	6627	810	727	762	618	502	370	285	257	336	514	665	781
	CDD50	652	0	0	0	4	28	89	182	209	119	20	1	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	14.1	17.1	16.0	16.0	14.2	11.9	10.8	9.7	9.9	12.3	15.6	17.5	18.2
(15) Precipitation	PrecAvg	93.1	9.6	7.1	7.5	6.2	4.0	3.9	4.1	6.1	8.5	12.2	11.5	10.6
	PrecMax	120.0	20.0	12.3	15.8	12.2	11.1	6.8	7.4	11.7	18.5	18.3	20.7	22.6
	PrecMin	64.6	3.5	3.8	2.5	3.4	0.4	1.2	2.0	2.5	3.7	4.3	5.6	4.3
	PrecStd	15.0	3.3	2.5	2.8	2.2	2.5	1.4	1.5	2.8	3.7	3.9	3.4	3.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.2	50.4	52.5	58.8	63.3	66.8	65.2	67.3	64.4	58.0	53.6	51.9
		MCWB	46.6	46.4	46.7	48.7	52.0	59.4	59.5	60.7	58.3	53.2	49.3	45.8
	2%	DB	48.3	48.3	49.3	53.7	57.7	61.2	62.5	63.7	60.9	55.5	51.3	49.4
		MCWB	45.6	45.1	45.0	47.9	51.9	56.5	58.7	59.1	55.9	52.2	48.9	45.4
	5%	DB	46.8	46.7	47.4	50.5	55.0	58.5	60.9	61.8	59.0	53.9	50.2	47.8
		MCWB	44.2	43.8	43.8	46.2	51.0	55.0	57.6	58.2	56.0	50.7	48.3	44.3
	10%	DB	45.6	45.2	46.0	48.7	53.2	56.7	59.5	60.2	57.6	52.7	48.8	46.3
		MCWB	43.1	42.6	42.9	45.1	49.8	53.9	56.8	57.3	55.0	49.7	46.6	43.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	48.6	49.0	50.4	54.0	59.2	60.9	61.4	59.8	55.8	51.3	47.5
		MCDB	48.8	49.8	51.6	53.4	59.5	63.1	63.1	64.6	62.6	56.9	52.6	50.4
	2%	WB	46.1	46.4	46.6	48.6	52.4	57.1	59.6	60.1	58.1	54.1	50.1	45.8
		MCDB	47.6	48.2	49.2	51.1	55.8	60.2	61.9	62.2	60.5	55.4	51.3	48.6
	5%	WB	44.6	44.9	45.3	46.9	51.4	56.0	58.6	59.0	57.0	51.9	49.0	44.7
		MCDB	46.4	47.0	48.0	49.5	54.2	58.7	60.8	61.0	59.1	53.5	50.5	47.4
	10%	WB	43.3	43.5	44.1	45.8	50.4	55.0	57.7	57.9	56.0	50.8	47.7	43.4
		MCDB	45.1	45.7	46.8	48.4	52.8	57.4	59.7	59.8	57.8	52.6	49.5	45.9
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.5	6.1	6.4	6.3	5.9	5.7	6.1	6.0	5.3	5.4	5.2
		MCDBR	6.0	6.5	7.3	8.8	8.8	8.7	7.8	8.6	8.0	6.4	6.2	6.6
	5% WB	MCWBR	4.8	4.6	4.6	4.8	4.8	4.5	4.2	4.7	4.4	4.3	4.6	4.3
		MCWBR	5.6	5.9	6.7	7.0	7.6	7.3	6.5	7.8	8.0	5.9	5.4	6.1
(40) Clear-Sky Solar Irradiance	taub		0.304	0.311	0.336	0.371	0.363	0.377	0.368	0.363	0.355	0.337	0.312	0.294
		taud	2.393	2.506	2.451	2.351	2.440	2.422	2.493	2.527	2.521	2.483	2.366	2.325
	Ebn at Noon		209	253	269	272	280	276	277	272	259	237	200	183
		Edh at Noon	17	21	27	35	33	34	31	29	26	21	17	15
(44) All-Sky Solar Radiation	RadAvg		163	421	759	1212	1556	1639	1484	1280	845	465	216	131
	RadStd		21	73	93	74	142	123	167	114	95	67	29	23

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.33	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page