

POLLOCKVILLE AGDM, AB, Canada

WMO: 712590

Lat: 51.1253N

Lon: 111.7053W

Elev: 750

StdP: 92.63

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -31.9	(c) -28.4	(d) -35.3	(e) 0.1	(f) -31.8	(g) -31.5	(h) 0.2	(i) -28.3	(j) 12.9	(k) -4.4	(l) 11.0	(m) -4.9	(n) 2.3	(o) 210	(p) 0.717

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.0	(c) 31.9	(d) 16.9	(e) 29.7	(f) 16.7	(g) 27.6	(h) 15.9	(i) 18.7	(j) 27.8	(k) 17.8	(l) 26.6	(m) 16.9	(n) 25.4	(o) 4.8	(p) 190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	12.3	21.5	14.6	11.4	20.5	13.6	10.7	19.6	56.2	27.7	53.1	26.8	50.2	25.4	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.4	(b) 10.6	(c) 9.1	(e) -36.4	(f) 35.1	(g) 3.1	(h) 1.9	(i) -38.6	(j) 36.4	(k) -40.4	(l) 37.5	(m) -42.2	(n) 38.6	(o) -44.4	(p) 40.0		
(4) 12.4	(5) 10.6	(6) 9.1	(7) -36.5	(8) 21.2	(9) 3.0	(10) 1.1	(11) -38.7	(12) 22.0	(13) -40.5	(14) 22.6	(15) -42.2	(16) 23.2	(17) -44.4	(18) 24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.5	-10.9	-11.1	-3.2	4.5	10.6	14.8	18.4	17.2	11.7	4.5	-4.5	-11.3		
	DBStd	12.35	8.27	7.85	7.72	5.15	4.15	3.21	3.16	3.48	4.48	5.20	7.43	7.76		
	HDD10.0	3179	649	592	408	172	43	2	0	1	32	181	437	662		
	HDD18.3	5508	908	826	666	415	239	114	38	64	203	429	686	920		
	CDD10.0	793	0	0	1	8	63	146	260	223	82	11	1	0		
	CDD18.3	80	0	0	0	0	1	8	40	28	4	0	0	0		
	CDH23.3	1859	0	0	1	7	90	201	779	587	187	8	0	0		
	CDH26.7	640	0	0	0	0	15	51	293	217	63	1	0	0		
(14) Wind	WSAvg	4.1	3.9	3.7	4.3	4.8	4.7	4.4	4.0	3.9	4.0	4.1	3.8	3.5		
(15) Precipitation	PrecAvg	355	16	10	15	22	40	73	59	48	28	14	14	12		
	PrecMax	465	42	23	36	51	83	153	148	87	74	34	53	19		
	PrecMin	264	3	1	4	3	4	14	23	11	3	5	1	2		
	PrecStd	66	9	5	8	13	24	32	27	25	18	7	12	5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	7.0	17.4	23.9	28.5	31.2	34.8	34.2	31.9	24.6	16.1	7.7		
		MCWB	3.7	2.8	8.3	11.4	14.4	17.3	18.1	16.9	15.3	12.4	8.2	4.1		
	2%	DB	4.7	4.0	13.5	20.6	25.9	27.9	32.3	31.4	28.4	20.2	11.4	4.2		
		MCWB	1.9	1.4	6.1	9.8	13.2	15.9	18.1	16.5	14.7	10.8	5.7	1.9		
	5%	DB	2.7	1.9	10.1	17.5	23.3	25.6	30.0	29.2	25.0	17.1	8.1	2.2		
		MCWB	0.9	0.2	4.5	7.9	12.1	15.2	17.4	16.3	13.7	9.2	3.8	0.3		
	10%	DB	0.4	-0.3	7.0	14.7	20.8	23.4	27.7	26.7	22.0	14.0	5.1	-0.3		
		MCWB	-0.9	-1.6	3.1	6.6	11.2	14.2	16.7	15.7	12.4	7.4	2.1	-1.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.9	3.4	9.0	11.9	15.4	18.8	21.0	19.3	16.7	13.2	8.7	4.3		
		MCDB	7.3	6.2	16.7	22.9	25.7	26.7	30.2	27.9	27.8	22.9	16.2	7.3		
	2%	WB	2.1	1.6	6.7	10.1	14.0	17.3	19.3	18.1	15.2	11.4	5.8	2.0		
		MCDB	4.3	3.6	12.5	19.5	24.1	25.3	28.6	27.5	25.9	18.8	10.6	3.9		
	5%	WB	0.9	0.2	4.8	8.6	12.9	16.0	18.3	17.2	14.1	9.6	4.1	0.4		
		MCDB	2.8	1.8	9.5	16.2	21.9	23.6	27.1	26.3	24.0	16.3	7.4	2.1		
	10%	WB	-0.9	-1.6	3.1	7.1	11.6	14.9	17.4	16.3	12.8	8.0	2.3	-1.6		
		MCDB	0.5	-0.2	6.5	13.4	19.3	21.8	25.8	24.9	21.4	13.6	4.8	-0.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	11.9	12.2	14.5	15.4	14.0	16.0	15.9	16.1	15.0	12.2	11.0		
		MCDBR	13.2	13.6	17.0	20.5	20.5	18.2	20.0	20.7	22.1	20.1	16.3	13.2		
		MCWBR	10.8	11.1	10.2	10.5	9.5	8.2	7.8	8.1	10.1	11.2	10.8	10.7		
		MCDBR	12.8	13.0	15.9	18.9	18.1	16.1	17.4	17.7	20.7	19.2	15.3	13.2		
	5% WB	MCWBR	10.7	10.8	10.0	10.0	8.7	8.0	7.6	7.6	9.7	10.8	10.4	10.8		
(40) Clear-Sky Solar Irradiance	taub		0.271	0.303	0.292	0.347	0.374	0.371	0.363	0.382	0.331	0.289	0.260	0.257		
	taud		2.354	2.314	2.462	2.311	2.280	2.341	2.396	2.312	2.437	2.535	2.491	2.362		
	Ebn at Noon		762	824	920	892	879	883	885	846	860	847	788	722		
	Edh at Noon		62	85	88	116	125	119	111	115	90	67	53	52		
(44) All-Sky Solar Radiation	RadAvg		1.17	2.20	3.57	4.86	5.83	6.15	6.63	5.38	3.85	2.34	1.26	0.89		
	RadStd		0.11	0.19	0.27	0.37	0.39	0.37	0.30	0.37	0.35	0.27	0.11	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (80 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page