

COLLINGWOOD, ON, Canada

WMO: 712700

Lat: 44.505N

Lon: 80.223W

Elev: 590

StdP: 14.39

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.7	(c) 3.1	(d) -7.6	(e) 3.7	(f) -0.7	(g) -2.8	(h) 4.8	(i) 4.2	(j) 28.9	(k) 18.6	(l) 26.4	(m) 16.6	(n) 6.6	(o) 150	(p) 0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	86.2	71.8	82.9	70.0	80.0	68.8	73.7	82.1	72.1	79.9	70.7	77.8	7.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.1	117.1	78.5	69.5	111.0	76.9	68.0	105.1	75.7	37.7	82.4	36.3	80.1	35.0	77.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.6	20.6	17.7	-8.9	92.1	6.5	2.6	-13.6	93.9	-17.4	95.5	-21.0	97.0	-25.8	98.9		
			-9.4	77.0	6.4	2.0	-14.0	78.4	-17.7	79.6	-21.3	80.7	-26.0	82.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.4	22.7	23.2	30.8	42.4	53.6	63.4	69.3	68.5	62.0	50.8	39.3	28.9	(6)	(7)
	DBStd	18.71	11.26	10.35	10.20	9.22	8.51	7.07	5.66	5.34	7.27	8.30	8.68	8.79	(7)	(8)
	HDD50	3601	847	750	602	265	54	1	0	0	2	90	336	654	(8)	(9)
	HDD65	7226	1311	1170	1061	678	369	113	21	25	141	447	772	1118	(9)	(10)
	CDD50	2279	0	0	6	39	167	404	598	572	362	116	14	1	(10)	(11)
	CDD65	430	0	0	0	1	18	66	154	132	51	8	0	0	(11)	(12)
	CDH74	2729	0	0	2	24	149	470	953	766	327	38	0	0	(12)	(13)
	CDH80	650	0	0	0	3	39	122	219	189	73	5	0	0	(13)	(14)
(14) Wind	WSAvg	7.6	8.9	8.6	8.7	8.8	7.1	6.0	6.0	6.1	6.4	7.6	8.5	8.8	(14)	(15)
(15) Precipitation	PrecAvg	37.6	3.5	2.7	2.6	2.7	3.1	3.1	3.3	2.9	3.4	3.5	3.7	3.4	(15)	(16)
	PrecMax	44.0	5.7	5.1	6.5	5.0	6.6	6.3	5.4	5.0	5.4	6.3	6.5	5.9	(16)	(17)
	PrecMin	29.7	2.0	0.9	0.9	1.2	1.1	0.9	1.2	1.5	0.8	1.1	1.5	1.4	(17)	(18)
	PrecStd	4.1	1.0	1.0	1.2	1.1	1.3	1.3	1.1	0.9	1.0	1.4	1.2	1.0	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.2	53.7	65.5	77.7	85.0	88.9	90.0	90.4	86.8	78.5	65.8	55.2	(19)	(20)
		MCWB	50.2	47.3	56.1	61.9	67.9	72.3	73.3	73.7	72.1	64.2	56.2	51.4	(20)	(21)
	2%	DB	46.1	46.7	56.7	69.4	78.1	83.5	85.3	84.8	81.5	73.2	60.7	48.0	(21)	(22)
		MCWB	42.6	41.8	50.5	57.4	64.8	70.3	72.0	71.0	68.8	63.7	54.5	44.4	(22)	(23)
	5%	DB	40.8	40.2	50.2	63.2	72.4	79.2	82.0	81.2	77.6	68.5	56.4	43.6	(23)	(24)
		MCWB	38.1	36.3	44.7	53.7	61.8	67.8	70.2	69.7	67.2	60.4	50.7	40.4	(24)	(25)
	10%	DB	37.0	36.4	44.1	57.0	67.5	75.6	79.3	77.9	74.0	63.9	52.0	39.9	(25)	(26)
		MCWB	34.9	33.5	39.2	48.7	58.8	66.1	69.3	68.4	65.7	57.2	47.7	37.1	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.7	48.3	57.7	64.5	70.3	74.1	76.3	76.3	73.8	69.4	58.9	51.9	(27)	(28)
		MCDB	52.8	51.1	64.1	72.8	81.5	84.0	86.0	84.9	82.9	76.0	62.4	55.5	(28)	(29)
	2%	WB	43.0	42.3	51.3	58.8	66.8	72.0	74.0	73.1	71.2	64.8	54.8	45.1	(29)	(30)
		MCDB	45.3	47.0	55.9	68.3	75.8	81.2	81.9	80.9	77.9	70.8	59.4	47.6	(30)	(31)
	5%	WB	38.2	36.7	45.3	54.4	63.5	69.8	72.2	71.4	68.9	61.1	51.0	40.6	(31)	(32)
		MCDB	40.5	39.7	50.6	62.3	71.2	77.1	79.6	78.6	75.5	67.5	55.7	43.4	(32)	(33)
	10%	WB	34.9	33.6	39.7	49.4	59.7	67.3	70.6	69.9	66.6	58.1	47.8	37.2	(33)	(34)
		MCDB	36.8	36.1	43.4	56.1	66.1	73.9	77.4	76.3	72.7	63.3	51.9	39.5	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	13.0	13.4	15.2	16.4	15.7	14.9	15.0	15.8	13.4	11.6	10.2	(35)	(36)
		MCDBR	15.1	17.3	21.2	26.7	23.8	21.8	18.5	19.9	20.4	20.5	18.6	14.2	(36)	(37)
	5% WB	MCWBR	13.3	14.4	16.0	17.3	14.0	12.0	10.1	10.3	11.2	12.6	14.2	12.0	(37)	(38)
		MCDWR	14.8	17.3	20.9	25.1	22.6	19.2	16.0	16.4	17.7	18.2	17.3	13.9	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.284	0.302	0.317	0.358	0.388	0.410	0.407	0.402	0.370	0.347	0.314	0.287	(39)	(40)
		taud	2.361	2.286	2.396	2.347	2.323	2.282	2.317	2.322	2.405	2.442	2.480	2.416	(40)	(41)
	Ebn at Noon		265	280	292	287	280	273	272	270	270	261	254	253	(41)	(42)
		Edh at Noon	24	31	32	37	39	41	39	38	32	27	22	21	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		401	705	1118	1431	1715	1877	1897	1617	1265	734	422	283	(43)	(44)
	RadStd		48	93	119	135	164	134	113	86	119	81	65	37	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page