

ATHABASCA AGCM, AB, Canada

WMO: 712710

Lat: 54.6347N

Lon: 113.3819W

Elev: 635

StdP: 93.93

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-31.0	-27.6	-34.5	0.2	-30.7	-31.1	0.2	-27.6	8.0	0.5	7.1	-0.2	1.1	220	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	27.3	17.2	25.8	16.4	24.2	15.8	18.9	25.1	17.8	23.7	16.9	22.5	2.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	12.7	22.1	15.5	11.9	20.7	14.5	11.1	19.6	56.3	25.2	52.8	23.8	49.8	22.6	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.2	5.5	DB	-35.0	30.5	3.4	1.1	-37.4	31.3	-39.4	31.9	-41.3	32.5	-43.7	33.3	(4)
(5)			WB	-35.2	21.1	3.3	1.4	-37.6	22.1	-39.5	23.0	-41.4	23.8	-43.8	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.0	-10.3	-10.3	-4.3	3.6	10.9	14.7	16.9	15.9	11.0	4.1	-4.6	-11.9	(6)
(7)		DBStd	12.09	9.11	8.27	7.74	5.09	4.71	3.17	2.61	3.21	4.64	4.76	6.82	8.22	(7)
(8)		HDD10.0	3243	628	569	443	199	46	4	0	1	42	191	439	680	(8)
(9)		HDD18.3	5618	886	803	702	442	232	116	60	88	221	442	689	938	(9)
(10)		CDD10.0	703	0	0	0	7	75	144	214	184	73	7	0	0	(10)
(11)		CDD18.3	37	0	0	0	0	2	6	16	12	1	0	0	0	(11)
(12)		CDH23.3	522	0	0	0	2	57	82	186	141	53	1	0	0	(12)
(13)		CDH26.7	72	0	0	0	0	9	7	27	21	9	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.6	2.7	2.6	3.0	2.9	2.6	2.3	2.2	2.4	3.0	2.6	2.7	(14)
(15)	Precipitation	PrecAvg	431	22	11	17	25	49	82	82	56	35	19	20	18	(15)
(16)		PrecMax	538	93	23	38	49	79	134	161	118	79	34	70	33	(16)
(17)		PrecMin	321	0	0	3	1	7	32	38	22	4	2	3	1	(17)
(18)		PrecStd	71	22	7	10	13	19	29	31	22	19	10	17	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	8.5	12.9	22.3	27.7	27.6	29.3	28.8	28.1	21.1	11.9	6.6	(19)
(20)			MCWB	3.6	3.9	6.3	10.9	13.9	16.7	19.2	18.2	16.8	12.2	6.8	2.3	(20)
(21)		2%	DB	6.3	5.4	9.4	17.9	24.8	25.6	27.1	26.7	24.6	16.4	8.0	4.0	(21)
(22)			MCWB	2.5	1.7	4.2	8.2	12.9	15.6	18.1	17.9	15.6	9.4	4.5	0.8	(22)
(23)		5%	DB	4.4	3.3	7.2	14.6	22.2	23.9	25.5	24.7	22.1	13.8	5.6	1.4	(23)
(24)			MCWB	1.4	0.7	2.7	6.6	11.6	14.7	17.2	17.0	14.3	7.8	2.7	-0.9	(24)
(25)		10%	DB	2.4	1.0	5.1	11.9	20.1	22.0	23.7	23.1	19.2	11.3	3.4	-0.7	(25)
(26)			MCWB	0.1	-1.1	1.4	5.4	10.5	14.4	16.5	16.2	12.7	6.3	1.1	-2.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	4.3	6.4	11.0	15.0	18.6	20.9	20.2	17.6	12.6	7.3	2.5	(27)
(28)			MCDWB	7.4	8.2	12.2	22.0	24.2	24.8	26.9	26.4	26.1	20.5	11.3	5.8	(28)
(29)		2%	WB	2.8	2.2	4.5	8.6	13.8	17.0	19.1	18.8	16.1	10.2	4.8	0.8	(29)
(30)			MCDWB	5.8	4.8	8.8	16.6	22.6	23.4	25.1	25.2	23.0	15.4	7.6	3.6	(30)
(31)		5%	WB	1.5	0.7	3.0	7.1	12.6	15.8	18.1	17.7	14.5	8.2	2.9	-0.9	(31)
(32)			MCDWB	4.2	3.1	6.8	13.6	20.7	22.0	23.8	23.4	21.0	12.9	5.3	1.5	(32)
(33)		10%	WB	0.0	-0.8	1.6	5.7	11.2	14.7	17.1	16.7	13.2	6.8	1.3	-2.6	(33)
(34)			MCDWB	2.4	1.3	4.8	11.1	18.8	20.5	22.5	22.0	18.7	10.4	3.2	-1.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	9.6	10.0	10.3	12.6	11.4	11.5	11.6	11.6	9.0	7.3	7.9	(35)
(36)			MCDBR	8.9	10.5	11.2	15.0	15.9	14.3	14.3	14.2	16.5	13.4	9.4	9.8	(36)
(37)			MCWBR	6.4	7.8	6.9	7.9	7.3	6.5	7.2	7.2	8.6	7.7	6.5	7.8	(37)
(38)		5% WB	MCDWR	8.6	10.0	10.8	13.8	14.7	12.9	13.0	13.0	15.8	12.5	8.9	9.7	(38)
(39)			MCWBR	6.5	7.8	6.8	7.6	7.2	6.5	7.1	7.0	8.5	7.5	6.5	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.251	0.272	0.300	0.324	0.338	0.351	0.353	0.360	0.306	0.281	0.250	0.231	(40)	
(41)		taud	2.289	2.304	2.334	2.400	2.418	2.386	2.435	2.360	2.530	2.568	2.461	2.302	(41)	
(42)		Ebn at Noon	716	826	881	905	907	895	886	856	873	824	735	669	(42)	
(43)		Edh at Noon	54	77	95	102	107	112	104	106	78	60	46	43	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.82	1.83	3.33	4.63	5.65	5.89	5.93	4.87	3.36	1.87	0.86	0.59	(44)	
(45)		RadStd	0.09	0.13	0.26	0.37	0.49	0.40	0.32	0.35	0.34	0.26	0.09	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page