

TWO HILLS AGDM, AB, Canada

WMO: 712760

Lat: 53.6253N

Lon: 111.6783W

Elev: 678

StdP: 93.44

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -30.7	(c) -27.6	(d) -34.3	(e) 0.2	(f) -30.6	(g) -30.8	(h) 0.2	(i) -27.4	(j) 13.5	(k) -4.2	(l) 12.1	(m) -6.3	(n) 3.8	(o) 160	(p) 0.728

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	27.9	17.1	26.1	16.5	24.3	15.9	19.2	25.5	18.0	23.9	16.9	22.4	4.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	13.1	22.3	15.7	12.1	20.8	14.7	11.3	19.7	57.7	25.8	53.7	23.9	50.2	22.4	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	10.1	9.0	-34.1	31.0	3.0	1.7	-36.3	32.2	-38.1	33.2	-39.8	34.2	-42.0	35.4		
			-34.2	21.8	3.0	1.2	-36.4	22.6	-38.2	23.3	-39.9	24.0	-42.0	24.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-12.0	-11.5	-5.0	3.6	10.7	14.6	16.9	15.7	11.0	3.9	-5.2	-11.3	(6)
(7)		DBStd	12.22	8.57	7.62	6.93	5.36	4.63	3.18	2.91	3.33	4.63	5.07	7.10	7.60	(7)
(8)		HDD10.0	3355	681	602	466	199	47	4	0	2	42	197	456	661	(8)
(9)		HDD18.3	5748	939	835	724	441	239	117	62	94	224	447	706	919	(9)
(10)		CDD10.0	693	0	0	0	8	69	143	216	177	71	8	0	0	(10)
(11)		CDD18.3	43	0	0	0	0	2	6	19	12	3	0	0	0	(11)
(12)		CDH23.3	591	0	0	0	1	51	82	227	156	73	2	0	0	(12)
(13)		CDH26.7	113	0	0	0	0	8	11	52	25	18	0	0	0	(13)
(14)	Wind	WSAvg	4.5	4.6	4.3	4.6	5.1	4.9	4.5	3.9	4.3	4.6	4.5	4.3	(14)	
(15)	Precipitation	PrecAvg	393	17	11	15	28	43	66	74	57	32	18	17	(15)	
(16)		PrecMax	497	58	23	37	104	102	137	151	121	77	47	79	31	(16)
(17)		PrecMin	290	3	1	5	2	5	12	22	11	1	1	2	3	(17)
(18)		PrecStd	65	12	6	7	21	23	29	27	24	20	10	17	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	5.2	11.6	22.0	27.9	28.1	30.7	29.3	29.2	22.2	12.1	5.6	(19)
(20)			MCWB	2.1	2.3	6.2	10.4	14.4	16.6	19.0	17.5	15.9	12.0	6.4	2.7	(20)
(21)		2%	DB	3.4	2.9	7.1	18.5	24.4	25.8	27.9	26.8	25.4	16.9	7.8	3.2	(21)
(22)			MCWB	1.3	0.7	3.5	8.8	12.6	15.6	18.7	17.2	14.4	9.7	4.1	1.0	(22)
(23)		5%	DB	1.9	1.0	4.9	15.0	21.9	23.5	25.8	25.1	22.3	13.8	5.2	1.3	(23)
(24)			MCWB	0.2	-0.6	2.1	7.1	11.6	14.8	18.0	16.9	13.4	7.8	2.1	-0.7	(24)
(25)		10%	DB	-0.1	-0.7	3.2	12.2	19.5	21.5	23.8	23.1	19.0	11.4	3.0	-0.9	(25)
(26)			MCWB	-1.6	-2.1	0.9	5.8	10.3	13.6	17.2	16.0	12.0	6.5	0.9	-2.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.6	2.5	6.4	11.2	15.4	18.6	21.6	20.1	16.6	12.4	7.0	2.9	(27)
(28)			MCDWB	4.7	4.9	10.8	19.8	23.1	25.3	27.1	25.5	25.8	21.0	11.3	5.3	(28)
(29)		2%	WB	1.5	0.8	3.7	9.2	13.6	16.9	19.8	18.6	15.1	10.4	4.5	1.2	(29)
(30)			MCDWB	3.3	2.4	6.7	17.4	21.6	23.0	25.9	24.7	23.5	16.1	7.6	3.2	(30)
(31)		5%	WB	0.3	-0.5	2.2	7.5	12.4	15.8	18.6	17.4	13.8	8.4	2.5	-0.6	(31)
(32)			MCDWB	2.0	1.0	4.6	14.3	20.3	21.4	24.7	23.3	21.2	12.8	4.7	1.1	(32)
(33)		10%	WB	-1.6	-2.2	1.1	6.1	11.2	14.7	17.6	16.4	12.5	6.9	1.0	-2.4	(33)
(34)			MCDWB	-0.2	-0.7	3.0	11.6	18.4	20.0	22.9	22.0	18.3	10.8	2.8	-0.9	(34)
(35)	Mean Daily Temperature Range			MDBR	8.4	8.6	8.4	10.2	12.0	10.7	11.3	11.7	11.6	9.6	7.6	(35)
(36)		5% DB	MCDBR	8.9	10.3	9.7	14.9	15.2	13.8	14.3	14.9	16.8	14.0	9.7	9.6	(36)
(37)			MCWBR	7.4	8.6	6.8	7.7	6.7	6.2	7.0	7.1	7.5	7.8	6.6	7.9	(37)
(38)			MCDBR	8.8	9.9	9.2	13.8	13.4	11.9	13.0	13.2	15.2	13.1	9.2	9.5	(38)
(39)		5% WB	MCWBR	7.4	8.5	6.5	7.6	6.3	6.1	6.9	6.9	7.1	7.7	6.7	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.248	0.271	0.301	0.328	0.346	0.361	0.361	0.371	0.309	0.275	0.249	0.225	(40)
(41)		taud		2.309	2.299	2.323	2.370	2.371	2.354	2.384	2.326	2.489	2.553	2.444	2.342	(41)
(42)		Ebn at Noon		745	840	886	904	901	887	881	848	874	842	753	715	(42)
(43)		Edh at Noon		56	79	97	107	113	116	111	111	82	62	49	44	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.96	2.01	3.53	4.68	5.80	5.95	6.12	5.00	3.50	2.01	0.96	0.71	(44)
(45)		RadStd		0.10	0.15	0.28	0.41	0.42	0.42	0.33	0.37	0.38	0.28	0.11	0.07	(45)

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (72 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page