

ANDREW AGDM, AB, Canada

WMO: 712860

Lat: 53.9176N

Lon: 112.2783W

Elev: 2051

StdP: 13.64

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-26.9	-20.6	-33.5	0.9	-26.9	-26.8	1.3	-20.6	26.1	31.5	23.4	26.8	5.4	140	0.701

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	82.1	63.8	79.0	62.5	75.9	61.1	67.6	78.2	65.1	75.1	63.1	72.4	8.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	94.7	73.7	61.2	87.1	70.3	59.3	81.2	67.7	33.2	78.5	31.2	75.6	29.6	72.0	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.1	20.3	17.9	-35.1	87.9	6.7	2.7	-39.8	89.8	-43.7	91.4	-47.5	92.9	-52.3	94.8		
			-35.2	72.4	6.6	2.4	-40.0	74.2	-43.9	75.6	-47.6	77.0	-52.4	78.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.6	9.6	9.5	21.0	37.7	50.5	57.8	61.5	58.8	50.4	37.9	21.3	8.9
	DBStd	22.27	14.97	14.01	13.13	9.66	7.99	5.30	4.93	5.69	7.82	8.55	12.32	14.25
	HDD50	6373	1254	1134	898	377	92	7	0	5	88	383	861	1274
	HDD65	10791	1719	1554	1363	818	451	222	132	203	439	840	1311	1739
	CDD50	1100	0	0	0	9	107	241	357	277	101	8	0	0
	CDD65	43	0	0	0	0	2	6	23	10	2	0	0	0
	CDH74	1075	0	0	0	2	106	154	396	280	133	4	0	0
	CDH80	196	0	0	0	0	19	18	84	46	29	0	0	0
	WSAvg	8.2	8.1	7.9	8.7	9.6	9.6	8.7	7.0	6.8	7.7	8.4	8.0	7.6
	PrecAvg	16.3	0.7	0.4	0.7	1.2	1.7	2.8	3.2	2.1	1.3	0.7	0.7	0.6
(15) Precipitation	PrecMax	22.6	2.7	0.9	1.5	2.6	4.6	5.0	5.5	4.1	3.2	1.7	3.0	1.5
	PrecMin	8.7	0.1	0.0	0.2	0.1	0.3	0.8	1.2	0.4	0.2	0.0	0.0	0.1
	PrecStd	2.9	0.6	0.2	0.3	0.6	0.9	1.1	1.1	0.7	0.8	0.4	0.6	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	41.8	50.8	72.4	82.9	82.5	86.9	84.6	84.1	71.9	52.8	42.5
		MCWB	36.1	36.0	42.5	51.7	56.7	62.0	68.4	65.0	61.9	54.2	43.9	36.7
	2%	DB	38.7	37.5	43.8	65.2	76.7	78.4	81.9	80.6	77.8	61.8	44.9	37.6
		MCWB	34.6	33.5	38.1	48.1	54.3	60.5	67.6	64.3	58.8	49.0	38.8	33.4
	5%	DB	35.3	33.8	40.3	59.0	72.1	74.7	78.3	76.9	71.9	56.4	40.5	33.7
		MCWB	32.2	31.0	35.6	45.3	52.7	58.8	65.4	62.9	56.0	45.6	35.9	30.5
	10%	DB	31.4	30.4	37.4	53.7	67.8	71.1	74.8	73.6	66.0	51.7	36.4	29.3
		MCWB	29.0	28.1	33.7	42.5	50.8	57.4	63.4	61.8	53.5	43.4	33.4	27.0
	0.4%	WB	36.8	36.7	43.3	52.4	58.7	65.9	72.0	69.2	62.7	54.6	44.4	37.4
		MCDB	40.9	40.6	49.9	68.9	74.9	76.8	81.9	79.1	80.2	70.1	51.8	42.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.8	33.7	38.5	48.8	56.1	63.2	68.8	66.5	59.7	50.4	39.2	33.8
		MCDB	38.3	36.7	43.2	63.9	71.5	73.2	79.4	76.6	74.5	60.1	44.3	37.3
	5%	WB	32.5	31.3	35.9	45.8	54.1	61.0	66.5	64.1	57.3	46.9	36.2	30.6
		MCDB	35.4	34.0	39.8	57.3	68.7	71.3	76.2	74.2	70.4	54.5	39.7	33.6
	10%	WB	28.9	27.9	33.9	43.3	52.1	58.9	64.3	62.2	54.7	44.2	33.5	27.1
		MCDB	31.3	30.2	37.0	52.4	64.7	68.2	73.4	71.8	64.3	50.8	36.2	29.4
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	20.0	18.4	20.6	24.7	21.3	22.6	24.5	24.6	20.7	16.7	17.4
		MCDBR	20.4	23.4	20.2	31.2	32.2	28.4	29.1	31.0	35.7	29.5	21.2	21.5
		MCWBR	16.9	19.8	15.1	16.6	14.0	13.5	16.3	16.7	17.8	17.4	15.2	17.9
	5% WB	MCDBR	20.1	22.6	19.3	28.8	28.7	24.3	27.0	28.1	32.5	27.9	19.6	21.3
		MCWBR	16.9	19.4	14.6	16.0	13.0	12.8	15.7	16.0	16.7	17.1	14.5	18.1
(40) Clear-Sky Solar Irradiance	taub		0.254	0.264	0.306	0.333	0.346	0.360	0.360	0.370	0.309	0.279	0.252	0.241
	taud		2.294	2.331	2.305	2.360	2.378	2.360	2.396	2.330	2.495	2.553	2.446	2.276
	Ebn at Noon		231	270	278	285	286	282	279	269	276	265	236	211
	Edh at Noon		18	24	31	34	36	36	35	35	26	19	15	15
(44) All-Sky Solar Radiation	RadAvg		292	621	1106	1480	1814	1892	1929	1582	1096	624	295	213
	RadStd		33	47	84	131	140	127	99	113	114	81	33	20

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page