

EGBERT CS, ON, Canada

WMO: 712960

Lat: 44.2331N

Lon: 79.7800W

Elev: 823

StdP: 14.26

Time Zone: -5.00 (NAE)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -1.3	(d) -13.7	(e) 2.7	(f) -5.7	(g) -7.3	(h) 3.8	(i) -0.4	(j) 20.8	(k) 26.4	(l) 19.0	(m) 22.8	(n) 5.6	(o) 330	(p) 0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.7	(c) 87.3	(d) 71.7	(e) 83.9	(f) 69.8	(g) 81.0	(h) 68.4	(i) 74.5	(j) 82.7	(k) 72.6	(l) 80.2	(m) 70.8	(n) 77.8	(o) 9.6	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	122.1	78.4	70.1	114.3	76.7	68.4	107.4	74.9	38.6	83.4	36.8	80.2	35.2	78.1	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.0	16.8	15.0		-15.3	91.6	5.3	3.2	-19.1	93.9	-22.2	95.8	-25.1	97.6	-29.0	99.9	
				DB												
				WB	-15.6	77.8	5.3	3.0	-19.4	80.0	-22.5	81.8	-25.5	83.5	-29.3	85.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	19.7	20.9	29.5	42.3	54.7	63.5	68.5	67.0	60.3	48.5	37.2	26.1
	DBStd	19.47	12.14	10.63	10.91	9.23	8.67	7.04	5.65	5.65	7.56	8.51	8.98	9.78
	HDD50	3981	938	815	640	267	47	1	0	0	7	135	391	740
	HDD65	7676	1403	1235	1101	682	340	110	28	43	181	515	833	1205
	CDD50	2150	0	0	4	35	194	405	574	527	315	88	8	0
	CDD65	371	0	0	0	1	21	64	137	106	39	3	0	0
	CDH74	3206	0	0	1	24	219	616	1152	817	349	28	0	0
	CDH80	846	0	0	0	2	50	186	311	209	86	2	0	0
	WSAvg	7.1	7.8	7.9	7.9	8.3	7.2	6.3	5.7	5.6	6.0	7.0	7.4	7.6
	PrecAvg	32.7	2.3	2.1	2.2	2.7	2.9	3.0	3.3	3.0	2.8	2.8	2.8	2.6
Precipitation	PrecMax	42.4	4.2	4.2	5.5	4.8	5.5	8.2	5.2	7.8	5.2	5.2	5.4	4.4
	PrecMin	22.8	1.1	0.9	0.8	1.0	1.0	0.8	1.3	1.3	1.1	0.6	0.7	1.0
	PrecStd	4.3	0.9	0.9	1.0	1.1	1.0	1.7	1.2	1.4	1.0	1.1	1.1	0.9
	PrecStd	4.3	0.9	0.9	1.0	1.1	1.0	1.7	1.2	1.4	1.0	1.1	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	50.1	50.2	64.7	77.9	85.1	89.5	90.8	91.4	87.6	78.1	63.3	53.2	
	0.4% MCWB	48.4	45.6	56.4	62.6	67.0	72.1	73.7	72.8	70.9	65.0	54.3	51.0	
	2% DB	43.1	43.3	55.4	69.1	80.3	85.6	86.9	85.0	82.3	71.9	58.3	46.6	
	2% MCWB	41.0	40.5	49.9	57.5	65.4	70.8	71.7	70.0	68.7	62.6	53.8	43.9	
	5% DB	38.8	38.5	49.6	63.4	74.9	81.1	83.5	81.6	77.9	66.5	54.5	42.1	
	5% MCWB	36.9	35.5	44.4	53.1	62.0	68.6	70.0	69.3	66.7	59.3	49.9	40.0	
	10% DB	35.5	35.3	44.2	57.8	70.4	76.8	80.4	78.5	73.7	61.9	50.3	38.4	
	10% MCWB	34.0	33.1	39.5	49.2	59.0	65.7	68.2	67.5	64.9	56.7	46.8	36.5	
	0.4% WB	48.8	46.1	58.1	65.1	71.3	75.6	77.8	76.9	74.0	69.5	58.2	51.2	
	0.4% MCDB	50.0	48.2	63.7	72.5	79.3	85.2	86.1	84.8	82.0	74.9	60.3	53.3	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	41.2	40.9	50.4	59.2	67.7	73.0	74.6	73.8	71.1	64.1	54.3	44.3	
	2% MCDB	42.6	43.7	53.5	67.5	77.3	82.0	82.4	81.2	78.7	68.7	57.4	45.9	
	5% WB	36.9	36.0	45.3	54.7	64.5	70.6	72.5	71.6	68.9	60.6	50.1	40.3	
	5% MCDB	38.4	37.9	49.4	61.7	73.0	78.5	79.8	78.4	75.7	65.3	53.6	42.0	
	10% WB	34.1	33.1	40.0	50.2	61.0	67.8	70.5	69.5	66.4	57.2	47.1	36.5	
	10% MCDB	35.4	35.0	43.5	56.9	67.9	74.4	77.3	75.2	71.7	61.3	50.6	38.0	
Mean Daily Temperature Range	MDBR	13.9	14.5	15.4	18.3	20.7	19.4	19.7	19.4	19.9	15.8	13.5	11.5	
	5% DB	14.0	17.5	22.1	27.8	25.9	24.4	23.2	23.5	24.5	23.0	19.8	14.0	
	5% WB	13.0	15.4	16.3	17.7	14.5	13.0	11.1	11.3	12.9	14.7	15.4	12.5	
	MCDBR	13.2	16.4	21.3	24.7	22.9	21.9	19.9	19.0	20.6	20.4	17.9	13.8	
	MCWBR	12.6	15.2	16.7	17.9	14.1	12.8	11.3	11.1	12.3	14.3	15.1	13.0	
	MCWBR	12.6	15.2	16.7	17.9	14.1	12.8	11.3	11.1	12.3	14.3	15.1	13.0	
Clear-Sky Solar Irradiance	taub	0.281	0.298	0.317	0.356	0.386	0.408	0.403	0.394	0.362	0.343	0.308	0.281	
	taud	2.373	2.308	2.405	2.354	2.320	2.279	2.313	2.323	2.412	2.452	2.498	2.435	
	Ebn at Noon	268	283	292	288	280	274	274	272	273	264	257	258	
	Edh at Noon	24	31	32	37	40	42	40	38	32	27	22	21	
All-Sky Solar Radiation	RadAvg	434	705	1118	1420	1709	1866	1883	1625	1286	754	452	320	
	RadStd	49	85	117	143	173	137	124	85	122	78	62	38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-3.22	-4.01	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page