

ON EGBERT 1 W, ON, Canada

WMO: 712961

Lat: 44.2326N

Lon: 79.7810W

Elev: 246

StdP: 98.40

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 64757

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.3	-18.4	-25.4	0.4	-20.9	-22.3	0.5	-18.2	7.6	-5.5	7.1	-5.7	1.9	N/A	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	30.4	21.2	28.6	20.4	27.1	19.7	22.7	27.8	21.8	26.8	21.0	25.2	3.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	16.2	24.8	20.3	15.4	24.3	19.4	14.6	23.6	68.2	27.8	65.0	27.2	62.0	25.0	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.8	6.0	5.4	-26.2	32.8	2.8	1.5	-28.2	33.9	-29.9	34.8	-31.4	35.7	-33.4	36.8		
(5)			-26.9	24.6	2.7	1.1	-28.9	25.3	-30.5	26.0	-32.0	26.6	-34.0	27.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-6.8	-6.4	-1.6	5.6	12.7	17.5	20.3	19.2	15.7	9.1	2.6	-3.3		
	DBStd	10.84	6.72	5.92	6.17	4.84	4.87	3.80	3.10	3.05	4.11	4.65	5.10	5.41		
	HDD10.0	2227	519	459	361	147	26	1	0	0	3	74	226	412		
	HDD18.3	4283	778	692	617	381	186	59	15	26	100	287	472	671		
	CDD10.0	1186	0	0	3	16	111	226	321	286	174	47	3	0		
	CDD18.3	201	0	0	0	0	12	34	77	53	22	2	0	0		
	CDH23.3	1715	0	0	1	7	133	326	654	393	186	15	0	0		
	CDH26.7	423	0	0	0	0	30	89	172	86	44	1	0	0		
(14) Wind	WSAvg	2.4	2.8	2.9	2.8	2.9	2.4	2.2	1.9	1.9	1.9	2.4	2.5	2.7		
(15) Precipitation	PrecAvg	830	59	53	56	68	73	77	83	77	72	70	70	66		
	PrecMax	1076	107	107	140	121	140	209	131	198	133	131	137	112		
	PrecMin	579	29	24	20	25	25	20	33	34	29	16	19	25		
	PrecStd	108	22	24	25	27	26	42	30	36	26	28	29	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	10.2	19.3	24.4	29.5	31.6	32.6	31.6	30.6	25.6	17.5	11.1		
		MCWB	9.4	7.7	15.0	14.9	19.8	21.6	22.6	21.2	22.2	18.1	12.7	9.7		
	2%	DB	6.6	6.3	13.3	19.8	27.1	29.3	30.5	28.8	27.8	22.1	14.4	7.8		
		MCWB	5.2	4.4	9.8	12.5	18.7	19.8	21.3	20.3	20.7	16.5	11.0	6.4		
	5%	DB	4.0	3.5	10.0	17.0	24.2	27.1	28.5	27.1	25.4	19.0	12.2	5.4		
		MCWB	2.8	1.7	7.7	12.0	17.0	19.6	20.6	19.8	19.4	14.3	9.1	4.1		
	10%	DB	2.0	1.6	6.9	14.0	21.7	24.9	26.9	25.5	23.1	16.5	9.9	3.4		
		MCWB	0.9	0.2	4.1	8.9	15.3	17.9	19.6	19.1	18.2	13.2	7.6	2.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	9.7	15.9	16.0	21.3	23.2	24.3	23.2	23.4	19.9	14.0	10.5		
		MCDB	9.7	11.4	21.7	19.3	27.4	29.3	30.2	26.6	28.5	22.7	15.8	11.8		
	2%	WB	4.8	5.6	11.1	13.9	20.0	21.6	22.7	22.0	22.0	17.0	11.5	7.0		
		MCDB	5.6	7.4	13.1	16.9	25.6	27.3	28.2	26.6	27.0	20.3	13.9	8.1		
	5%	WB	2.4	2.8	7.9	11.3	18.6	20.2	21.8	21.1	20.9	15.3	9.4	4.9		
		MCDB	3.5	4.4	10.6	14.8	23.5	24.5	26.9	25.0	24.3	18.1	12.0	6.0		
	10%	WB	0.8	0.7	4.4	8.8	16.6	19.1	21.0	20.2	19.4	13.8	7.8	2.7		
		MCDB	1.5	2.1	6.4	12.4	20.7	23.0	25.2	24.1	22.4	15.8	10.3	3.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	7.7	8.5	10.2	11.6	10.8	11.0	10.7	10.9	8.7	7.5	6.2		
		MCDBR	8.0	9.6	12.5	15.5	14.3	13.3	12.9	12.6	13.3	12.8	11.1	7.8		
	5% WB	MCWBR	7.6	8.4	8.9	10.5	8.0	7.2	6.1	6.1	6.5	7.6	8.2	6.8		
		MCWBR	7.8	10.1	11.7	13.7	12.5	11.6	11.0	10.2	11.2	10.5	10.3	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.282	0.298	0.317	0.356	0.387	0.408	0.403	0.395	0.362	0.344	0.309	0.281		
		taud	2.372	2.308	2.404	2.353	2.320	2.278	2.312	2.322	2.412	2.452	2.497	2.435		
	Ebn at Noon		845	891	922	907	884	863	862	858	861	830	811	812		
		Edh at Noon	76	98	102	117	125	131	125	120	101	85	68	66		
(44) All-Sky Solar Radiation	RadAvg		1.37	2.22	3.52	4.48	5.39	5.88	5.93	5.12	4.05	2.38	1.43	1.01		
	RadStd		0.15	0.27	0.37	0.45	0.55	0.43	0.39	0.27	0.39	0.24	0.20	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page