

POINT PELEE, ON, Canada

WMO: 713030

Lat: 41.9488N

Lon: 82.5192W

Elev: 177

StdP: 99.22

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.6	-14.0	-21.1	0.6	-17.0	-17.9	0.8	-13.4	5.9	-6.8	5.5	-6.0	2.5	290	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	29.5	24.0	28.2	23.1	27.1	22.4	25.3	28.1	24.2	27.1	23.3	26.2	2.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.4	19.8	27.3	23.3	18.5	26.3	22.3	17.4	25.4	78.4	28.2	74.2	27.2	70.3	26.2	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.9	5.3	4.7	DB	-19.7	30.9	3.8	2.0	-22.4	32.4	-24.6	33.5	-26.7	34.6	-29.5	36.1	(4)
(5)			WB	-20.1	25.7	3.7	1.7	-22.7	27.0	-24.8	27.9	-26.9	28.9	-29.5	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	-3.9	-3.4	0.7	6.7	12.7	18.6	21.6	21.2	17.9	11.6	5.3	-0.2	(6)
(7)		DBStd	10.09	5.72	5.60	4.80	4.04	4.38	3.77	3.26	2.97	3.82	4.46	4.62	4.68	(7)
(8)		HDD10.0	1732	431	374	290	115	19	0	0	0	1	33	153	316	(8)
(9)		HDD18.3	3667	689	608	547	349	183	42	8	9	52	213	392	573	(9)
(10)		CDD10.0	1418	0	0	2	16	104	258	361	346	238	84	11	1	(10)
(11)		CDD18.3	311	0	0	0	0	9	49	111	97	39	5	0	0	(11)
(12)		CDH23.3	1906	0	0	0	2	44	259	816	584	193	8	0	0	(12)
(13)		CDH26.7	334	0	0	0	0	7	44	169	82	33	1	0	0	(13)
(14)	Wind	WSAvg	2.3	2.6	2.7	2.5	2.5	2.3	1.7	1.6	1.6	2.0	2.4	2.7	2.8	(14)
(15)	Precipitation	PrecAvg	956	64	55	67	92	94	100	95	88	90	70	72	71	(15)
(16)		PrecMax	1162	142	135	138	137	183	159	218	215	206	119	139	184	(16)
(17)		PrecMin	675	19	14	28	51	31	34	41	20	31	19	21	31	(17)
(18)		PrecStd	125	31	30	27	25	43	35	40	45	40	24	26	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	10.5	15.5	21.0	27.2	30.0	31.5	30.4	29.8	24.2	17.9	13.3	(19)
(20)			MCWB	7.4	8.5	11.5	14.6	20.0	23.1	25.4	25.4	24.3	20.6	13.5	11.5	(20)
(21)		2%	DB	6.3	7.6	11.7	17.8	24.2	27.9	29.8	28.6	27.3	22.1	15.1	9.8	(21)
(22)			MCWB	5.2	5.8	8.9	12.6	18.0	22.3	24.1	23.9	22.8	19.1	12.6	8.7	(22)
(23)		5%	DB	4.7	5.4	9.3	15.2	21.9	26.2	28.5	27.4	25.5	20.4	13.4	7.6	(23)
(24)			MCWB	3.7	3.8	7.2	10.7	17.2	21.1	23.4	23.0	21.5	17.6	11.0	6.6	(24)
(25)		10%	DB	3.2	3.4	7.1	12.9	19.7	24.6	27.3	26.3	23.8	18.6	11.9	5.9	(25)
(26)			MCWB	2.3	2.0	5.3	9.2	15.7	20.2	22.5	22.2	20.4	15.9	9.7	4.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	9.5	12.6	16.4	21.1	24.7	26.8	26.7	25.1	21.4	14.7	11.6	(27)
(28)			MCDWB	8.2	10.1	15.0	18.4	26.0	28.1	30.0	28.9	29.0	23.3	16.2	12.9	(28)
(29)		2%	WB	5.5	6.1	9.3	13.4	19.4	23.4	25.6	25.1	23.6	19.8	12.9	9.0	(29)
(30)			MCDWB	6.1	7.1	11.1	17.2	22.8	26.6	28.3	27.6	26.4	21.5	14.7	9.8	(30)
(31)		5%	WB	3.9	3.8	7.4	11.4	17.8	22.2	24.5	24.0	22.3	18.0	11.4	6.7	(31)
(32)			MCDWB	4.6	5.2	9.0	14.3	20.8	25.2	27.3	26.5	24.9	20.1	13.1	7.4	(32)
(33)		10%	WB	2.3	2.1	5.4	9.8	16.3	21.0	23.4	23.0	21.0	16.2	9.9	4.9	(33)
(34)			MCDWB	3.1	3.3	7.0	12.6	19.1	23.9	26.5	25.5	23.4	18.3	11.5	5.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	7.1	7.4	8.4	8.5	8.6	9.0	8.5	8.4	7.3	6.0	5.1	(35)
(36)			MCDBR	6.7	8.3	10.3	12.1	11.1	9.9	9.4	8.9	8.9	8.5	7.6	6.5	(36)
(37)			MCWBR	6.1	7.0	7.9	7.7	5.9	5.4	5.2	5.0	5.2	5.6	5.9	5.9	(37)
(38)		5% WB	MCDBR	6.7	7.9	9.7	10.7	10.3	8.9	8.8	7.7	8.5	7.9	7.4	6.4	(38)
(39)			MCWBR	6.3	7.0	8.0	7.8	6.1	5.2	5.4	5.0	5.3	5.7	6.2	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.333	0.356	0.398	0.431	0.445	0.438	0.425	0.384	0.365	0.325	0.314	(40)	
(41)		taud	2.389	2.283	2.304	2.262	2.215	2.225	2.269	2.293	2.382	2.409	2.486	2.443	(41)	
(42)		Ebn at Noon	835	863	886	871	847	834	835	835	848	820	813	796	(42)	
(43)		Edh at Noon	81	105	116	130	140	139	132	125	107	92	74	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.38	2.23	3.44	4.61	5.44	6.10	6.10	5.33	4.29	2.78	1.73	1.19	(44)	
(45)		RadStd	0.16	0.27	0.32	0.37	0.46	0.39	0.33	0.21	0.37	0.22	0.24	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	+97	N/A

Nomenclature: See separate page