

TRACADIE, NS, Canada

WMO: 713080

Lat: 45.608N

Lon: 61.680W

Elev: 219

StdP: 14.58

Time Zone: -4.00 (NAA)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.1	5.3	-7.0	3.8	3.6	-2.5	4.9	7.2	28.7	33.6	26.3	31.6	11.5	250	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	81.6	70.1	78.8	68.9	76.2	67.2	72.5	78.8	70.9	76.3	69.2	74.0	10.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.2	112.1	76.1	68.8	106.8	74.4	67.3	101.3	72.6	36.2	79.0	34.9	76.4	33.5	74.3	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.1	22.1	19.9	-4.7	87.1	4.2	1.9	-7.7	88.5	-10.1	89.6	-12.4	90.7	-15.5	92.1		
(5)			-5.5	75.3	4.1	1.2	-8.4	76.2	-10.8	76.8	-13.1	77.5	-16.1	78.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.8	24.7	23.3	28.8	38.8	48.2	57.0	66.8	66.6	60.4	50.2	40.9	31.0
	DBStd	16.96	10.32	9.53	8.22	7.67	7.13	6.81	5.56	4.69	6.24	6.88	8.04	8.94
	HDD50	3642	786	748	658	348	123	13	0	0	2	83	292	589
	HDD65	7588	1250	1168	1122	786	523	254	46	37	166	460	723	1053
	CDD50	1759	1	0	1	12	66	222	520	515	314	89	18	1
	CDD65	234	0	0	0	0	2	14	101	88	28	1	0	0
	CDH74	1057	0	0	1	3	23	84	503	347	95	1	0	0
	CDH80	148	0	0	0	0	3	6	83	44	12	0	0	0
Wind	WSAvg	10.0	11.1	10.7	11.0	10.4	9.4	8.7	9.0	8.6	9.6	9.9	10.9	11.0
Precipitation	PrecAvg	54.4	5.0	4.4	4.5	4.3	4.1	3.7	3.4	4.2	4.4	5.4	5.7	5.8
	PrecMax	66.3	7.2	6.9	7.8	7.6	7.4	6.2	6.2	11.0	14.6	9.8	9.2	12.2
	PrecMin	40.6	2.6	2.0	2.1	1.7	1.7	1.6	1.6	1.8	0.4	1.9	3.3	3.2
	PrecStd	5.9	1.2	1.3	1.6	1.3	1.4	1.3	1.3	1.8	3.0	2.2	1.5	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	52.9	56.9	67.7	77.4	80.4	85.8	84.4	81.7	71.8	64.4	57.5
		MCWB	54.1	51.3	51.1	55.3	63.2	67.2	71.7	72.0	71.6	65.3	61.0	55.6
	2%	DB	49.9	46.3	49.6	60.1	69.3	76.4	82.3	80.7	76.4	67.9	61.4	53.1
		MCWB	48.6	44.5	46.2	54.2	58.9	66.0	70.3	70.1	68.2	63.6	59.2	51.6
	5%	DB	43.9	40.6	44.8	55.4	64.5	72.4	79.4	77.8	73.2	64.3	58.3	47.8
		MCWB	42.1	38.2	41.1	51.5	56.2	63.4	69.6	68.5	66.6	60.5	56.2	46.5
	10%	DB	38.2	35.7	40.2	51.2	60.5	69.0	76.5	75.2	70.4	61.3	54.0	43.1
		MCWB	36.7	33.8	37.1	46.9	54.0	62.0	67.6	67.1	65.5	57.7	51.5	41.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.3	51.4	53.5	59.4	66.1	71.2	74.3	74.2	73.3	67.9	61.5	55.8
		MCDB	55.8	52.7	56.0	64.0	75.9	78.2	82.3	81.2	77.9	70.6	63.7	57.0
	2%	WB	48.7	44.8	46.8	55.5	61.4	68.2	72.6	72.2	70.4	64.3	59.5	51.7
		MCDB	49.8	45.9	49.2	59.5	66.6	73.0	79.8	77.6	74.6	66.6	61.3	52.9
	5%	WB	42.6	38.9	42.1	51.8	57.9	65.3	71.1	70.5	68.4	61.3	56.7	46.7
		MCDB	44.0	40.1	44.0	54.6	62.4	70.1	77.2	75.6	72.0	64.1	58.2	47.8
	10%	WB	36.8	34.0	37.1	47.3	54.3	62.5	69.3	68.8	66.2	57.9	51.9	42.0
		MCDB	38.1	35.3	39.8	50.8	59.0	67.7	74.3	73.6	69.4	60.7	53.8	43.1
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.1	12.7	13.4	15.3	15.3	14.9	14.2	14.0	12.1	11.9	11.4
		MCDBR	19.8	20.2	20.9	21.0	22.7	21.2	18.6	17.9	17.7	15.9	16.9	18.1
		MCWBR	20.1	19.3	18.3	15.7	14.4	13.1	10.1	10.1	11.6	12.7	15.8	18.4
	5% WB	MCDBR	20.0	20.8	19.9	20.3	20.8	18.7	16.0	15.2	15.0	14.8	16.7	18.0
		MCWBR	20.3	20.6	18.9	17.1	15.0	12.9	9.6	9.8	11.2	13.4	16.3	18.5
Clear-Sky Solar Irradiance	taub		0.294	0.295	0.319	0.350	0.371	0.386	0.413	0.398	0.354	0.333	0.319	0.296
	taud		2.465	2.446	2.428	2.420	2.415	2.406	2.364	2.400	2.499	2.536	2.510	2.493
	Ebn at Noon		260	283	290	289	285	280	270	270	275	266	249	247
	Edh at Noon		22	27	31	35	36	36	37	35	29	24	21	19
All-Sky Solar Radiation	RadAvg		386	659	1057	1321	1576	1689	1695	1537	1214	767	424	289
	RadStd		29	64	69	106	162	148	115	106	89	71	49	21

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.74	N/A	N/A	N/A	N/A

Nomenclature: See separate page