

DEBERT, NS, Canada

WMO: 713170

Lat: 45.4215N

Lon: 63.4658W

Elev: 123

StdP: 14.63

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.6	-1.2	-13.8	2.6	-5.1	-8.6	3.5	0.6	28.6	35.7	25.6	28.4	4.3	280	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	81.3	68.9	78.8	67.3	76.3	66.0	71.5	78.2	69.8	75.7	68.1	73.6	10.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	107.3	75.5	67.5	101.7	73.8	65.9	96.0	71.8	35.4	78.7	33.9	75.7	32.5	73.6	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 23.3	(b) 20.3	(c) 18.0	(e) -16.0	(f) 86.7	(g) 3.9	(h) 1.9	(i) -18.8	(j) 88.1	(k) -21.1	(l) 89.2	(m) -23.3	(n) 90.3	(o) -26.2	(p) 91.7		
(4) 23.3	(5) 20.3	(6) 18.0	(7) -16.4	(8) 74.9	(9) 3.9	(10) 0.9	(11) -19.2	(12) 75.5	(13) -21.5	(14) 76.0	(15) -23.6	(16) 76.5	(17) -26.5	(18) 77.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.4	20.6	21.2	28.0	39.6	49.9	58.1	66.2	65.3	57.8	47.5	37.9	27.4
	DBStd	17.72	11.44	10.03	8.73	6.84	5.86	5.88	4.55	4.85	6.65	7.26	8.86	10.17
	HDD50	4019	910	805	683	319	75	6	0	0	9	136	375	701
	HDD65	8047	1375	1225	1148	761	469	219	40	57	231	544	812	1166
	CDD50	1621	0	0	0	8	72	248	504	474	242	59	13	1
	CDD65	170	0	0	0	0	0	12	78	65	14	1	0	0
	CDH74	1049	0	0	0	0	9	88	507	380	63	2	0	0
	CDH80	127	0	0	0	0	0	6	68	47	6	0	0	0
(14) Wind	WSAvg	7.8	8.4	8.5	9.3	8.8	8.0	7.3	6.5	6.3	6.9	7.6	8.0	8.2
(15) Precipitation	PrecAvg	46.0	4.3	3.4	3.8	3.2	3.4	3.3	3.0	3.4	4.2	4.3	4.8	4.8
	PrecMax	55.6	6.8	6.2	7.3	5.6	6.4	6.3	6.9	7.2	13.1	11.2	8.7	8.9
	PrecMin	36.0	1.3	1.3	1.4	1.1	1.5	1.0	0.6	0.9	0.9	1.0	2.3	2.0
	PrecStd	5.0	1.3	1.4	1.6	1.0	1.1	1.5	1.4	1.8	2.6	2.2	1.5	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	50.5	55.9	65.8	75.2	80.6	84.7	84.3	79.7	71.8	64.6	56.7
		MCWB	53.9	48.7	47.1	53.9	60.1	66.2	71.2	70.6	69.6	65.3	61.4	54.8
	2%	DB	46.2	43.1	48.6	60.5	70.0	76.5	81.8	80.9	75.4	66.7	60.5	51.4
		MCWB	44.9	40.9	43.6	52.2	57.8	65.3	69.3	68.7	66.4	61.4	58.3	49.9
	5%	DB	40.7	39.0	44.6	56.3	65.5	73.1	79.5	78.2	72.1	63.2	57.1	46.2
		MCWB	38.9	36.7	40.4	49.6	54.7	62.1	67.8	66.9	65.0	59.1	54.6	44.6
	10%	DB	35.9	35.4	40.4	52.7	61.8	70.0	76.8	75.6	69.4	60.1	52.8	41.8
		MCWB	34.4	33.6	36.2	46.9	53.3	60.2	66.5	65.9	63.0	55.9	50.3	39.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.3	48.9	49.8	58.9	64.7	70.5	73.8	73.4	71.5	67.2	61.7	55.1
		MCDB	55.0	50.9	51.7	61.7	72.4	77.1	82.0	80.4	77.0	69.8	64.0	56.6
	2%	WB	45.2	41.7	45.4	55.0	60.2	67.3	71.9	71.3	68.8	62.7	58.6	50.2
		MCDB	46.2	42.7	48.0	58.2	65.5	73.4	79.3	77.6	73.3	65.3	60.3	51.6
	5%	WB	38.9	37.0	40.9	51.4	57.4	64.8	70.0	69.5	66.7	59.9	55.2	44.8
		MCDB	40.2	38.4	44.1	54.7	62.6	70.5	76.3	75.5	70.7	62.8	57.0	46.0
	10%	WB	34.5	33.5	36.7	47.8	54.7	62.2	68.3	67.6	64.4	56.5	50.5	40.2
		MCDB	35.8	34.8	39.8	51.6	60.1	67.6	74.1	73.0	68.1	59.6	52.7	41.6
(35) Mean Daily Temperature Range	5% DB	MDBR	17.6	17.7	17.2	18.4	19.8	19.2	19.7	19.7	19.9	17.7	15.9	15.2
		MCDBR	22.0	19.1	22.4	25.4	28.0	25.7	24.4	23.3	21.9	20.6	19.3	18.7
		MCWBR	21.7	17.2	18.0	17.6	17.0	15.3	13.5	12.9	14.4	16.0	17.3	18.7
	5% WB	MCDBR	21.2	18.6	20.6	21.0	21.5	20.2	19.6	18.7	18.2	17.9	17.5	18.9
		MCWBR	21.1	17.7	18.3	17.7	15.1	12.9	11.8	11.5	13.0	15.5	16.9	19.1
(40) Clear-Sky Solar Irradiance	taub		0.301	0.290	0.321	0.353	0.369	0.392	0.413	0.397	0.354	0.328	0.310	0.289
	taud		2.422	2.476	2.444	2.406	2.405	2.358	2.320	2.364	2.467	2.535	2.538	2.519
	Ebn at Noon		257	286	290	288	285	278	270	271	275	268	254	252
	Edh at Noon		23	26	31	35	36	38	39	36	30	24	20	19
(44) All-Sky Solar Radiation	RadAvg		434	689	1068	1314	1539	1673	1708	1562	1225	781	436	321
	RadStd		38	59	70	120	178	149	121	116	100	84	49	23

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.61	+0.83	N/A	N/A	+90	+25

Nomenclature: See separate page