

DEBERT, NS, Canada

WMO: 713170

Lat: 45.4215N

Lon: 63.4658W

Elev: 38

StdP: 100.88

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.5	-18.4	-25.5	0.4	-20.6	-22.6	0.5	-17.4	12.8	2.1	11.5	-2.0	1.9	280	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	27.4	20.5	26.0	19.6	24.6	18.9	22.0	25.7	21.0	24.3	20.1	23.1	4.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.6	15.3	24.1	19.7	14.5	23.2	18.8	13.7	22.1	64.4	25.9	61.0	24.3	57.8	23.1	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.1	8.0	DB	-26.7	30.4	2.2	1.1	-28.2	31.2	-29.5	31.8	-30.7	32.4	-32.3	33.2	(4)
(5)			WB	-26.9	23.8	2.2	0.5	-28.4	24.2	-29.7	24.4	-30.9	24.7	-32.5	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	-6.3	-6.0	-2.2	4.2	9.9	14.5	19.0	18.5	14.3	8.6	3.3	-2.6
	DBStd	9.84	6.36	5.57	4.85	3.80	3.25	3.27	2.53	2.69	3.69	4.03	4.92	5.65
	HDD10.0	2233	506	447	379	177	42	3	0	0	5	76	208	389
	HDD18.3	4471	764	681	638	423	261	122	22	32	128	302	451	648
	CDD10.0	901	0	0	0	4	40	138	280	263	134	33	7	1
	CDD18.3	94	0	0	0	0	0	7	43	36	8	1	0	0
	CDH23.3	583	0	0	0	0	5	49	282	211	35	1	0	0
	CDH26.7	71	0	0	0	0	0	3	38	26	3	0	0	0
Wind	WSAvg	3.5	3.8	3.8	4.2	3.9	3.6	3.3	2.9	2.8	3.1	3.4	3.6	3.7
Precipitation	PrecAvg	1168	108	86	97	82	87	83	77	86	107	110	123	121
	PrecMax	1412	173	158	185	141	162	159	175	184	334	284	221	225
	PrecMin	915	32	32	35	27	39	26	14	22	24	25	58	50
	PrecStd	127	34	35	40	26	29	39	36	45	67	56	38	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	10.3	13.3	18.8	24.0	27.0	29.3	29.1	26.5	22.1	18.1	13.7
		MCWB	12.2	9.3	8.4	12.2	15.6	19.0	21.8	21.4	20.9	18.5	16.3	12.7
	2%	DB	7.9	6.2	9.2	15.8	21.1	24.7	27.7	27.1	24.1	19.3	15.8	10.8
		MCWB	7.2	4.9	6.5	11.2	14.3	18.5	20.7	20.4	19.1	16.3	14.6	10.0
	5%	DB	4.8	3.9	7.0	13.5	18.6	22.8	26.4	25.7	22.3	17.4	13.9	7.9
		MCWB	3.8	2.6	4.7	9.8	12.6	16.7	19.9	19.4	18.3	15.1	12.6	7.0
	10%	DB	2.2	1.9	4.7	11.5	16.5	21.1	24.9	24.2	20.8	15.6	11.6	5.4
		MCWB	1.3	0.9	2.3	8.3	11.8	15.7	19.2	18.8	17.2	13.3	10.2	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	9.4	9.9	15.0	18.1	21.4	23.2	23.0	21.9	19.5	16.5	12.8
		MCDB	12.8	10.5	10.9	16.5	22.5	25.1	27.8	26.9	25.0	21.0	17.8	13.7
	2%	WB	7.3	5.4	7.4	12.8	15.7	19.6	22.1	21.8	20.5	17.0	14.8	10.1
		MCDB	7.9	5.9	8.9	14.6	18.6	23.0	26.3	25.3	22.9	18.5	15.7	10.9
	5%	WB	3.8	2.8	5.0	10.8	14.1	18.2	21.1	20.9	19.3	15.5	12.9	7.1
		MCDB	4.6	3.6	6.7	12.6	17.0	21.4	24.6	24.1	21.5	17.1	13.9	7.8
	10%	WB	1.4	0.8	2.6	8.8	12.6	16.8	20.1	19.8	18.0	13.6	10.3	4.6
		MCDB	2.1	1.6	4.3	10.9	15.6	19.8	23.4	22.8	20.0	15.4	11.5	5.3
Mean Daily Temperature Range	5% DB	MDBR	9.8	9.8	9.5	10.2	11.0	10.7	10.9	11.0	11.1	9.8	8.8	8.4
		MCDBR	12.2	10.6	12.4	14.1	15.5	14.3	13.6	12.9	12.2	11.4	10.7	10.4
		MCWBR	12.0	9.6	10.0	9.8	9.4	8.5	7.5	7.2	8.0	8.9	9.6	10.4
	5% WB	MCDBR	11.8	10.3	11.5	11.7	11.9	11.2	10.9	10.4	10.1	10.0	9.7	10.5
		MCWBR	11.7	9.8	10.2	9.8	8.4	7.2	6.6	6.4	7.2	8.6	9.4	10.6
Clear-Sky Solar Irradiance	taub	0.301	0.290	0.321	0.353	0.369	0.392	0.413	0.397	0.354	0.328	0.310	0.289	
	taud	2.422	2.476	2.444	2.406	2.405	2.358	2.320	2.364	2.467	2.535	2.538	2.519	
	Ebn at Noon	809	902	914	907	899	876	851	853	866	846	800	795	
	Edh at Noon	72	81	97	110	114	120	124	114	94	77	64	59	
All-Sky Solar Radiation	RadAvg	1.37	2.17	3.37	4.14	4.85	5.27	5.38	4.92	3.86	2.46	1.38	1.01	
	RadStd	0.12	0.18	0.22	0.38	0.56	0.47	0.38	0.37	0.31	0.26	0.15	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	+0.34	+0.46	N/A	N/A	+50	+14

Nomenclature: See separate page