

BEDFORD RANGE, NS, Canada

WMO: 713250

Lat: **44.747N**Lon: **63.665W**Elev: **10**StdP: **101.21**Time Zone: **-4.00 (NAA)**Period: **04-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.9	-15.1	-21.3	0.6	-15.6	-19.4	0.7	-13.0	9.3	-0.7	8.5	-2.8	1.4	320	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	28.2	20.1	26.6	19.3	25.2	18.6	21.9	26.1	21.0	24.8	20.0	23.3	3.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.2	23.9	19.6	14.3	22.8	18.8	13.6	22.0	64.0	25.9	60.6	24.9	57.5	23.3	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	6.9	6.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	-20.7	23.5	3.0	1.0	-22.9	24.2	-24.7	24.7	-26.4	25.3	-28.6	26.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-4.1	-4.0	-0.7	4.9	10.1	14.8	19.4	19.1	15.4	9.6	4.5	-0.6
	DBStd	9.19	5.77	5.20	4.53	3.50	3.15	3.11	2.37	2.39	3.60	3.95	4.53	5.19
	HDD10.0	1921	437	391	332	159	37	3	0	0	3	56	174	329
	HDD18.3	4091	695	624	589	404	257	111	16	20	100	270	417	587
	CDD10.0	982	0	0	1	5	39	148	291	281	164	44	8	1
	CDD18.3	110	0	0	0	0	1	6	48	43	12	0	0	0
	CDH23.3	829	0	0	3	2	24	92	361	276	68	2	0	0
	CDH26.7	152	0	0	1	0	7	18	74	38	14	0	0	0
(14) Wind	WSAvg	2.5	2.7	2.9	3.1	3.0	2.7	2.5	2.1	2.0	2.1	2.3	2.6	2.6
(15) Precipitation	PrecAvg	1419	125	114	120	101	121	98	92	96	117	143	148	143
	PrecMax	1704	216	209	250	184	316	236	218	263	352	318	261	238
	PrecMin	1147	46	33	42	36	54	25	19	42	37	40	82	65
	PrecStd	155	39	47	54	35	56	49	45	52	77	62	49	44
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	11.5	15.7	19.6	26.8	28.9	31.8	29.7	28.3	22.9	17.8	13.9
		MCWB	10.7	9.9	10.0	11.7	15.9	18.9	21.5	21.4	21.4	16.4	15.7	13.3
	2%	DB	9.1	8.1	10.7	15.6	21.6	25.7	28.5	27.7	25.0	20.0	15.8	11.6
		MCWB	8.2	6.7	6.7	9.3	13.8	17.8	20.2	20.1	19.2	16.0	13.9	10.6
	5%	DB	6.9	5.5	8.0	13.6	19.0	23.6	26.8	26.2	23.2	18.1	14.2	9.7
		MCWB	5.8	3.9	5.0	8.8	12.4	16.6	19.7	19.4	18.3	15.2	12.7	8.9
	10%	DB	4.4	3.3	6.0	11.4	16.6	21.6	25.3	24.8	21.5	16.6	12.4	7.6
		MCWB	3.1	1.6	3.3	8.0	11.0	15.5	18.9	18.5	17.4	14.2	10.9	6.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.8	10.5	11.2	14.0	17.9	21.1	23.1	23.0	22.3	18.8	16.3	13.3
		MCDB	11.5	11.3	14.1	16.7	23.6	26.9	27.8	27.3	25.9	20.8	17.6	13.9
	2%	WB	8.3	6.8	7.7	12.1	15.3	19.2	22.0	21.7	20.6	17.0	14.5	10.8
		MCDB	8.9	7.8	9.4	13.9	19.5	24.0	26.4	25.5	23.6	18.6	15.5	11.5
	5%	WB	5.9	4.2	5.6	10.1	13.5	17.7	21.0	20.8	19.6	15.9	12.9	9.0
		MCDB	6.7	5.3	7.5	11.8	17.5	21.5	25.2	24.2	21.9	17.5	13.9	9.7
	10%	WB	3.3	1.8	3.5	8.5	11.9	16.4	20.1	19.9	18.5	14.4	11.0	6.7
		MCDB	4.3	3.0	5.6	10.9	15.1	20.1	23.7	23.0	20.8	16.4	12.3	7.6
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.1	9.3	9.8	10.6	10.3	10.3	10.8	10.8	10.2	8.6	8.3
		MCDBR	11.4	10.4	12.9	14.2	15.6	14.9	13.3	13.2	12.4	12.1	10.3	10.2
	5% WB	MCWBR	11.2	9.4	9.6	9.0	8.6	7.8	6.4	6.7	7.3	8.4	9.2	10.2
		MCWBR	11.3	10.2	12.0	10.6	12.6	12.1	10.8	10.1	9.8	9.8	9.5	10.1
(40) Clear-Sky Solar Irradiance	taub		0.305	0.295	0.325	0.349	0.370	0.399	0.416	0.397	0.355	0.331	0.315	0.296
		taud	2.453	2.517	2.468	2.442	2.427	2.370	2.345	2.391	2.484	2.550	2.550	2.532
	Ebn at Noon		815	904	914	913	900	870	850	855	869	847	803	796
		Edh at Noon	71	79	96	107	112	119	121	111	94	77	65	60
(44) All-Sky Solar Radiation	RadAvg		1.43	2.31	3.50	4.29	4.94	5.38	5.37	4.99	4.04	2.61	1.49	1.11
	RadStd		0.11	0.17	0.24	0.36	0.62	0.50	0.39	0.35	0.28	0.27	0.16	0.09

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	+0.36	+0.50	N/A	N/A	+50	+14

Nomenclature: See separate page