

HALIFAX KOOTENAY, NS, Canada

WMO: 713260

Lat: 44.590N

Lon: 63.550W

Elev: 171

StdP: 14.61

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.4	8.2	-4.9	4.3	7.5	-1.8	5.0	12.0	37.2	39.6	32.2	40.3	11.2	290	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.8	80.3	67.0	77.3	65.4	74.6	64.4	70.2	76.3	68.6	73.5	67.1	71.4	9.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.4	104.9	72.0	66.9	99.6	70.6	65.4	94.5	69.3	34.3	76.3	33.0	73.9	31.7	71.5	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.6	25.3	22.0	DB	-1.4	86.4	5.0	3.1	-4.9	88.6	-7.8	90.4	-10.6	92.1	-14.2	94.3	(4)
(5)			WB	-2.1	74.1	4.2	1.5	-5.1	75.1	-7.5	76.0	-9.9	76.8	-13.0	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	25.9	26.1	31.4	40.6	49.0	57.4	65.7	66.7	61.1	51.4	41.4	31.7
	DBStd	15.93	9.64	8.41	7.67	5.71	5.74	5.98	4.47	3.84	5.50	6.53	7.55	9.05
	HDD50	3280	748	668	579	286	89	9	0	0	1	62	270	568
	HDD65	7181	1213	1088	1042	731	498	236	44	25	140	424	707	1033
	CDD50	1752	0	0	2	5	56	232	488	518	334	105	12	0
	CDD65	178	0	0	0	0	1	9	66	78	23	1	0	0
	CDH74	746	0	0	3	0	24	85	296	262	73	3	0	0
	CDH80	116	0	0	0	0	4	15	49	33	15	0	0	0
Wind	WSAvg	10.6	12.1	11.8	12.3	11.5	10.2	9.6	8.8	8.2	9.5	10.8	11.4	11.7
Precipitation	PrecAvg	55.7	5.2	4.5	4.8	4.3	4.4	4.1	4.0	3.8	3.8	5.0	5.5	5.9
	PrecMax	70.7	10.7	9.0	9.6	8.2	8.4	13.7	9.0	12.6	8.9	10.1	10.2	10.0
	PrecMin	38.7	1.7	1.3	1.8	0.7	1.0	1.3	0.5	1.0	1.1	1.3	1.5	2.6
	PrecStd	7.8	1.9	1.9	1.8	1.7	1.8	2.2	1.9	2.4	1.8	2.0	2.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	48.6	58.2	63.3	77.8	82.3	85.6	84.1	80.1	71.7	61.2	54.9
		MCWB	49.6	46.7	47.9	50.9	59.6	66.6	70.4	70.9	69.2	60.7	58.1	54.0
	2%	DB	46.9	44.4	48.7	57.4	67.8	75.8	80.2	79.4	75.3	66.6	58.2	51.5
		MCWB	45.8	42.6	41.9	46.4	55.4	61.8	67.1	67.1	66.2	60.3	56.0	50.5
	5%	DB	43.8	40.9	44.4	53.1	62.5	71.7	77.0	76.8	71.7	63.2	55.8	48.4
		MCWB	42.4	39.2	40.1	45.3	52.6	60.0	65.6	65.4	64.1	59.2	53.7	47.4
	10%	DB	39.9	37.8	41.2	49.5	58.5	68.0	74.2	74.1	69.0	60.8	53.0	45.2
		MCWB	38.2	35.8	37.5	44.2	49.6	59.2	64.6	64.6	63.4	57.1	50.8	43.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	47.9	51.1	54.9	62.5	68.6	72.4	72.6	71.4	66.0	59.7	54.4
		MCDB	50.6	48.7	56.8	58.6	72.2	79.2	80.0	79.4	77.7	68.3	60.7	54.7
	2%	WB	46.1	43.0	43.7	50.6	58.1	65.2	70.1	70.2	68.5	62.5	56.9	50.5
		MCDB	46.7	43.9	46.1	52.9	63.9	72.1	77.2	75.3	72.1	65.1	57.7	51.1
	5%	WB	42.7	39.5	40.9	47.6	54.7	62.5	68.3	68.7	66.8	60.2	54.2	47.5
		MCDB	43.6	40.7	43.5	50.3	60.0	68.4	73.7	73.0	69.8	62.1	55.4	48.3
	10%	WB	38.5	36.1	37.9	45.1	51.6	60.3	66.5	67.1	64.9	58.0	51.2	44.3
		MCDB	39.6	37.5	40.7	48.6	56.3	65.4	71.1	71.2	67.7	60.1	52.7	45.2
Mean Daily Temperature Range	5% DB	MDBR	14.2	13.4	13.2	13.4	14.4	14.4	13.9	13.8	13.5	12.4	11.9	12.8
		MCDBR	16.7	15.3	17.0	20.0	22.3	22.3	18.9	18.0	16.1	14.7	14.4	16.0
		MCWBR	17.6	15.0	12.8	12.7	12.9	11.8	9.0	8.5	9.5	10.6	13.7	17.1
	5% WB	MCDBR	16.8	15.5	15.9	16.2	19.7	19.5	16.5	14.2	13.1	12.5	13.9	15.8
		MCWBR	17.9	15.8	13.8	13.2	13.3	11.9	9.6	8.4	9.3	11.0	14.7	17.0
Clear-Sky Solar Irradiance	taub	0.302	0.296	0.323	0.348	0.369	0.398	0.414	0.394	0.353	0.332	0.315	0.296	
	taud	2.478	2.524	2.478	2.451	2.438	2.384	2.360	2.412	2.502	2.557	2.554	2.538	
	Ebn at Noon	261	287	291	290	286	277	270	272	277	269	255	253	
	Edh at Noon	22	25	30	34	35	37	38	35	29	24	21	19	
All-Sky Solar Radiation	RadAvg	456	742	1121	1370	1571	1709	1697	1586	1294	840	483	361	
	RadStd	34	54	77	112	203	159	124	110	84	87	52	28	

Historical Trends

DBAvg	Heating		Cooling			Degree-Days			
	99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	N/A	N/A	N/A	+0.67	+0.90	N/A	N/A	+101	+22

Nomenclature: See separate page