

HALIFAX KOOTENAY, NS, Canada

WMO: 713260

Lat: 44.590N

Lon: 63.550W

Elev: 52

StdP: 100.70

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.3	-13.2	-20.5	0.6	-13.6	-18.8	0.7	-11.1	16.6	4.2	14.4	4.6	5.0	290	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.7	26.8	19.5	25.2	18.5	23.7	18.0	21.2	24.6	20.3	23.1	19.5	21.9	4.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.0	22.2	19.4	14.2	21.5	18.6	13.5	20.7	62.0	24.6	58.8	23.3	55.9	21.9	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.3	9.8	-18.5	30.2	2.8	1.7	-20.5	31.4	-22.1	32.4	-23.7	33.4	-25.7	34.6		
(5)			-18.9	23.4	2.3	0.8	-20.6	24.0	-22.0	24.4	-23.3	24.9	-25.0	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-3.4	-3.3	-0.3	4.8	9.4	14.1	18.7	19.3	16.2	10.8	5.2	-0.2
	DBStd	8.85	5.36	4.67	4.26	3.17	3.19	3.32	2.48	2.13	3.05	3.63	4.19	5.03
	HDD10.0	1822	416	371	322	159	49	5	0	0	1	34	150	316
	HDD18.3	3989	674	604	579	406	277	131	24	14	78	236	393	574
	CDD10.0	973	0	0	1	3	31	129	271	288	186	58	7	0
	CDD18.3	99	0	0	0	0	1	5	37	43	13	1	0	0
	CDH23.3	414	0	0	2	0	13	47	164	146	41	2	0	0
	CDH26.7	64	0	0	0	0	2	8	27	18	8	0	0	0
Wind	WSAvg	4.8	5.4	5.3	5.5	5.1	4.6	4.3	3.9	3.7	4.2	4.8	5.1	5.2
Precipitation	PrecAvg	1414	132	114	123	110	111	103	101	96	97	128	139	151
	PrecMax	1795	271	229	243	208	214	349	229	320	225	256	258	253
	PrecMin	983	42	34	45	19	26	32	13	25	27	32	38	67
	PrecStd	198	47	47	46	42	45	55	48	61	46	52	55	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	9.2	14.6	17.4	25.5	27.9	29.8	29.0	26.7	22.1	16.2	12.7
		MCWB	9.8	8.2	8.8	10.5	15.4	19.2	21.3	21.6	20.7	15.9	14.5	12.2
	2%	DB	8.3	6.9	9.3	14.1	19.9	24.3	26.8	26.3	24.1	19.2	14.6	10.8
		MCWB	7.7	5.9	5.5	8.0	13.0	16.5	19.5	19.5	19.0	15.7	13.3	10.3
	5%	DB	6.5	5.0	6.9	11.7	16.9	22.0	25.0	24.9	22.0	17.3	13.2	9.1
		MCWB	5.8	4.0	4.5	7.4	11.5	15.6	18.7	18.5	17.8	15.1	12.1	8.5
	10%	DB	4.4	3.2	5.1	9.7	14.7	20.0	23.4	23.4	20.6	16.0	11.7	7.3
		MCWB	3.4	2.1	3.1	6.8	9.8	15.1	18.1	18.1	17.4	14.0	10.4	6.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	8.9	10.6	12.7	16.9	20.3	22.5	22.6	21.9	18.9	15.4	12.4
		MCDB	10.4	9.3	13.8	14.8	22.3	26.2	26.7	26.4	25.4	20.2	15.9	12.6
	2%	WB	7.8	6.1	6.5	10.3	14.5	18.4	21.1	21.2	20.3	17.0	13.8	10.3
		MCDB	8.2	6.6	7.8	11.6	17.7	22.3	25.1	24.0	22.3	18.4	14.3	10.6
	5%	WB	5.9	4.1	5.0	8.7	12.6	17.0	20.2	20.4	19.3	15.6	12.4	8.6
		MCDB	6.5	4.8	6.4	10.2	15.6	20.2	23.2	22.8	21.0	16.7	13.0	9.1
	10%	WB	3.6	2.3	3.3	7.3	10.9	15.7	19.2	19.5	18.3	14.4	10.7	6.8
		MCDB	4.2	3.0	4.9	9.2	13.5	18.5	21.7	21.8	19.8	15.6	11.5	7.3
Mean Daily Temperature Range	5% DB	MDBR	7.9	7.4	7.3	7.5	8.0	8.0	7.7	7.7	7.5	6.9	6.6	7.1
		MCDBR	9.3	8.5	9.4	11.1	12.4	12.4	10.5	10.0	9.0	8.2	8.0	8.9
		MCWBR	9.8	8.3	7.1	7.1	7.1	6.6	5.0	4.7	5.3	5.9	7.6	9.5
	5% WB	MCDBR	9.3	8.6	8.8	9.0	11.0	10.8	9.2	7.9	7.3	7.0	7.7	8.8
		MCWBR	10.0	8.8	7.7	7.3	7.4	6.6	5.4	4.7	5.2	6.1	8.2	9.4
Clear-Sky Solar Irradiance	taub	0.302	0.296	0.323	0.348	0.369	0.398	0.414	0.394	0.353	0.332	0.315	0.296	
	taud	2.478	2.524	2.478	2.451	2.438	2.384	2.360	2.412	2.502	2.557	2.554	2.538	
	Ebn at Noon	823	904	916	915	901	872	852	858	872	849	804	798	
	Edh at Noon	70	79	95	106	111	118	119	109	92	77	65	60	
All-Sky Solar Radiation	RadAvg	1.44	2.34	3.53	4.32	4.95	5.39	5.35	5.00	4.08	2.65	1.52	1.14	
	RadStd	0.11	0.17	0.24	0.35	0.64	0.50	0.39	0.35	0.27	0.27	0.16	0.09	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	+0.37	+0.50	N/A	N/A	+56	+12

Nomenclature: See separate page