

SAGLEK, NL, Canada

WMO: 713350

Lat: **58.488N**Lon: **62.586W**Elev: **516**StdP: **95.28**Time Zone: **-4.00 (NAA)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-29.5	-27.2	N/A	N/A	N/A	N/A	N/A	N/A	27.2	-21.6	25.0	-17.3	11.3	260	1.115

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	19.4	N/A	17.2	N/A	15.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	19.4	17.5	DB	-31.6	22.1	3.1	2.4	-33.8	23.8	-35.6	25.2	-37.3	26.5	-39.6	28.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.7	-17.3	-18.1	-14.2	-7.9	-2.3	3.1	7.9	8.0	3.3	-1.2	-6.7	-11.9		
	DBStd	10.13	6.14	5.89	6.10	5.06	4.45	4.32	4.56	4.17	3.72	3.17	3.44	5.46		
	HDD10.0	5440	848	786	751	538	382	214	98	91	206	347	500	681		
	HDD18.3	8411	1106	1019	1009	788	639	458	326	320	452	605	750	939		
	CDD10.0	72	0	0	0	0	2	6	31	30	4	0	0	0		
	CDD18.3	2	0	0	0	0	0	1	1	1	0	0	0	0		
	CDH23.3	3	0	0	0	0	0	2	1	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	7.4	8.4	8.0	8.1	7.7	6.8	6.3	6.0	6.4	7.2	6.8	8.0	8.8		
	PrecAvg	729	51	41	42	43	38	63	97	70	91	78	61	53		
(15) Precipitation	PrecMax	923	101	92	110	99	84	122	147	101	177	158	113	129		
	PrecMin	562	7	3	6	14	7	31	58	35	38	44	24	10		
	PrecStd	79	23	23	25	21	17	18	23	17	32	25	21	27		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.3	-0.9	3.4	7.4	16.4	19.5	22.5	21.7	18.0	10.9	3.2	1.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	-2.4	-3.0	-1.3	4.1	11.5	15.1	19.7	19.3	14.7	7.9	0.9	-0.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	-5.3	-6.3	-3.3	1.4	7.9	12.6	17.3	17.3	11.6	5.3	-0.6	-2.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	-8.4	-9.6	-5.3	-0.7	4.5	9.9	14.9	14.8	9.1	3.2	-2.2	-4.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.2	5.5	5.4	5.2	5.6	5.8	5.5	4.7	3.5	3.3	4.1		
		MCDBR	7.1	8.1	8.4	8.1	9.7	10.1	8.4	8.6	8.6	7.3	5.3	4.1		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.207	0.231	0.275	0.329	0.322	0.325	0.340	0.325	0.303	0.276	0.229	0.201		
	taud		2.156	2.217	2.122	1.993	2.163	2.403	2.480	2.544	2.568	2.527	2.290	2.099		
	Ebn at Noon		669	827	869	867	907	911	888	882	852	778	638	536		
	Edh at Noon		45	71	107	146	133	107	97	85	71	54	40	34		
(44) All-Sky Solar Radiation	RadAvg		0.50	1.41	2.88	4.44	5.55	5.08	4.57	3.76	2.50	1.20	0.52	0.28		
	RadStd		0.05	0.15	0.33	0.48	0.50	0.38	0.34	0.40	0.21	0.10	0.05	0.03		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page