

LA SCIE, NL, Canada

WMO: 713370

Lat: 49.913N

Lon: 55.671W

Elev: 636

StdP: 14.36

Time Zone: -3.50 (NAF)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.2	2.4	-7.8	3.7	0.2	-4.1	4.5	3.7	29.6	23.8	26.6	23.5	10.4	280	0.720

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	79.4	65.4	75.7	64.0	72.5	62.6	68.3	75.0	66.2	72.2	64.2	70.1	11.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	97.4	71.7	63.8	90.8	69.7	61.8	84.5	67.6	33.0	75.5	31.3	72.3	29.8	70.1	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	22.0	19.7	DB	-6.2	86.1	3.6	2.3	-8.7	87.8	-10.8	89.2	-12.8	90.5	-15.4	92.1	(4)
(5)			WB	-6.9	72.2	3.6	1.7	-9.4	73.4	-11.5	74.4	-13.5	75.3	-16.1	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.6	19.0	18.9	23.9	32.7	41.6	51.0	60.4	60.5	52.8	42.7	33.5	24.6
	DBStd	16.46	8.43	8.69	7.87	6.33	7.63	8.98	7.25	6.41	6.99	6.59	6.97	7.67
	HDD50	5131	961	870	809	519	284	97	9	4	48	246	497	787
	HDD65	9718	1426	1290	1274	969	726	428	178	166	372	692	945	1252
	CDD50	960	0	0	0	0	24	126	330	329	130	19	2	0
	CDD65	71	0	0	0	0	0	7	34	25	5	0	0	0
	CDH74	486	0	0	0	0	8	75	231	141	30	1	0	0
	CDH80	72	0	0	0	0	1	11	37	19	4	0	0	0
Wind	WSAvg	9.5	11.0	10.5	10.6	9.9	8.6	8.2	7.8	7.8	9.1	9.4	10.3	11.0
Precipitation	PrecAvg	45.6	3.7	3.6	3.3	3.1	3.5	3.6	4.0	4.3	4.2	4.6	4.0	4.2
	PrecMax	58.7	6.1	9.2	7.0	6.4	6.8	6.1	6.3	6.1	9.8	9.0	6.0	7.3
	PrecMin	35.7	1.7	1.4	1.3	1.1	1.1	1.7	1.5	1.4	1.3	1.9	2.1	2.1
	PrecStd	5.2	1.4	1.6	1.5	1.4	1.1	1.3	1.4	1.4	1.9	1.9	1.1	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.1	44.8	47.4	57.8	74.0	81.7	84.0	82.5	78.3	65.6	57.0	46.9
		MCWB	45.6	43.8	41.2	47.9	58.5	65.1	67.4	69.0	65.1	58.1	54.4	45.5
	2%	DB	39.3	38.9	40.7	50.4	66.0	75.6	79.9	77.7	71.4	60.4	52.7	41.3
		MCWB	38.6	37.6	36.9	44.0	54.1	62.2	65.8	65.6	62.5	54.8	51.2	40.5
	5%	DB	33.9	34.2	37.1	46.0	60.0	70.9	76.1	74.4	67.5	56.5	48.4	37.8
		MCWB	33.3	32.7	33.9	40.7	51.1	60.3	64.3	64.2	60.3	52.9	46.6	37.2
	10%	DB	30.8	30.9	34.0	42.5	54.9	66.2	72.5	71.3	63.9	52.9	43.9	34.9
		MCWB	30.1	30.0	31.7	38.2	47.6	57.6	63.0	62.8	58.1	49.6	42.1	34.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.9	44.1	42.1	50.2	60.7	68.4	71.2	71.0	67.2	60.3	55.3	45.7
		MCDB	46.1	44.5	45.5	55.0	68.5	75.7	80.5	79.1	72.0	63.4	56.5	46.4
	2%	WB	38.7	37.8	37.7	45.5	56.2	64.6	68.4	68.2	64.2	56.2	51.2	40.5
		MCDB	39.3	38.7	40.1	48.9	63.7	71.8	75.6	74.7	69.0	58.2	52.2	41.1
	5%	WB	33.4	33.1	34.5	41.8	52.2	61.3	66.3	66.0	61.4	52.8	46.8	37.0
		MCDB	33.8	33.9	36.5	45.4	58.8	68.7	72.7	71.8	66.0	55.4	48.0	37.4
	10%	WB	30.2	30.1	32.0	38.4	48.3	58.3	64.2	64.0	58.5	49.4	42.2	34.2
		MCDB	30.6	30.7	33.5	41.9	54.3	65.8	70.3	69.6	62.9	52.3	43.5	34.6
Mean Daily Temperature Range	5% DB	MDBR	12.5	13.6	13.2	12.6	15.5	16.6	16.9	15.3	14.4	11.7	10.0	10.2
		MCDBR	16.1	17.4	17.5	19.2	25.9	24.1	22.2	20.2	19.7	17.7	15.8	13.7
		MCWBR	16.5	16.5	14.5	13.8	16.5	14.1	12.4	12.0	13.1	13.7	15.4	13.7
	5% WB	MCDBR	16.1	16.2	16.1	18.0	23.9	22.2	20.0	18.3	18.4	16.5	16.0	13.6
		MCWBR	16.4	16.0	14.3	14.3	16.5	14.4	13.1	12.2	14.1	14.2	15.9	13.7
Clear-Sky Solar Irradiance	taub		0.287	0.287	0.316	0.343	0.361	0.374	0.398	0.376	0.354	0.324	0.300	0.292
	taud		2.387	2.378	2.300	2.335	2.407	2.417	2.396	2.453	2.500	2.539	2.506	2.363
	Ebn at Noon		242	274	282	286	285	281	272	273	268	258	238	220
	Edh at Noon		20	26	33	36	35	35	36	32	28	22	18	18
All-Sky Solar Radiation	RadAvg		268	517	903	1264	1515	1612	1662	1367	1019	617	321	203
	RadStd		22	68	107	148	139	173	136	94	84	66	32	17

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	N/A	+2.36	N/A	+0.76	+1.03	N/A	N/A	N/A	N/A

Nomenclature: See separate page