

MARY'S HARBOUR, NL, Canada

WMO: 713390

Lat: 52.304N

Lon: 55.833W

Elev: 12

StdP: 101.19

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.2	-23.2	-32.8	0.2	-24.7	-30.2	0.2	-22.5	16.2	-4.0	14.6	-4.8	3.9	250	0.819

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.9	25.9	17.6	23.7	16.8	21.5	15.8	18.7	24.2	17.5	22.2	16.4	20.7	6.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.6	11.9	21.0	15.4	11.0	19.9	14.3	10.2	18.8	53.3	24.3	49.5	22.1	46.2	20.8	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.8	10.4	DB	-28.7	30.5	2.0	1.6	-30.1	31.7	-31.3	32.6	-32.4	33.5	-33.9	34.7	(4)
(5)			WB	-28.9	21.0	2.0	1.0	-30.4	21.7	-31.6	22.3	-32.7	22.8	-34.2	23.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.5	-11.3	-11.1	-6.8	-1.0	3.9	9.3	13.9	14.1	10.1	4.6	-1.1	-7.1
	DBStd	10.02	6.66	6.23	5.51	3.69	3.37	4.44	4.17	3.56	3.79	3.27	4.27	5.96
	HDD10.0	3455	660	591	519	331	194	67	12	4	43	172	333	530
	HDD18.3	6151	918	824	778	581	448	272	148	138	248	427	582	788
	CDD10.0	366	0	0	0	0	4	47	132	133	47	3	0	0
	CDD18.3	22	0	0	0	0	0	2	10	8	2	0	0	0
	CDH23.3	221	0	0	0	0	2	34	99	71	14	0	0	0
	CDH26.7	41	0	0	0	0	1	8	16	14	3	0	0	0
Wind	WSAvg	4.8	5.1	5.2	5.5	5.2	4.5	4.5	4.0	3.9	4.5	4.7	5.1	5.3
Precipitation	PrecAvg	1080	111	93	82	62	70	76	90	93	93	99	103	108
	PrecMax	1304	232	147	145	107	144	153	177	192	197	185	198	161
	PrecMin	894	46	48	34	20	17	30	36	29	32	41	42	51
	PrecStd	100	41	28	28	21	31	26	30	32	30	35	34	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.1	4.0	5.2	10.7	20.9	27.5	28.8	28.5	25.5	17.1	12.2	5.2
		MCWB	3.1	2.6	2.3	6.0	13.1	17.7	18.9	19.1	18.0	11.7	10.3	4.0
	2%	DB	1.9	1.5	2.7	7.5	15.9	23.2	26.0	25.1	20.9	14.1	8.8	3.2
		MCWB	1.1	0.7	0.9	4.2	10.1	15.5	17.6	17.7	15.4	10.6	7.4	2.4
	5%	DB	0.5	0.5	1.5	5.3	12.5	20.5	23.9	22.9	18.5	11.7	6.0	2.0
		MCWB	-0.2	-0.1	0.3	2.9	8.2	14.3	17.0	16.7	14.4	9.2	4.7	1.3
	10%	DB	-0.9	-0.9	0.5	3.7	9.5	17.4	21.5	20.7	16.3	9.6	4.2	0.9
		MCWB	-1.6	-1.6	-0.4	1.7	6.4	12.8	16.2	15.8	12.8	7.4	3.2	0.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	3.1	3.0	6.9	13.6	18.6	20.5	20.1	18.6	13.2	10.5	4.3
		MCDB	3.8	3.9	4.9	10.0	19.4	25.5	25.8	25.9	23.9	15.6	11.9	4.9
	2%	WB	1.2	0.9	1.4	4.7	10.7	16.5	18.8	18.7	16.6	11.2	7.4	2.6
		MCDB	1.7	1.1	2.2	6.8	15.1	21.7	24.4	23.9	20.1	13.4	8.7	3.0
	5%	WB	-0.1	0.0	0.6	3.2	8.4	14.8	17.6	17.5	14.8	9.4	4.9	1.5
		MCDB	0.5	0.5	1.2	5.0	12.0	19.3	22.5	21.7	18.0	11.4	5.7	2.0
	10%	WB	-1.5	-1.7	-0.3	2.0	6.5	13.1	16.4	16.3	13.1	7.7	3.4	0.4
		MCDB	-0.9	-1.0	0.5	3.2	9.5	17.4	21.0	20.1	15.9	9.4	4.2	0.8
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.4	8.6	6.8	7.7	9.2	9.7	8.9	8.3	6.4	6.2	7.4
		MCDBR	8.5	8.1	8.1	9.2	15.0	15.4	14.4	13.4	12.2	10.5	7.9	6.4
		MCWBR	8.3	8.0	7.2	6.8	9.7	8.9	7.7	7.2	7.7	7.6	7.4	6.6
	5% WB	MCDBR	8.3	7.9	6.9	7.9	13.9	14.2	13.3	12.2	11.2	9.7	7.4	6.3
		MCWBR	8.2	7.9	6.5	6.2	9.4	8.9	7.9	7.4	7.8	7.6	7.4	6.4
Clear-Sky Solar Irradiance	taub	0.274	0.284	0.302	0.357	0.392	0.385	0.411	0.381	0.353	0.321	0.292	0.282	
	taud	2.293	2.281	2.272	2.228	2.276	2.375	2.347	2.433	2.480	2.533	2.477	2.292	
	Ebn at Noon	728	834	891	875	859	869	837	846	831	794	718	643	
	Edh at Noon	62	84	104	124	125	115	116	101	86	67	53	53	
All-Sky Solar Radiation	RadAvg	0.85	1.77	2.99	4.28	4.81	4.98	4.87	4.11	3.06	1.76	0.94	0.60	
	RadStd	0.13	0.21	0.47	0.45	0.56	0.48	0.45	0.27	0.22	0.15	0.09	0.08	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (6 neighbors)		N/A	N/A	+1.96	N/A	N/A	+0.42	N/A	N/A	N/A
		N/A	N/A	+1.43	N/A	N/A	+0.52	N/A	N/A	N/A

Nomenclature: See separate page