

DAPP AGDM, AB, Canada

WMO: 713400

Lat: 54.3290N

Lon: 113.9345W

Elev: 2031

StdP: 13.65

Time Zone: -7.00 (NAM)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-29.6	-22.9	-35.9	0.8	-29.5	-28.8	1.2	-22.7	23.8	31.9	20.7	28.9	3.9	100	0.692

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.8	81.6	64.0	78.5	62.8	75.7	61.3	67.8	77.9	65.4	75.1	63.3	72.7	8.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	96.0	73.8	61.5	88.0	71.1	59.4	81.5	68.0	33.4	77.9	31.4	75.1	29.8	72.8	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.5	18.8	16.4	DB	-40.3	87.6	5.3	2.8	-44.1	89.6	-47.2	91.3	-50.2	92.9	-54.0	94.9	(4)
(5)			WB	-40.5	72.1	5.3	2.7	-44.3	74.0	-47.4	75.6	-50.3	77.1	-54.1	79.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	34.8	9.0	9.7	20.1	36.9	49.8	57.0	60.5	57.6	49.0	37.2	21.0	8.8	(6)
(7)		DBStd	22.02	15.30	14.25	13.49	9.87	7.90	5.28	4.92	5.63	7.52	8.29	12.95	13.79	(7)
(8)		HDD50	6500	1270	1127	928	398	101	7	1	7	108	404	871	1278	(8)
(9)		HDD65	11037	1735	1547	1393	842	472	246	157	237	481	863	1321	1743	(9)
(10)		CDD50	967	0	0	0	6	95	216	326	242	77	5	0	0	(10)
(11)		CDD65	29	0	0	0	0	1	5	17	6	0	0	0	0	(11)
(12)		CDH74	983	0	0	0	3	103	176	375	235	87	4	0	0	(12)
(13)		CDH80	165	0	0	0	0	17	25	72	36	15	0	0	0	(13)
(14)	Wind	WSAvg	7.2	6.8	6.7	7.6	8.7	9.0	7.8	6.3	6.0	6.8	7.4	6.9	6.3	(14)
(15)	Precipitation	PrecAvg	17.0	0.9	0.4	0.7	1.0	1.9	3.2	3.2	2.2	1.4	0.7	0.8	0.7	(15)
(16)		PrecMax	21.2	3.7	0.9	1.5	1.9	3.1	5.3	6.3	4.6	3.1	1.3	2.8	1.3	(16)
(17)		PrecMin	12.6	0.0	0.0	0.1	0.0	0.3	1.3	1.5	0.9	0.2	0.1	0.1	0.0	(17)
(18)		PrecStd	2.8	0.9	0.3	0.4	0.5	0.7	1.1	1.2	0.9	0.7	0.4	0.7	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	42.0	49.0	72.6	82.3	83.2	86.4	84.1	82.1	71.2	52.4	42.6	(19)
(20)			MCWB	37.2	36.2	41.0	51.8	56.2	62.0	68.4	65.1	61.5	53.8	43.8	37.0	(20)
(21)		2%	DB	39.5	38.3	43.7	64.2	76.6	78.8	81.4	79.9	75.9	61.3	44.9	37.6	(21)
(22)			MCWB	34.8	33.4	37.4	47.8	54.7	60.9	67.5	64.8	58.9	48.8	38.6	33.5	(22)
(23)		5%	DB	35.9	34.6	40.3	58.2	72.0	75.3	78.0	76.3	70.8	56.0	40.5	33.6	(23)
(24)			MCWB	32.5	31.1	35.4	44.9	52.4	59.0	65.5	63.4	56.6	45.5	35.7	30.4	(24)
(25)		10%	DB	31.3	30.9	37.2	53.4	67.9	71.4	74.9	72.8	65.2	51.4	36.5	29.1	(25)
(26)			MCWB	28.7	28.2	33.3	42.8	50.8	57.3	63.7	61.6	53.5	43.1	33.4	26.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.5	36.8	42.2	52.6	58.6	66.4	72.0	69.5	63.1	54.4	44.3	37.2	(27)
(28)			MCD B	42.3	41.5	48.1	69.8	76.8	76.7	81.4	78.5	78.3	69.8	51.2	42.0	(28)
(29)		2%	WB	35.2	33.9	37.8	48.6	55.9	63.0	69.1	66.7	60.1	49.6	39.4	33.7	(29)
(30)			MCD B	39.2	37.6	42.7	62.1	72.1	74.4	79.0	77.0	73.5	58.8	44.5	37.4	(30)
(31)		5%	WB	32.7	31.4	35.6	45.7	54.0	60.8	66.7	64.4	57.2	46.5	36.2	30.3	(31)
(32)			MCD B	35.9	34.7	39.8	56.9	68.8	71.2	76.4	74.0	69.2	54.1	39.8	33.3	(32)
(33)		10%	WB	28.8	28.1	33.6	43.0	52.0	58.8	64.5	62.4	54.6	44.0	33.6	26.9	(33)
(34)			MCD B	31.3	30.9	36.7	51.9	65.3	68.8	73.4	71.6	63.6	50.5	36.2	29.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.8	22.5	21.3	21.4	26.1	23.8	24.8	26.2	26.6	22.3	17.7	19.0	(35)
(36)			MCDBR	21.8	25.1	22.9	32.0	35.2	31.6	31.4	32.9	37.3	31.4	21.9	22.5	(36)
(37)			MCWBR	18.0	21.2	17.4	17.6	16.7	15.9	18.8	19.3	20.7	19.4	15.9	19.2	(37)
(38)		5% WB	MCD BR	21.6	23.9	21.8	29.6	31.1	26.6	29.3	29.6	34.6	29.7	19.7	22.3	(38)
(39)			MCWBR	18.2	20.4	16.7	17.0	15.3	14.7	18.4	18.2	19.4	18.9	15.1	19.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.253	0.274	0.305	0.327	0.343	0.355	0.357	0.361	0.310	0.283	0.253	0.236	(40)
(41)		taud		2.285	2.297	2.313	2.391	2.399	2.376	2.421	2.355	2.510	2.557	2.453	2.294	(41)
(42)		Ebn at Noon		228	262	278	286	286	283	280	271	276	261	233	211	(42)
(43)		Edh at Noon		18	25	31	33	35	36	34	34	25	19	15	14	(43)
(44)	All-Sky Solar Radiation	RadAvg		272	593	1061	1468	1780	1866	1884	1555	1074	604	284	196	(44)
(45)		RadStd		28	43	82	124	145	130	109	113	111	75	29	17	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page