

PEORIA AGDM, AB, Canada

WMO: 713480

Lat: 55.6211N

Lon: 118.2931W

Elev: 621

StdP: 94.08

Time Zone: -7.00 (NAM)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-33.3	-29.8	-37.2	0.1	-33.3	-33.1	0.2	-29.6	9.9	0.6	9.0	-1.2	1.3	80	0.671

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	27.6	16.3	25.8	15.5	24.1	14.8	18.2	24.7	17.1	23.4	16.0	22.2	3.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.8	12.1	20.8	14.6	11.2	19.5	13.5	10.4	18.2	54.1	25.0	50.3	23.4	47.0	22.0	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.5	7.5	6.5	-37.1	30.6	3.5	1.7	-39.6	31.8	-41.7	32.8	-43.6	33.7	-46.1	34.9
			-37.1	20.4	3.4	1.6	-39.5	21.6	-41.5	22.5	-43.5	23.4	-45.9	24.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.3	-10.2	-10.3	-5.6	3.0	10.0	14.0	15.7	14.2	9.5	3.3	-5.4	-11.5
	DBStd	11.64	8.66	8.72	7.41	5.23	4.41	2.91	2.66	3.23	4.17	4.95	6.85	8.07
	HDD10.0	3350	626	569	484	213	53	3	1	5	57	211	463	665
	HDD18.3	5866	884	802	742	460	258	133	89	133	264	465	712	923
	CDD10.0	540	0	0	0	3	54	123	177	134	44	4	1	0
	CDD18.3	13	0	0	0	0	0	3	7	4	0	0	0	0
	CDH23.3	527	0	0	0	2	39	91	209	141	43	1	0	0
	CDH26.7	91	0	0	0	0	5	11	41	28	6	0	0	0
Wind	WSAvg	2.9	2.7	2.6	2.8	3.4	3.6	3.1	2.7	2.6	2.9	3.0	2.7	2.6
Precipitation	PrecAvg	470	33	20	23	25	46	76	73	54	39	30	30	24
	PrecMax	642	102	52	46	49	88	138	133	139	108	88	91	96
	PrecMin	307	9	4	10	6	17	17	29	17	8	6	5	1
	PrecStd	92	19	10	10	12	20	35	29	29	21	18	19	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	7.5	10.0	21.8	27.2	28.1	30.2	29.6	27.5	21.2	12.5	7.3
		MCWB	3.6	3.5	4.7	10.1	12.8	16.9	18.5	17.3	15.0	11.8	6.3	3.6
	2%	DB	6.2	5.4	7.9	17.2	24.0	25.8	27.6	26.9	24.3	16.0	8.4	5.2
		MCWB	2.9	2.0	3.5	7.8	11.9	14.9	17.0	16.6	14.3	8.9	4.4	2.0
	5%	DB	4.7	3.6	6.2	14.1	21.7	24.0	25.7	24.6	20.9	13.4	5.9	2.9
		MCWB	1.8	0.9	2.3	6.4	10.9	14.1	16.4	15.6	12.6	7.3	2.7	0.3
	10%	DB	2.4	1.7	4.4	11.5	19.6	22.1	23.8	22.7	18.0	11.2	3.8	0.5
		MCWB	0.2	-0.5	1.2	5.1	9.9	13.4	15.7	14.8	11.1	6.2	1.3	-1.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	3.7	5.3	10.8	14.5	18.3	20.5	19.1	16.5	12.3	6.6	3.8
		MCDB	7.2	6.7	9.1	20.8	24.1	25.7	26.6	26.2	24.8	20.1	10.6	6.9
	2%	WB	3.1	2.3	3.8	8.5	12.6	16.5	18.7	17.8	14.7	9.7	4.8	2.1
		MCDB	5.9	4.9	7.6	16.1	21.7	23.4	24.6	24.1	22.4	15.1	8.2	5.0
	5%	WB	1.9	1.1	2.5	6.7	11.6	15.3	17.5	16.7	13.2	8.0	3.0	0.4
		MCDB	4.5	3.4	5.8	13.1	19.9	21.7	23.7	22.9	20.0	12.3	5.7	2.8
	10%	WB	0.4	-0.5	1.3	5.4	10.5	14.2	16.4	15.4	11.8	6.5	1.4	-1.4
		MCDB	2.5	1.7	4.1	10.9	18.0	20.2	22.3	21.2	16.9	10.4	3.5	0.5
Mean Daily Temperature Range	5% DB	MDBR	10.1	11.4	11.8	11.9	14.0	12.9	13.8	14.3	13.4	11.0	9.6	9.7
		MCDBR	11.4	11.7	12.7	16.9	18.1	17.2	18.1	18.3	18.7	15.2	11.0	12.6
		MCWBR	8.6	8.8	8.9	9.2	8.5	8.2	9.2	9.3	9.4	9.1	7.9	10.2
	5% WB	MCDBR	11.0	11.3	12.3	15.6	16.4	14.7	16.1	16.4	17.9	14.4	10.8	12.4
		MCWBR	8.5	8.6	8.8	8.9	8.0	7.8	8.9	9.0	9.3	9.1	8.1	10.1
Clear-Sky Solar Irradiance	taub	0.244	0.249	0.303	0.326	0.344	0.352	0.353	0.353	0.310	0.285	0.244	0.231	
	taud	2.278	2.356	2.275	2.377	2.392	2.389	2.406	2.396	2.523	2.548	2.417	2.228	
	Ebn at Noon	702	854	867	898	898	892	883	859	860	805	714	622	
	Edh at Noon	52	70	98	104	109	111	107	101	78	59	45	42	
All-Sky Solar Radiation	RadAvg	0.73	1.68	3.18	4.70	5.61	6.10	5.94	4.83	3.29	1.76	0.79	0.52	
	RadStd	0.07	0.13	0.25	0.27	0.38	0.47	0.38	0.42	0.29	0.20	0.07	0.04	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (19 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page