

BAKER LAKE CS, NU, Canada

WMO: 713560

Lat: 64.319N

Lon: 96.002W

Elev: 167

StdP: 14.61

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-40.6	-38.0	-49.1	0.3	-40.4	-46.1	0.4	-37.9	46.2	-21.6	41.5	-22.6	12.8	330	1.061

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	70.1	57.1	66.4	55.3	62.9	53.6	58.8	67.7	56.6	64.3	54.3	61.6	11.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.5	63.5	62.1	52.1	58.2	60.0	50.1	53.8	57.7	25.7	68.1	24.2	64.2	22.8	61.8	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.3	34.0	29.6	DB	-43.6	78.3	3.3	4.8	-46.0	81.8	-48.0	84.6	-49.9	87.3	-52.3	90.8	(4)
(5)			WB	-43.6	62.6	3.0	2.6	-45.7	64.4	-47.4	65.9	-49.1	67.4	-51.3	69.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	-20.8	-22.9	-14.4	2.8	21.5	42.3	54.1	50.9	38.5	21.9	-1.4	-14.2		
	DBStd	29.07	10.94	10.36	12.12	11.15	9.62	7.67	5.75	5.67	6.61	9.15	12.34	11.86		
	HDD50	13619	2195	2042	1996	1417	884	254	25	56	346	870	1543	1991		
	HDD65	18836	2660	2462	2461	1867	1349	682	340	437	794	1335	1993	2456		
	CDD50	261	0	0	0	0	0	22	152	85	2	0	0	0		
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH74	37	0	0	0	0	0	8	24	5	0	0	0	0		
	CDH80	4	0	0	0	0	0	2	0	0	0	0	0	0		
	WSAvg	13.9	15.3	16.1	13.8	14.7	13.3	12.2	11.9	12.3	13.3	14.3	14.4	14.8		
	PrecAvg	10.5	0.4	0.3	0.5	0.6	0.6	0.9	1.5	1.7	1.7	1.3	0.7	0.4		
(15) Precipitation	PrecMax	15.2	1.1	1.1	1.5	1.6	1.7	2.3	3.9	3.7	3.7	3.4	2.4	1.3		
	PrecMin	6.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.3	0.2	0.0	0.0		
	PrecStd	2.3	0.3	0.2	0.3	0.4	0.4	0.6	1.0	1.0	0.8	0.7	0.5	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.8	8.1	19.2	33.5	44.0	71.1	77.1	73.2	59.0	42.6	29.6	25.3		
		MCWB	16.0	7.1	18.5	32.2	38.9	56.9	60.3	59.0	51.4	40.2	29.1	24.7		
	2%	DB	3.3	3.0	14.1	27.3	38.3	64.2	72.3	67.6	54.3	37.6	25.0	15.6		
		MCWB	2.7	2.5	13.2	26.0	35.8	53.0	57.8	55.9	47.9	36.0	24.4	15.0		
	5%	DB	-0.3	-1.5	9.4	23.6	35.6	59.2	68.5	63.9	51.0	35.0	21.7	9.0		
		MCWB	-0.8	-2.1	8.7	22.4	33.6	49.6	56.2	54.3	46.3	33.7	21.0	8.3		
	10%	DB	-4.5	-6.7	5.4	19.6	33.5	54.9	65.2	60.6	47.9	33.2	17.8	3.5		
		MCWB	-5.0	-7.2	4.8	18.7	31.9	47.2	54.8	53.0	44.4	32.3	17.2	2.8		
	0.4%	WB	16.4	7.5	18.5	32.1	39.3	58.0	62.1	60.3	52.7	40.5	29.1	24.9		
		MCDB	17.9	8.2	19.1	33.2	43.2	68.9	73.1	68.1	57.7	41.9	29.3	25.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	2.6	2.5	13.4	26.1	35.9	53.4	59.8	58.0	48.9	36.1	24.4	15.1		
		MCDB	2.9	2.9	14.0	27.1	38.0	62.8	69.4	65.6	52.6	37.3	24.8	15.5		
	5%	WB	-0.9	-2.2	8.7	22.6	33.8	50.2	57.7	55.7	46.7	33.9	21.1	8.4		
		MCDB	-0.3	-1.7	9.3	23.6	35.2	58.3	66.0	62.0	50.4	34.7	21.7	9.0		
	10%	WB	-5.0	-7.2	4.7	18.7	32.2	47.6	55.6	53.5	44.5	32.4	17.2	2.8		
		MCDB	-4.5	-6.7	5.2	19.5	33.4	54.6	63.8	59.1	47.7	33.2	17.9	3.4		
	5% DB	MDBR	11.2	10.4	12.9	14.1	10.7	13.9	16.1	13.2	10.0	8.7	11.6	11.4		
		MCDBR	16.1	16.3	16.0	15.9	10.9	22.1	21.8	19.0	15.4	8.6	14.1	16.7		
		MCWBR	16.1	16.0	15.8	15.3	9.2	13.1	10.9	10.1	10.6	7.8	14.2	16.5		
		MCWBR	16.1	16.2	15.9	15.7	10.4	21.2	19.9	16.9	14.4	7.9	14.3	16.9		
(40) Clear-Sky Solar Irradiance	taub		0.160	0.230	0.255	0.321	0.347	0.330	0.347	0.332	0.303	0.260	0.165	0.148		
	taud		1.927	2.153	2.229	2.065	2.135	2.456	2.459	2.498	2.509	2.257	1.923	1.920		
	Ebn at Noon		141	224	269	267	271	282	272	267	252	206	128	64		
	Edh at Noon		8	18	26	40	41	31	30	26	21	16	8	3		
(44) All-Sky Solar Radiation	RadAvg		55	298	866	1607	2022	1820	1717	1220	674	241	80	20		
	RadStd		5	20	39	71	123	140	134	104	75	37	13	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page