

BAKER LAKE CS, NU, Canada

WMO: 713560

Lat: 64.319N

Lon: 96.002W

Elev: 51

StdP: 100.72

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-40.3	-38.9	-45.0	0.0	-40.2	-43.4	0.1	-38.9	20.6	-29.8	18.5	-30.3	5.7	330	1.061

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	21.2	14.0	19.1	12.9	17.2	12.0	14.9	19.8	13.6	17.9	12.4	16.4	4.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	9.1	16.7	11.2	8.3	15.6	10.0	7.7	14.3	41.9	20.1	38.5	17.9	35.2	16.5	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.1	15.2	13.2	DB	-42.0	25.7	1.9	2.7	-43.3	27.6	-44.4	29.2	-45.5	30.7	-46.8	32.7	(4)
(5)			WB	-42.0	17.0	1.6	1.4	-43.2	18.0	-44.1	18.9	-45.1	19.7	-46.3	20.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.3	-29.3	-30.5	-25.8	-16.2	-5.8	5.7	12.3	10.5	3.6	-5.6	-18.6	-25.7	(6)	
	DBStd	16.15	6.08	5.75	6.73	6.19	5.35	4.26	3.19	3.15	3.67	5.08	6.86	6.59	(7)	
	HDD10.0	7566	1219	1134	1109	787	491	141	14	31	192	483	857	1106	(8)	
	HDD18.3	10464	1478	1368	1367	1037	749	379	189	243	441	742	1107	1364	(9)	
	CDD10.0	145	0	0	0	0	0	12	84	47	1	0	0	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH23.3	21	0	0	0	0	0	4	13	3	0	0	0	0	(12)	
	CDH26.7	2	0	0	0	0	0	1	1	0	0	0	0	0	(13)	
	Wind	WSAvg	6.2	6.8	7.2	6.2	6.6	5.9	5.5	5.3	5.5	6.0	6.4	6.4	6.6	(14)
	Precipitation	PrecAvg	266	9	7	12	15	16	23	38	42	42	32	19	10	(15)
(16) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	PrecMax	386	28	27	39	40	42	59	100	93	94	87	60	33	(16)	
	PrecMin	153	0	0	0	1	0	0	1	5	8	5	0	1	(17)	
	PrecStd	58	7	6	8	9	11	15	25	25	21	18	13	8	(18)	
	0.4%	DB	-8.4	-13.3	-7.1	0.8	6.6	21.7	25.0	22.9	15.0	5.9	-1.3	-3.7	(19)	
		MCWB	-8.9	-13.8	-7.5	0.1	3.9	13.8	15.7	15.0	10.8	4.5	-1.6	-4.0	(20)	
	2%	DB	-16.0	-16.1	-9.9	-2.6	3.5	17.9	22.4	19.8	12.4	3.1	-3.9	-9.1	(21)	
		MCWB	-16.3	-16.4	-10.4	-3.3	2.1	11.7	14.4	13.3	8.8	2.2	-4.2	-9.5	(22)	
	5%	DB	-18.0	-18.6	-12.5	-4.7	2.0	15.1	20.3	17.7	10.5	1.7	-5.7	-12.8	(23)	
		MCWB	-18.2	-18.9	-13.0	-5.3	0.9	9.8	13.5	12.4	7.9	1.0	-6.1	-13.2	(24)	
	10%	DB	-20.3	-21.5	-14.8	-6.9	0.8	12.7	18.4	15.9	8.8	0.7	-7.9	-15.8	(25)	
		MCWB	-20.6	-21.8	-15.1	-7.4	0.0	8.5	12.6	11.7	6.9	0.1	-8.2	-16.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.7	-13.6	-7.5	0.1	4.1	14.5	16.7	15.7	11.5	4.7	-1.6	-4.0	(27)	
		MCDB	-7.8	-13.2	-7.2	0.6	6.2	20.5	22.8	20.1	14.3	5.5	-1.5	-3.8	(28)	
	2%	WB	-16.3	-16.4	-10.3	-3.3	2.2	11.9	15.4	14.4	9.4	2.3	-4.2	-9.4	(29)	
		MCDB	-16.2	-16.1	-10.0	-2.7	3.3	17.1	20.8	18.7	11.5	3.0	-4.0	-9.1	(30)	
	5%	WB	-18.3	-19.0	-12.9	-5.2	1.0	10.1	14.3	13.2	8.2	1.1	-6.1	-13.1	(31)	
		MCDB	-18.0	-18.7	-12.6	-4.7	1.8	14.6	18.9	16.6	10.2	1.5	-5.7	-12.8	(32)	
	10%	WB	-20.5	-21.8	-15.2	-7.4	0.1	8.7	13.1	12.0	6.9	0.2	-8.2	-16.2	(33)	
		MCDB	-20.3	-21.5	-14.9	-7.0	0.8	12.6	17.7	15.1	8.7	0.7	-7.9	-15.9	(34)	
	Mean Daily Temperature Range	MDBR	6.2	5.8	7.1	7.8	6.0	7.7	8.9	7.4	5.6	4.8	6.5	6.3	(35)	
		5% DB	9.0	9.0	8.9	8.8	6.1	12.3	12.1	10.6	8.6	4.8	7.8	9.3	(36)	
		MCWBR	8.9	8.9	8.8	8.5	5.1	7.3	6.1	5.6	5.9	4.3	7.9	9.2	(37)	
		5% WB	8.9	9.0	8.9	8.7	5.8	11.8	11.1	9.4	8.0	4.4	8.0	9.4	(38)	
	Clear-Sky Solar Irradiance	MCWBR	8.9	8.8	8.8	8.4	5.0	7.4	6.3	5.7	6.0	4.1	8.0	9.4	(39)	
		taub	0.160	0.230	0.255	0.321	0.347	0.330	0.347	0.332	0.303	0.260	0.165	0.148	(40)	
		taud	1.927	2.153	2.229	2.065	2.135	2.456	2.459	2.498	2.509	2.257	1.923	1.920	(41)	
		Ebn at Noon	445	705	847	842	854	888	859	841	796	649	405	203	(42)	
	All-Sky Solar Radiation	Edh at Noon	25	57	83	126	130	97	94	83	66	51	24	9	(43)	
		RadAvg	0.17	0.94	2.73	5.07	6.38	5.74	5.41	3.85	2.12	0.76	0.25	0.06	(44)	
		RadStd	0.02	0.06	0.12	0.22	0.39	0.44	0.42	0.33	0.24	0.12	0.04	0.00	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page