

QIKIQTARJUAQ, NU, Canada

WMO: 713570

Lat: 67.547N

Lon: 64.033W

Elev: 18

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-34.2	-30.7	-42.1	0.5	-33.8	-38.4	0.6	-30.3	24.6	-3.7	21.5	-2.5	2.7	190	0.993

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	54.1	47.9	50.9	46.1	48.1	44.1	48.6	53.2	46.4	50.2	44.4	47.5	10.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.2	44.4	50.9	43.4	41.5	48.1	41.8	39.0	45.9	19.6	53.4	18.4	50.4	17.4	47.7	58.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	19.0	16.3	DB	-39.3	64.5	5.3	5.0	-43.1	68.1	-46.2	71.0	-49.2	73.8	-53.0	77.4	(4)
(5)			WB	-39.4	53.6	5.3	2.8	-43.2	55.6	-46.3	57.2	-49.3	58.8	-53.1	60.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	-12.9	-15.5	-10.2	1.5	21.9	34.4	40.3	41.6	36.0	26.4	14.0	-3.6	
	DBStd	22.27	10.57	10.13	10.35	9.21	7.72	4.27	5.45	4.40	3.87	5.43	8.93	10.44	
	HDD50	12909	1949	1835	1868	1454	870	469	304	265	421	732	1081	1661	
	HDD65	18377	2414	2255	2333	1904	1335	919	766	726	871	1197	1531	2126	
	CDD50	7	0	0	0	0	0	0	3	4	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	6.5	5.9	5.9	6.1	5.7	5.6	6.7	7.2	7.1	7.1	7.0	7.4	6.2	
Precipitation	PrecAvg	15.7	0.8	0.6	0.6	0.6	1.0	1.2	1.5	2.1	2.4	2.3	1.5	1.2	
	PrecMax	24.4	2.7	2.2	1.5	1.5	2.0	2.6	2.9	3.1	4.9	4.5	5.4	3.8	
	PrecMin	7.3	0.2	0.1	0.1	0.0	0.1	0.2	0.2	0.9	0.6	0.7	0.3	0.2	
	PrecStd	4.3	0.7	0.5	0.4	0.4	0.5	0.6	0.7	0.6	0.9	0.9	1.1	1.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.2	9.8	19.1	28.1	37.4	52.1	60.8	59.8	50.4	43.2	34.2	29.6	
		MCWB	19.9	9.0	18.1	25.9	34.3	45.3	52.0	50.9	42.5	37.4	30.2	27.0	
	2%	DB	11.8	6.4	13.3	22.8	34.6	46.1	54.8	54.0	45.5	38.2	30.4	18.9	
		MCWB	10.9	5.5	12.4	21.3	32.5	41.3	48.4	48.3	40.8	34.8	28.5	18.1	
	5%	DB	7.1	3.2	9.2	18.6	33.0	43.3	51.7	50.7	42.8	35.2	28.1	14.3	
		MCWB	6.4	2.3	8.4	17.2	31.3	39.4	46.5	46.4	39.6	32.8	26.4	13.3	
	10%	DB	2.6	-0.3	4.9	15.0	31.4	40.7	48.9	47.9	40.8	33.3	26.1	10.3	
		MCWB	1.8	-1.0	4.1	13.8	30.1	37.8	44.7	44.5	38.1	31.5	24.5	9.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	8.9	18.3	26.0	34.9	45.5	52.3	51.9	43.8	37.9	31.2	26.5
			MCDB	20.1	9.3	19.0	27.6	36.8	51.8	59.6	58.2	47.7	41.4	33.1	29.3
2%		WB	10.9	5.5	12.4	21.1	32.9	41.7	49.2	48.7	41.6	35.5	28.6	18.1	
		MCDB	11.7	6.2	13.1	22.7	34.3	45.5	54.1	53.3	44.5	37.7	30.0	18.7	
5%		WB	6.5	2.4	8.4	17.1	31.5	39.6	46.8	46.7	39.9	33.4	26.6	13.2	
		MCDB	7.2	3.1	9.1	18.4	32.7	42.9	51.0	50.2	42.0	34.6	28.0	14.1	
10%		WB	1.8	-1.1	4.1	13.9	30.2	37.8	44.8	44.8	38.7	31.9	24.6	9.3	
		MCDB	2.6	-0.4	4.8	15.0	31.2	40.4	48.5	47.5	40.4	33.1	26.0	10.1	
Mean Daily Temperature Range		5% DB	MDBR	12.3	12.3	12.8	14.9	9.7	7.9	10.3	8.0	6.0	7.4	8.7	11.0
			MCDBR	14.0	13.3	12.2	15.7	8.6	13.1	16.2	13.7	9.5	8.5	9.1	13.2
	MCWBR		13.7	12.7	11.6	14.2	7.0	9.3	10.7	8.7	6.3	6.8	8.2	12.4	
	5% WB	MCDBR	14.2	13.0	12.1	15.3	8.0	12.6	15.8	13.1	8.2	7.4	9.0	13.0	
		MCWBR	13.8	12.5	11.6	13.8	6.6	9.1	10.9	8.7	5.7	6.3	8.2	12.3	
Clear-Sky Solar Irradiance	taub	0.165	0.211	0.258	0.314	0.348	0.341	0.342	0.345	0.296	0.246	0.173	N/A		
	taud	1.847	2.051	2.111	1.973	1.972	2.165	2.328	2.361	2.368	2.148	1.909	N/A		
	Ebn at Noon	49	199	250	260	263	271	268	253	239	176	43	0		
	Edh at Noon	3	16	27	41	47	40	33	29	22	14	3	0		
All-Sky Solar Radiation	RadAvg	16	205	763	1546	2133	2184	1763	1162	670	253	36	0		
	RadStd	1	10	30	66	77	145	117	67	41	16	4	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	+1.12	+2.63	+3.20	N/A	N/A	N/A	-392	-400	N/A	N/A	

Nomenclature: See separate page