

QIKIQTARJUAQ, NU, Canada

WMO: 713570

Lat: 67.547N

Lon: 64.033W

Elev: 6

StdP: 101.26

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-36.8	-34.8	-41.1	0.1	-36.6	-39.1	0.1	-34.6	11.0	-19.8	9.6	-19.2	1.2	190	0.993

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	12.3	8.8	10.5	7.8	8.9	6.7	9.2	11.8	8.0	10.1	6.9	8.6	4.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.3	6.3	10.5	6.3	5.9	8.9	5.4	5.6	7.7	27.6	11.9	24.9	10.2	22.5	8.7	14.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.5	7.3	DB	-39.6	18.0	3.0	2.8	-41.7	20.0	-43.4	21.7	-45.1	23.2	-47.2	25.2	(4)
(5)			WB	-39.7	12.0	2.9	1.5	-41.8	13.1	-43.5	14.0	-45.1	14.9	-47.3	16.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.6	-24.9	-26.4	-23.5	-16.9	-5.6	1.3	4.6	5.3	2.2	-3.1	-10.0	-19.8	(6)	
	DBStd	12.37	5.87	5.63	5.75	5.12	4.29	2.37	3.03	2.44	2.15	3.02	4.96	5.80	(7)	
	HDD10.0	7172	1083	1019	1038	808	483	261	169	147	234	407	601	923	(8)	
	HDD18.3	10209	1341	1253	1296	1058	742	511	426	403	484	665	851	1181	(9)	
	CDD10.0	4	0	0	0	0	0	0	2	2	0	0	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	2.9	2.6	2.7	2.7	2.5	2.5	3.0	3.2	3.2	3.2	3.1	3.3	2.8	(14)	
(15) Precipitation	PrecAvg	399	21	14	14	15	25	31	37	54	60	59	38	31	(15)	
	PrecMax	620	68	56	39	37	50	66	74	79	125	114	138	97	(16)	
	PrecMin	185	4	2	2	1	3	5	6	24	16	17	8	5	(17)	
	PrecStd	109	18	12	10	10	12	15	18	14	23	24	28	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.5	-12.3	-7.1	-2.2	3.0	11.1	16.0	15.5	10.2	6.2	1.2	-1.3	(19)	
		MCWB	-6.7	-12.8	-7.7	-3.4	1.3	7.4	11.1	10.5	5.8	3.0	-1.0	-2.8	(20)	
	2%	DB	-11.2	-14.2	-10.4	-5.1	1.5	7.8	12.7	12.2	7.5	3.4	-0.9	-7.3	(21)	
		MCWB	-11.7	-14.7	-10.9	-5.9	0.3	5.1	9.1	9.1	4.9	1.5	-1.9	-7.7	(22)	
	5%	DB	-13.8	-16.0	-12.6	-7.5	0.6	6.3	10.9	10.4	6.0	1.8	-2.1	-9.8	(23)	
		MCWB	-14.2	-16.5	-13.1	-8.2	-0.4	4.1	8.1	8.0	4.2	0.5	-3.1	-10.4	(24)	
	10%	DB	-16.3	-18.0	-15.1	-9.4	-0.3	4.8	9.4	8.8	4.9	0.7	-3.3	-12.1	(25)	
		MCWB	-16.8	-18.4	-15.5	-10.1	-1.1	3.2	7.0	7.0	3.4	-0.3	-4.1	-12.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-6.9	-12.8	-7.6	-3.3	1.6	7.5	11.3	11.1	6.6	3.3	-0.5	-3.1	(27)	
		MCDB	-6.6	-12.6	-7.2	-2.4	2.7	11.0	15.3	14.6	8.7	5.2	0.6	-1.5	(28)	
	2%	WB	-11.7	-14.7	-10.9	-6.0	0.5	5.4	9.5	9.3	5.3	2.0	-1.9	-7.7	(29)	
		MCDB	-11.3	-14.4	-10.5	-5.2	1.3	7.5	12.3	11.8	7.0	3.1	-1.1	-7.4	(30)	
	5%	WB	-14.2	-16.5	-13.1	-8.3	-0.3	4.2	8.2	8.2	4.4	0.8	-3.0	-10.4	(31)	
		MCDB	-13.8	-16.0	-12.7	-7.6	0.4	6.1	10.6	10.1	5.6	1.4	-2.2	-9.9	(32)	
	10%	WB	-16.8	-18.4	-15.5	-10.1	-1.0	3.2	7.1	7.1	3.7	-0.1	-4.1	-12.6	(33)	
		MCDB	-16.4	-18.0	-15.1	-9.5	-0.4	4.7	9.2	8.6	4.7	0.6	-3.3	-12.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	6.8	7.1	8.3	5.4	4.4	5.7	4.4	3.3	4.1	4.8	6.1	(35)	
		MCDBR	7.8	7.4	6.8	8.7	4.8	7.3	9.0	7.6	5.3	4.7	5.1	7.4	(36)	
	5% WB	MCWBR	7.6	7.1	6.5	7.9	3.9	5.2	6.0	4.8	3.5	3.8	4.5	6.9	(37)	
		MCWBR	7.9	7.2	6.7	8.5	4.4	7.0	8.8	7.3	4.6	4.1	5.0	7.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.165	0.211	0.258	0.314	0.348	0.341	0.342	0.345	0.296	0.246	0.173	N/A	(40)	
		taud	1.847	2.051	2.111	1.973	1.972	2.165	2.328	2.361	2.368	2.148	1.909	N/A	(41)	
	Ebn at Noon		155	626	788	820	830	855	845	798	752	556	135	0	(42)	
		Edh at Noon	11	49	84	130	147	125	103	90	68	44	9	0	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.05	0.65	2.41	4.87	6.72	6.88	5.56	3.66	2.11	0.80	0.11	0.00	(44)	
	RadStd		0.00	0.03	0.09	0.21	0.24	0.46	0.37	0.21	0.13	0.05	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.62	+1.46	+1.78	N/A	N/A	N/A	-218	-222	N/A	N/A

Nomenclature: See separate page