

FORT SIMPSON, NT, Canada

WMO: 713650

Lat: 61.7587N

Lon: 121.2301W

Elev: 168

StdP: 99.32

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.1	-36.8	-41.6	0.1	-37.5	-38.7	0.1	-35.1	8.7	-17.2	7.9	-18.4	0.4	320	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	28.5	17.2	26.7	16.4	24.9	15.7	18.6	25.7	17.7	24.4	16.8	22.9	2.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	11.7	20.3	15.1	10.9	19.9	14.1	10.2	19.3	53.4	25.8	50.5	24.6	47.7	23.1	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.1	6.1	-42.3	31.8	3.1	1.9	-44.6	33.1	-46.4	34.2	-48.2	35.2	-50.4	36.6		
(5)			-40.6	20.4	2.4	1.1	-42.3	21.3	-43.7	21.9	-45.0	22.6	-46.8	23.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.2	-23.5	-19.4	-13.1	-0.7	9.3	15.5	17.7	15.0	8.6	-1.1	-14.5	-21.5	(6)
(7)		DBStd	16.03	8.03	6.86	8.27	6.58	5.36	3.92	3.24	3.89	4.45	4.71	6.61	7.39	(7)
(8)		HDD10.0	5124	1039	823	716	323	77	6	0	6	78	344	735	976	(8)
(9)		HDD18.3	7564	1297	1056	974	572	283	99	51	116	293	602	985	1234	(9)
(10)		CDD10.0	661	0	0	0	1	54	172	238	161	35	1	0	0	(10)
(11)		CDD18.3	61	0	0	0	0	2	15	31	12	1	0	0	0	(11)
(12)		CDH23.3	748	0	0	0	0	48	197	338	156	9	0	0	0	(12)
(13)		CDH26.7	161	0	0	0	0	6	42	76	36	1	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.0	2.2	2.7	2.7	2.8	2.6	2.4	2.4	2.3	2.1	2.0	(14)	
(15)	Precipitation	PrecAvg	376	19	18	17	17	31	47	58	55	31	37	24	19	(15)
(16)		PrecMax	632	41	55	52	65	100	178	132	116	94	154	49	56	(16)
(17)		PrecMin	247	0	5	0	0	2	7	13	9	7	3	6	7	(17)
(18)		PrecStd	78	10	12	13	14	23	33	29	31	18	26	13	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	3.8	10.3	18.3	27.4	30.4	31.1	30.3	24.1	15.1	4.9	1.8	(19)
(20)			MCWB	0.2	0.6	4.1	8.9	14.0	17.1	18.7	18.7	14.6	8.4	1.3	-0.6	(20)
(21)		2%	DB	-5.4	-3.8	6.3	14.7	24.5	27.7	28.7	27.1	21.1	10.3	-1.3	-5.6	(21)
(22)			MCWB	-6.0	-5.1	1.7	6.9	13.1	16.1	17.7	17.1	13.4	6.2	-2.0	-6.3	(22)
(23)		5%	DB	-10.1	-7.2	2.8	12.3	21.9	25.6	26.9	24.8	18.6	7.3	-3.7	-8.2	(23)
(24)			MCWB	-10.5	-7.9	-0.2	5.5	12.1	15.1	17.2	16.2	12.0	4.7	-4.2	-8.6	(24)
(25)		10%	DB	-13.5	-10.2	-0.9	9.6	19.0	23.6	25.1	22.7	16.3	4.9	-5.9	-11.1	(25)
(26)			MCWB	-13.9	-10.8	-2.8	4.1	10.3	14.4	16.5	15.3	11.1	3.1	-6.4	-11.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.2	0.8	4.3	9.5	15.3	18.7	20.1	19.6	16.1	9.2	1.4	-0.4	(27)
(28)			MCDWB	3.2	3.6	9.7	17.6	24.7	26.0	27.8	28.0	22.6	13.6	3.8	1.6	(28)
(29)		2%	WB	-5.9	-4.9	1.8	7.2	13.6	17.4	19.0	18.1	14.1	6.6	-2.0	-6.2	(29)
(30)			MCDWB	-5.2	-3.8	5.9	14.2	22.9	24.5	26.1	25.1	19.5	9.8	-1.3	-5.7	(30)
(31)		5%	WB	-10.3	-7.9	-0.2	5.7	12.3	16.3	18.1	16.9	12.6	4.9	-4.2	-8.6	(31)
(32)			MCDWB	-9.9	-7.1	2.7	11.8	21.2	23.1	24.9	23.1	17.3	7.2	-3.7	-8.2	(32)
(33)		10%	WB	-13.6	-10.7	-2.7	4.2	10.8	15.3	17.3	15.8	11.5	3.2	-6.3	-11.4	(33)
(34)			MCDWB	-13.3	-10.2	-0.8	9.4	18.6	21.8	23.6	21.4	15.7	4.8	-5.9	-11.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.6	9.6	11.8	11.6	12.4	11.9	11.5	11.2	10.4	6.4	6.9	7.4	(35)
(36)			MCDBR	11.6	12.9	14.1	14.9	16.0	14.8	14.7	14.9	14.6	11.3	7.3	9.9	(36)
(37)			MCWBR	10.8	11.8	10.2	8.7	7.9	6.5	6.5	7.1	8.0	7.7	6.6	9.2	(37)
(38)		5% WB	MCDBR	11.6	13.0	13.9	14.4	15.2	12.6	13.0	13.2	13.3	10.5	7.3	10.0	(38)
(39)			MCWBR	10.9	11.8	10.2	8.5	7.7	6.0	6.2	6.8	7.7	7.4	6.6	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.193	0.246	0.267	0.333	0.344	0.354	0.380	0.354	0.308	0.273	0.199	0.157	(40)	
(41)		taud	2.111	2.260	2.264	2.198	2.427	2.443	2.390	2.464	2.582	2.521	2.140	1.958	(41)	
(42)		Ebn at Noon	559	750	860	852	877	872	835	830	821	728	536	409	(42)	
(43)		Edh at Noon	33	60	86	115	100	101	104	89	66	48	31	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.34	1.21	3.01	4.96	5.69	5.90	5.40	4.21	2.66	1.15	0.40	0.17	(44)	
(45)		RadStd	0.02	0.07	0.13	0.24	0.40	0.49	0.36	0.30	0.27	0.10	0.05	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page