

ILE AUX PERROQUETS, QC, Canada

WMO: 713750

Lat: 50.2208N

Lon: 64.2072W

Elev: 9

StdP: 101.22

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.4	-19.3	-27.0	0.3	-20.7	-24.6	0.4	-18.6	20.4	-6.7	19.0	-7.5	8.0	320	0.906

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	17.6	15.4	16.4	14.6	15.4	13.9	15.9	16.9	15.0	15.9	14.1	14.9	4.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	10.9	16.4	14.5	10.3	15.5	13.6	9.7	14.6	44.5	17.0	42.0	16.0	39.4	14.9	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
17.2	15.1	13.2	DB	-24.7	20.7	2.1	1.5	-26.2	21.8	-27.4	22.7	-28.5	23.5	-30.0	24.6	(4)
			WB	-25.2	18.1	2.0	1.0	-26.7	18.7	-27.8	19.3	-29.0	19.8	-30.4	20.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.9	-9.9	-9.6	-5.3	0.1	4.7	9.1	12.1	12.2	9.0	5.3	0.3	-5.9	
	DBStd	8.50	5.37	5.05	4.50	2.54	2.16	2.16	1.88	2.32	2.32	2.37	3.67	4.88	
	HDD10.0	3125	616	548	474	296	163	42	4	7	45	146	291	493	
	HDD18.3	5989	874	782	733	546	422	277	192	189	279	403	541	751	
	CDD10.0	178	0	0	0	0	0	16	70	76	17	1	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	6.5	8.2	7.7	7.2	6.6	5.5	5.4	5.0	5.0	5.6	6.6	7.5	8.3	
Precipitation	PrecAvg	1099	83	68	87	76	91	92	93	85	96	116	117	98	
	PrecMax	1264	185	141	179	180	200	172	183	151	176	194	204	242	
	PrecMin	937	19	26	34	17	36	36	46	41	42	38	48	40	
	PrecStd	94	39	28	43	39	40	41	39	27	30	40	39	44	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	3.1	3.8	7.9	12.4	16.6	18.9	19.2	16.9	12.0	9.2	5.3	
		MCWB	2.0	1.8	1.3	4.4	8.4	12.7	15.7	16.8	14.4	10.0	8.6	4.7	
	2%	DB	1.3	1.0	2.1	5.5	10.1	14.9	17.3	17.9	14.8	10.5	6.9	3.7	
		MCWB	0.5	0.0	0.3	2.9	7.6	12.2	15.2	15.9	12.8	9.1	6.1	2.8	
	5%	DB	-0.3	-0.6	1.0	4.1	8.9	13.6	16.2	16.8	13.5	9.4	5.8	2.2	
		MCWB	-0.9	-1.2	-0.3	2.1	6.8	11.4	14.5	15.1	11.9	8.1	5.0	1.3	
	10%	DB	-2.0	-2.2	0.1	3.2	7.9	12.4	15.2	15.8	12.4	8.5	5.0	1.0	
		MCWB	-2.7	-3.0	-0.9	1.6	6.1	10.5	13.8	14.3	10.9	7.2	4.1	0.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.5	2.3	2.2	4.8	9.4	14.8	17.3	17.3	14.7	10.9	8.8	5.0
			MCDB	3.2	2.9	3.1	6.9	10.7	15.9	18.2	18.5	15.9	11.5	9.1	5.4
2%		WB	0.8	0.3	0.9	3.4	8.0	13.1	15.8	16.1	13.0	9.6	6.4	3.1	
		MCDB	1.4	1.1	1.6	4.7	9.3	14.0	16.8	17.1	13.7	10.2	6.8	3.6	
5%		WB	-0.6	-0.8	0.1	2.6	7.1	11.9	15.0	15.1	11.8	8.5	5.3	1.5	
		MCDB	-0.1	-0.1	0.8	3.7	8.5	13.0	15.9	16.0	12.5	9.1	5.7	2.0	
10%		WB	-2.5	-2.9	-0.7	1.8	6.2	10.8	14.1	14.2	10.8	7.5	4.1	0.3	
		MCDB	-1.9	-2.2	0.0	2.9	7.5	12.0	14.9	15.1	11.6	8.2	4.7	0.9	
Mean Daily Temperature Range		5% DB	MDBR	6.7	6.6	6.1	4.3	4.5	5.1	5.4	5.3	4.7	3.8	4.2	5.4
			MCDBR	7.6	6.4	5.5	5.3	6.2	7.0	6.9	6.3	5.8	4.6	4.5	5.5
	MCWBR		7.3	6.0	4.7	4.0	4.4	4.9	5.1	4.9	4.6	4.0	4.8	5.4	
	5% WB	MCDBR	7.5	6.0	5.1	4.8	5.6	6.2	6.3	6.0	5.4	4.1	4.6	5.5	
		MCWBR	7.6	5.9	4.8	3.9	4.3	5.1	5.3	5.0	4.8	4.1	4.9	5.6	
Clear-Sky Solar Irradiance	taub	0.267	0.271	0.294	0.338	0.362	0.383	0.417	0.381	0.355	0.331	0.291	0.273		
	taud	2.368	2.333	2.342	2.344	2.410	2.382	2.337	2.440	2.481	2.514	2.517	2.377		
	Ebn at Noon	786	878	916	906	896	875	837	853	841	800	759	718		
	Edh at Noon	63	84	100	113	111	115	119	102	88	72	56	55		
All-Sky Solar Radiation	RadAvg	1.04	2.02	3.33	4.49	5.22	5.60	5.31	4.52	3.41	2.08	1.09	0.81		
	RadStd	0.12	0.17	0.29	0.38	0.32	0.51	0.49	0.23	0.22	0.15	0.10	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (9 neighbors)	N/A	N/A	+1.24	N/A	+0.33	+0.36	N/A	N/A	N/A	N/A

Nomenclature: See separate page