

ST-JOVITE, QC, Canada

WMO: 713760

Lat: 46.0803N

Lon: 74.5558W

Elev: 782

StdP: 14.29

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.1	-17.1	-30.0	1.1	-22.2	-23.8	1.5	-15.9	12.1	25.1	10.7	21.9	0.9	70	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.7	84.7	69.1	81.7	67.4	78.9	65.7	72.3	79.8	70.5	77.4	68.7	75.1	5.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	113.9	75.6	68.3	107.0	73.6	66.5	100.4	71.9	36.6	80.0	34.9	77.3	33.4	75.1	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.5	9.2	7.8	DB	-31.5	89.7	5.7	3.3	-35.5	92.1	-38.9	94.0	-42.1	95.9	-46.2	98.3
			WB	-31.6	76.2	5.7	2.1	-35.8	77.8	-39.1	79.0	-42.3	80.2	-46.5	81.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	39.8	10.4	13.3	24.5	38.6	51.8	60.5	64.9	63.0	55.5	43.8	31.6	18.5	(6)
(7)		DBStd	21.27	14.45	12.92	11.94	8.31	7.80	6.85	5.39	5.74	7.51	7.96	9.53	12.31	(7)
(8)		HDD50	5262	1229	1028	792	354	70	5	0	0	30	227	552	975	(8)
(9)		HDD65	9343	1694	1448	1256	792	414	166	69	107	297	659	1001	1440	(9)
(10)		CDD50	1552	0	0	1	11	127	321	461	403	194	33	1	0	(10)
(11)		CDD65	160	0	0	0	0	6	32	65	45	12	0	0	0	(11)
(12)		CDH74	2036	0	0	1	9	161	468	738	497	157	5	0	0	(12)
(13)		CDH80	453	0	0	0	1	31	115	174	95	37	0	0	0	(13)
(14)	Wind	WSAvg	2.8	2.8	3.0	3.2	3.5	3.2	2.7	2.5	2.4	2.5	2.8	2.9	2.6	(14)
(15)	Precipitation	PrecAvg	41.3	2.9	2.2	2.8	2.9	3.4	4.3	4.1	4.0	4.1	3.5	3.2	3.5	(15)
(16)		PrecMax	50.6	4.8	6.0	4.8	5.9	5.6	7.1	7.4	6.3	8.8	6.3	6.3	5.6	(16)
(17)		PrecMin	35.2	1.3	1.0	0.5	0.9	1.8	2.0	2.7	1.5	1.2	1.5	0.9	1.3	(17)
(18)		PrecStd	4.1	1.1	1.1	1.3	1.2	1.2	1.4	1.2	1.3	1.9	1.2	1.1	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.0	45.5	59.2	73.8	83.8	88.3	89.3	86.4	85.1	73.6	59.2	47.7	(19)
(20)			MCWB	46.3	39.8	48.3	56.4	64.0	71.2	73.2	70.0	68.8	60.5	53.4	45.9	(20)
(21)		2%	DB	38.8	40.0	50.2	65.6	78.6	83.2	84.4	82.7	78.4	67.0	54.7	41.2	(21)
(22)			MCWB	37.8	36.3	41.3	50.3	60.7	68.1	69.7	68.3	66.5	57.4	49.8	40.1	(22)
(23)		5%	DB	34.5	36.0	45.0	59.6	73.6	79.6	81.3	79.4	73.8	62.0	49.9	37.2	(23)
(24)			MCWB	33.2	33.4	37.9	47.7	58.1	65.8	68.1	66.5	63.8	55.1	45.8	35.9	(24)
(25)		10%	DB	31.2	33.0	40.4	54.2	68.5	75.6	78.2	76.3	69.8	57.4	45.4	34.0	(25)
(26)			MCWB	30.0	31.0	35.3	44.1	55.7	63.6	66.3	65.8	62.4	52.3	42.4	32.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.0	42.0	50.0	60.1	69.0	74.4	76.0	73.9	71.7	63.7	55.8	46.6	(27)
(28)			MDCB	47.0	43.7	55.4	68.5	79.5	83.7	84.9	81.3	79.1	68.8	57.9	47.2	(28)
(29)		2%	WB	37.9	36.8	42.7	54.3	64.9	71.1	72.7	71.4	68.8	59.5	50.8	40.3	(29)
(30)			MDCB	38.7	39.0	47.9	61.1	73.3	79.7	79.9	77.9	74.4	64.9	53.5	40.9	(30)
(31)		5%	WB	33.5	33.7	38.9	49.2	61.4	68.4	70.6	69.3	66.3	56.2	46.4	36.2	(31)
(32)			MDCB	34.3	35.6	43.7	56.9	68.3	75.3	77.1	75.4	71.4	60.7	48.9	37.1	(32)
(33)		10%	WB	30.0	31.2	35.9	45.5	58.2	66.2	68.8	67.5	63.6	53.1	42.6	33.1	(33)
(34)			MDCB	31.3	33.3	39.5	52.9	65.3	72.1	75.1	73.3	68.8	56.8	45.3	33.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.3	24.2	22.7	22.4	25.2	24.0	23.7	24.3	24.1	19.7	16.2	17.3	(35)
(36)			MCDBR	17.6	21.0	26.6	33.9	34.8	30.2	28.1	28.5	29.2	27.9	23.3	14.8	(36)
(37)			MCWBR	16.9	17.5	17.7	19.8	17.8	16.0	15.0	15.5	17.5	18.2	18.0	13.7	(37)
(38)		5% WB	MCDBR	17.3	18.7	22.7	28.6	26.3	24.5	23.1	23.2	24.4	24.0	20.6	14.1	(38)
(39)			MCWBR	17.2	16.4	16.5	19.0	15.5	14.6	13.5	13.7	15.9	17.3	17.6	13.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.250	0.276	0.311	0.334	0.369	0.402	0.398	0.387	0.359	0.327	0.298	0.266	(40)	
(41)		taud	2.345	2.252	2.263	2.414	2.388	2.294	2.312	2.351	2.419	2.519	2.504	2.360	(41)	
(42)		Ebn at Noon	275	286	291	293	285	274	274	273	272	266	255	254	(42)	
(43)		Edh at Noon	23	31	36	35	37	41	39	36	31	24	20	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	427	737	1174	1454	1625	1775	1771	1564	1215	707	422	312	(44)	
(45)		RadStd	61	91	108	130	159	130	161	75	105	67	53	26	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+126	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page