

ST-JOVITE, QC, Canada

WMO: 713760

Lat: 46.0803N

Lon: 74.5558W

Elev: 239

StdP: 98.49

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.6	-27.3	-34.4	0.2	-30.1	-31.0	0.2	-26.6	5.4	-3.8	4.8	-5.6	0.4	70	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	29.3	20.6	27.6	19.7	26.1	18.7	22.4	26.6	21.4	25.2	20.4	23.9	2.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	16.3	24.2	20.2	15.3	23.1	19.2	14.3	22.2	67.2	26.7	63.3	25.2	59.8	24.0	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.7	4.1	3.5														
			DB		-35.3	32.1	3.2	1.8	-37.5	33.4	-39.4	34.5	-41.1	35.5	-43.4	36.8
			WB		-35.4	24.6	3.2	1.2	-37.6	25.4	-39.5	26.1	-41.3	26.8	-43.6	27.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	-12.0	-10.4	-4.2	3.7	11.0	15.9	18.3	17.2	13.0	6.5	-0.2	-7.5	(6)
(7)		DBStd	11.82	8.03	7.18	6.63	4.62	4.33	3.80	2.99	3.19	4.17	4.42	5.30	6.84	(7)
(8)		HDD10.0	2923	683	571	440	197	39	3	0	0	17	126	307	542	(8)
(9)		HDD18.3	5191	941	804	698	440	230	92	38	59	165	366	556	800	(9)
(10)		CDD10.0	862	0	0	1	6	71	178	256	224	108	18	1	0	(10)
(11)		CDD18.3	89	0	0	0	0	3	18	36	25	7	0	0	0	(11)
(12)		CDH23.3	1131	0	0	1	5	89	260	410	276	87	3	0	0	(12)
(13)		CDH26.7	252	0	0	0	1	17	64	97	53	21	0	0	0	(13)
(14)	Wind	WSAvg	1.3	1.2	1.3	1.4	1.6	1.4	1.2	1.1	1.1	1.1	1.2	1.3	1.2	(14)
(15)	Precipitation	PrecAvg	1049	73	56	72	74	87	108	105	102	103	90	82	88	(15)
(16)		PrecMax	1285	123	152	123	150	142	181	189	159	223	160	161	141	(16)
(17)		PrecMin	895	32	25	13	23	45	52	69	39	31	37	23	32	(17)
(18)		PrecStd	105	28	29	32	31	30	36	30	32	48	31	29	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	7.5	15.1	23.2	28.8	31.3	31.8	30.2	29.5	23.1	15.1	8.7	(19)
(20)			MCWB	7.9	4.4	9.0	13.6	17.8	21.8	22.9	21.1	20.5	15.8	11.9	7.7	(20)
(21)		2%	DB	3.8	4.5	10.1	18.6	25.9	28.5	29.1	28.2	25.8	19.4	12.6	5.1	(21)
(22)			MCWB	3.2	2.4	5.2	10.2	16.0	20.1	21.0	20.2	19.2	14.1	9.9	4.5	(22)
(23)		5%	DB	1.4	2.2	7.2	15.3	23.1	26.4	27.4	26.3	23.2	16.6	9.9	2.9	(23)
(24)			MCWB	0.7	0.8	3.3	8.7	14.5	18.8	20.1	19.2	17.7	12.8	7.7	2.2	(24)
(25)		10%	DB	-0.4	0.6	4.7	12.3	20.3	24.2	25.7	24.6	21.0	14.1	7.4	1.1	(25)
(26)			MCWB	-1.1	-0.6	1.8	6.7	13.1	17.6	19.1	18.8	16.9	11.3	5.8	0.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	5.5	10.0	15.6	20.5	23.6	24.4	23.3	22.1	17.6	13.2	8.1	(27)
(28)			MCDWB	8.3	6.5	13.0	20.3	26.4	28.7	29.4	27.4	26.2	20.5	14.4	8.4	(28)
(29)		2%	WB	3.3	2.7	5.9	12.4	18.3	21.7	22.6	21.9	20.5	15.3	10.5	4.6	(29)
(30)			MCDWB	3.7	3.9	8.8	16.1	23.0	26.5	26.6	25.5	23.6	18.3	12.0	4.9	(30)
(31)		5%	WB	0.8	1.0	3.8	9.6	16.3	20.2	21.4	20.7	19.0	13.5	8.0	2.3	(31)
(32)			MCDWB	1.3	2.0	6.5	13.8	20.2	24.1	25.1	24.1	21.9	16.0	9.4	2.9	(32)
(33)		10%	WB	-1.1	-0.5	2.2	7.5	14.5	19.0	20.4	19.7	17.6	11.7	5.9	0.6	(33)
(34)			MCDWB	-0.4	0.7	4.2	11.6	18.5	22.3	23.9	22.9	20.4	13.8	7.4	1.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.9	13.5	12.6	12.4	14.0	13.3	13.2	13.5	13.4	11.0	9.0	9.6	(35)
(36)			MCDBR	9.8	11.7	14.8	18.9	19.3	16.8	15.6	15.8	16.2	15.5	13.0	8.2	(36)
(37)			MCWBR	9.4	9.7	9.8	11.0	9.9	8.9	8.3	8.6	9.7	10.1	10.0	7.6	(37)
(38)		5% WB	MCDBR	9.6	10.4	12.6	15.9	14.6	13.6	12.8	12.9	13.5	13.3	11.4	7.8	(38)
(39)			MCWBR	9.6	9.1	9.2	10.6	8.6	8.1	7.5	7.6	8.9	9.6	9.8	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.250	0.276	0.311	0.334	0.369	0.402	0.398	0.387	0.359	0.327	0.298	0.266	(40)	
(41)		taud	2.345	2.252	2.263	2.414	2.388	2.294	2.312	2.351	2.419	2.519	2.504	2.360	(41)	
(42)		Ebn at Noon	867	902	916	925	898	865	863	860	856	840	804	800	(42)	
(43)		Edh at Noon	73	99	114	109	116	128	124	115	98	77	64	65	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.35	2.32	3.70	4.58	5.12	5.60	5.58	4.93	3.83	2.23	1.33	0.98	(44)	
(45)		RadStd	0.19	0.29	0.34	0.41	0.50	0.41	0.51	0.24	0.33	0.21	0.17	0.08	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page