

CRESTOMERE AGCM, AB, Canada

WMO: 713800

Lat: 52.7328N

Lon: 113.9028W

Elev: 2805

StdP: 13.27

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-23.4	-17.2	-29.5	1.2	-23.4	-23.3	1.7	-17.0	29.9	24.7	26.7	22.7	3.7	150	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.0	81.5	62.4	78.8	60.8	75.9	60.0	65.8	76.7	63.8	74.6	62.0	72.6	8.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	92.0	71.3	59.6	84.6	69.0	57.7	78.7	67.0	32.2	77.0	30.5	75.0	29.2	72.6	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	21.2	18.6	-32.8	87.5	5.0	3.2	-36.4	89.8	-39.4	91.6	-42.2	93.4	-45.8	95.7		
(5)			-33.0	70.4	5.0	3.2	-36.6	72.7	-39.5	74.5	-42.3	76.3	-46.0	78.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	17.1	13.9	24.8	37.8	49.9	56.8	61.2	59.6	51.2	39.2	24.7	14.2
	DBStd	20.42	14.87	15.96	14.43	9.28	7.77	5.32	4.73	5.41	8.03	8.66	12.79	14.08
	HDD50	5595	1021	1011	780	374	100	9	0	3	80	348	760	1109
	HDD65	10006	1486	1431	1245	815	468	248	134	179	415	801	1210	1574
	CDD50	1100	0	0	0	9	98	214	349	302	116	12	0	0
	CDD65	37	0	0	0	0	2	3	18	13	1	0	0	0
	CDH74	1027	0	0	0	4	97	109	370	295	147	5	0	0
	CDH80	163	0	0	0	0	9	11	64	51	28	0	0	0
	WSAvg	7.7	8.0	7.9	7.6	9.2	9.1	8.0	6.8	6.0	6.8	7.8	7.1	7.6
	PrecAvg	19.3	0.9	0.7	0.8	1.2	2.2	3.6	3.7	2.3	1.4	0.9	0.9	0.6
(15) Precipitation	PrecMax	23.9	3.0	1.4	1.8	2.4	4.6	5.7	6.8	4.2	3.1	2.8	2.3	1.2
	PrecMin	13.4	0.1	0.0	0.0	0.2	0.7	1.0	1.2	0.8	0.0	0.1	0.2	0.2
	PrecStd	3.0	0.7	0.4	0.5	0.6	0.9	1.3	1.5	0.8	0.8	0.7	0.6	0.3
	PrecStd	3.0	0.7	0.4	0.5	0.6	0.9	1.3	1.5	0.8	0.8	0.7	0.6	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.5	47.6	56.2	72.6	81.3	81.2	85.9	85.3	83.6	71.1	59.7	45.9
		MCWB	38.0	38.0	43.5	50.9	55.7	61.3	63.7	63.7	59.8	51.6	46.3	36.6
	2%	DB	44.7	42.8	50.0	66.0	76.7	77.2	81.2	80.5	78.6	64.0	51.3	41.6
		MCWB	37.2	35.7	39.8	48.1	54.3	58.7	65.0	63.0	58.4	49.5	41.2	34.5
	5%	DB	41.5	38.9	45.9	58.5	72.2	73.9	78.2	77.2	73.2	58.8	44.8	37.6
		MCWB	35.3	33.1	37.7	43.4	52.5	57.8	63.1	62.6	56.9	46.6	37.3	31.7
	10%	DB	37.6	35.6	41.7	53.6	67.4	70.5	74.7	73.7	68.0	54.0	41.0	33.5
		MCWB	32.3	30.8	35.2	41.2	50.4	56.1	61.5	61.3	54.6	43.8	35.2	28.9
	0.4%	WB	39.1	38.9	44.1	51.3	57.6	63.9	70.4	68.5	62.0	54.0	45.9	37.8
		MCDB	46.2	46.0	54.9	71.3	77.4	74.7	80.2	78.1	76.8	69.5	57.8	44.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.4	35.8	40.6	47.7	55.2	61.4	66.5	65.7	59.9	50.3	41.4	35.0
		MCDB	44.2	41.9	48.8	65.2	71.3	73.2	77.0	76.9	74.7	62.8	49.0	41.2
	5%	WB	35.5	33.5	37.8	44.6	53.4	59.3	64.4	63.7	57.5	47.3	38.3	32.2
		MCDB	41.3	38.4	45.4	56.1	69.7	70.4	75.5	74.5	71.0	57.0	43.9	37.3
	10%	WB	32.7	31.1	35.6	41.9	51.5	57.5	62.6	61.8	55.3	44.7	35.5	29.0
		MCDB	37.3	35.3	41.0	52.2	65.9	68.1	73.0	72.5	67.6	52.9	40.2	33.0
(35) Mean Daily Temperature Range	5% DB	MDBR	18.7	19.6	19.4	20.9	24.7	22.0	23.0	23.8	25.1	21.6	18.2	18.2
		MCDBR	19.3	19.6	22.4	31.4	34.2	28.7	29.9	30.9	36.5	30.3	22.3	19.7
		MCWBR	13.8	14.0	13.9	16.5	15.3	13.4	15.4	16.2	18.2	17.1	14.4	14.6
		MCDBR	19.0	18.6	21.9	30.4	31.3	24.7	27.5	28.4	32.9	28.9	21.2	20.1
	5% WB	MCWBR	14.0	13.9	14.1	16.3	14.4	12.7	15.0	15.7	17.1	16.8	14.5	15.1
		MCWBR	14.0	13.9	14.1	16.3	14.4	12.7	15.0	15.7	17.1	16.8	14.5	15.1
(40) Clear-Sky Solar Irradiance	taub		0.259	0.262	0.299	0.324	0.338	0.345	0.348	0.358	0.309	0.282	0.252	0.242
	taud		2.312	2.390	2.390	2.383	2.395	2.398	2.422	2.360	2.483	2.541	2.470	2.317
	Ebn at Noon		237	276	285	289	289	287	284	274	279	267	244	223
	Edh at Noon		19	23	29	34	35	36	34	34	27	20	16	15
(44) All-Sky Solar Radiation	RadAvg		327	646	1099	1479	1784	1887	1974	1626	1131	671	342	243
	RadStd		27	49	75	133	120	128	109	110	121	75	33	21

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (74 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page