

CAP-TOURMENTE, QC, Canada

WMO: 713840

Lat: 47.0787N

Lon: 70.7810W

Elev: 20

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.5	-5.7	-22.8	1.6	-8.2	-17.8	2.1	-3.8	22.3	23.4	19.8	23.6	5.9	270	0.545

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	83.6	70.9	80.5	68.9	77.6	67.4	73.4	80.4	71.4	77.6	69.5	75.2	7.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.1	114.7	77.1	69.2	107.3	75.2	67.3	100.4	73.3	37.0	80.5	35.3	77.9	33.6	75.2	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	17.1	14.5	-18.3	88.8	4.3	3.0	-21.4	91.0	-23.9	92.7	-26.2	94.5	-29.3	96.7
			-19.1	77.1	4.1	2.6	-22.1	79.0	-24.5	80.6	-26.8	82.1	-29.8	84.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.1	14.2	16.5	26.4	39.2	52.4	61.9	67.2	65.9	58.2	46.1	34.3	21.3
	DBStd	20.24	11.82	10.82	9.59	6.92	6.73	5.99	4.62	4.80	6.21	6.74	7.97	10.36
	HDD50	4684	1110	939	733	328	49	1	0	0	6	159	471	888
	HDD65	8585	1575	1359	1198	773	394	129	30	47	220	587	920	1353
	CDD50	1801	0	0	0	5	124	358	532	492	251	38	1	0
	CDD65	228	0	0	0	0	4	37	98	74	15	0	0	0
	CDH74	1548	0	0	0	3	82	299	623	436	104	1	0	0
	CDH80	304	0	0	0	0	16	64	127	82	15	0	0	0
Wind	WSAvg	5.9	6.4	6.5	6.7	6.8	6.6	5.6	4.8	5.0	5.2	5.7	5.8	5.8
Precipitation	PrecAvg	49.1	3.4	2.7	3.2	3.6	4.1	4.3	5.0	4.9	4.7	4.7	4.2	3.9
	PrecMax	56.1	7.6	6.4	5.2	9.1	7.6	7.5	9.7	7.7	8.9	8.9	7.5	8.1
	PrecMin	40.5	1.4	1.3	1.8	1.1	1.8	1.7	1.4	2.0	2.9	2.3	1.2	1.7
	PrecStd	4.7	1.5	1.1	1.0	1.9	1.3	1.3	1.7	1.6	1.3	1.7	1.3	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	41.6	51.0	66.8	81.9	86.0	87.2	86.0	82.1	70.4	58.2	44.4
		MCWB	41.4	38.5	41.8	52.4	62.4	71.2	74.2	72.8	70.5	59.8	54.1	41.0
	2%	DB	37.9	37.8	44.9	59.5	75.0	81.3	83.5	82.3	76.9	64.4	52.4	40.0
		MCWB	35.8	34.3	38.4	48.1	61.7	68.8	71.7	70.7	67.1	57.6	48.0	37.6
	5%	DB	34.4	35.2	40.9	53.8	69.5	77.2	80.4	78.8	72.3	60.2	48.3	37.3
		MCWB	32.8	33.0	36.0	44.8	57.3	66.5	69.6	68.5	64.8	55.2	44.6	35.1
	10%	DB	31.0	32.4	37.9	49.9	64.4	73.4	77.4	75.7	68.7	56.5	45.0	34.8
		MCWB	29.2	30.5	34.3	42.6	55.1	64.0	68.1	66.9	62.4	51.8	41.9	33.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.3	39.3	44.6	57.0	68.5	74.8	77.6	74.9	73.1	62.7	55.0	42.7
		MCDB	42.2	41.0	47.2	63.8	78.1	83.3	84.6	82.8	79.8	67.1	57.6	43.8
	2%	WB	36.0	35.0	39.7	49.6	63.6	71.4	73.7	72.5	69.3	59.2	49.2	38.2
		MCDB	36.9	36.8	43.5	56.3	70.4	78.3	80.3	79.4	74.4	63.4	51.5	39.5
	5%	WB	32.8	33.0	36.9	46.4	59.3	68.4	71.6	70.5	66.4	56.3	45.1	35.3
		MCDB	34.1	34.8	40.1	52.8	66.5	74.5	77.6	76.6	71.2	60.0	47.6	36.8
	10%	WB	29.0	30.3	34.7	43.6	56.3	65.9	69.6	68.6	63.5	52.7	42.6	33.3
		MCDB	30.7	32.4	37.3	48.8	63.7	71.6	75.2	73.9	68.1	55.7	44.9	34.7
Mean Daily Temperature Range	5% DB	MDBR	15.3	16.3	14.8	15.5	18.1	18.1	17.8	17.7	16.7	14.5	11.8	13.1
		MCDBR	15.2	14.5	17.3	23.8	27.5	24.4	22.4	21.7	22.1	20.2	16.5	12.3
		MCWBR	14.2	12.7	12.6	15.1	15.6	14.8	13.0	13.0	13.7	14.0	13.4	11.1
	5% WB	MCDBR	14.7	14.2	15.3	21.7	24.3	22.0	20.0	19.5	20.1	18.5	15.1	12.1
		MCWBR	14.5	12.7	12.0	15.1	15.3	14.6	12.8	12.6	13.8	14.1	13.3	11.5
Clear-Sky Solar Irradiance	taub	0.262	0.285	0.324	0.356	0.367	0.400	0.415	0.393	0.372	0.340	0.310	0.286	
	taud	2.339	2.262	2.229	2.322	2.384	2.314	2.291	2.355	2.408	2.482	2.449	2.319	
	Ebn at Noon	265	280	284	285	285	275	268	270	266	258	244	237	
	Edh at Noon	23	30	37	37	37	40	40	36	31	25	21	21	
All-Sky Solar Radiation	RadAvg	441	729	1105	1409	1605	1737	1693	1472	1151	675	388	298	
	RadStd	59	89	89	119	168	113	172	95	95	56	45	29	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page