

CAP-TOURMENTE, QC, Canada

WMO: 713840

Lat: 47.0787N

Lon: 70.7810W

Elev: 6

StdP: 101.25

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -23.6	(c) -20.9	(d) -30.5	(e) 0.2	(f) -22.4	(g) -27.7	(h) 0.3	(i) -19.9	(j) 10.0	(k) -4.8	(l) 8.8	(m) -4.6	(n) 2.7	(o) 270	(p) 0.545

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	28.7	21.6	27.0	20.5	25.3	19.7	23.0	26.9	21.9	25.4	20.8	24.0	3.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.7	16.4	25.1	20.7	15.3	24.0	19.6	14.3	22.9	68.2	26.9	64.1	25.5	60.3	24.0	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.1	(b) 7.7	(c) 6.5	(e) -27.9	(f) 31.5	(g) 2.4	(h) 1.7	(i) -29.6	(j) 32.8	(k) -31.0	(l) 33.7	(m) -32.4	(n) 34.7	(o) -34.1	(p) 35.9		
(a) 9.1	(b) 7.7	(c) 6.5	(e) -28.4	(f) 25.1	(g) 2.3	(h) 1.5	(i) -30.0	(j) 26.1	(k) -31.4	(l) 27.0	(m) -32.7	(n) 27.8	(o) -34.3	(p) 28.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-9.9	-8.6	-3.1	4.0	11.4	16.6	19.5	18.8	14.5	7.8	1.3	-5.9
	DBStd	11.24	6.57	6.01	5.33	3.84	3.74	3.33	2.57	2.67	3.45	3.75	4.43	5.76
	HDD10.0	2602	617	522	407	182	27	1	0	0	3	88	262	493
	HDD18.3	4769	875	755	666	429	219	72	17	26	122	326	511	752
	CDD10.0	1001	0	0	0	3	69	199	296	273	139	21	1	0
	CDD18.3	127	0	0	0	0	2	21	54	41	8	0	0	0
	CDH23.3	860	0	0	0	2	46	166	346	242	58	1	0	0
	CDH26.7	169	0	0	0	0	9	36	71	46	8	0	0	0
Wind	WSAvg	2.6	2.9	2.9	3.0	3.0	2.9	2.5	2.1	2.2	2.3	2.6	2.6	2.6
Precipitation	PrecAvg	1248	87	69	81	92	105	110	127	125	120	119	106	98
	PrecMax	1424	192	163	131	232	192	191	246	195	226	225	191	206
	PrecMin	1028	35	34	45	28	45	44	35	50	74	59	31	42
	PrecStd	119	37	27	26	48	34	33	43	40	34	42	33	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	5.3	10.5	19.4	27.7	30.0	30.7	30.0	27.8	21.3	14.6	6.9
		MCWB	5.2	3.6	5.4	11.3	16.9	21.8	23.4	22.7	21.4	15.5	12.3	5.0
	2%	DB	3.3	3.2	7.1	15.3	23.9	27.4	28.6	27.9	24.9	18.0	11.3	4.4
		MCWB	2.1	1.3	3.6	8.9	16.5	20.4	22.1	21.5	19.5	14.2	8.9	3.1
	5%	DB	1.4	1.8	4.9	12.1	20.8	25.1	26.9	26.0	22.4	15.6	9.0	3.0
		MCWB	0.5	0.5	2.2	7.1	14.1	19.2	20.9	20.3	18.2	12.9	7.0	1.7
	10%	DB	-0.5	0.2	3.3	9.9	18.0	23.0	25.2	24.3	20.4	13.6	7.2	1.6
		MCWB	-1.5	-0.8	1.3	5.9	12.8	17.8	20.0	19.4	16.9	11.0	5.5	0.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	4.1	7.0	13.9	20.3	23.8	25.3	23.8	22.8	17.1	12.8	5.9
		MCDB	5.7	5.0	8.4	17.7	25.6	28.5	29.2	28.2	26.6	19.5	14.2	6.6
	2%	WB	2.2	1.7	4.3	9.8	17.5	21.9	23.2	22.5	20.7	15.1	9.6	3.4
		MCDB	2.7	2.6	6.4	13.5	21.3	25.7	26.8	26.3	23.6	17.4	10.8	4.2
	5%	WB	0.4	0.5	2.7	8.0	15.2	20.2	22.0	21.4	19.1	13.5	7.3	1.9
		MCDB	1.2	1.6	4.5	11.6	19.2	23.6	25.3	24.8	21.8	15.6	8.7	2.7
	10%	WB	-1.7	-0.9	1.5	6.4	13.5	18.8	20.9	20.3	17.5	11.5	5.9	0.7
		MCDB	-0.7	0.2	2.9	9.3	17.6	22.0	24.0	23.3	20.1	13.2	7.2	1.5
Mean Daily Temperature Range	5% DB	MDBR	8.5	9.1	8.2	8.6	10.0	10.0	9.9	9.9	9.3	8.1	6.6	7.3
		MCDBR	8.5	8.1	9.6	13.2	15.3	13.6	12.4	12.1	12.3	11.2	9.2	6.8
		MCWBR	7.9	7.1	7.0	8.4	8.7	8.2	7.2	7.2	7.6	7.8	7.5	6.2
	5% WB	MCDBR	8.1	7.9	8.5	12.0	13.5	12.2	11.1	10.8	11.2	10.3	8.4	6.7
		MCWBR	8.1	7.1	6.7	8.4	8.5	8.1	7.1	7.0	7.7	7.8	7.4	6.4
Clear-Sky Solar Irradiance	taub	0.262	0.285	0.324	0.356	0.367	0.400	0.415	0.393	0.372	0.340	0.310	0.286	
	taud	2.339	2.262	2.229	2.322	2.384	2.314	2.291	2.355	2.408	2.482	2.449	2.319	
	Ebn at Noon	835	882	894	897	898	866	845	851	837	814	770	748	
	Edh at Noon	72	96	117	118	116	125	126	114	99	79	66	66	
All-Sky Solar Radiation	RadAvg	1.39	2.30	3.48	4.44	5.06	5.48	5.34	4.64	3.63	2.13	1.22	0.94	
	RadStd	0.19	0.28	0.28	0.37	0.53	0.36	0.54	0.30	0.30	0.18	0.14	0.09	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page