

HALIFAX STANFIELD, NS, Canada

WMO: 713950

Lat: 44.880N

Lon: 63.500W

Elev: 477

StdP: 14.44

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.4	4.6	-9.5	3.4	2.3	-4.7	4.4	6.8	35.1	39.2	30.9	38.6	10.6	320	0.668

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	82.2	68.9	79.2	67.0	76.6	65.8	71.7	78.3	69.9	75.5	68.3	73.3	11.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.6	110.6	74.3	68.1	105.0	72.5	66.5	99.2	70.8	35.7	78.4	34.2	75.8	32.8	73.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.7	24.9	21.9	DB	-5.1	88.3	5.4	2.8	-8.9	90.3	-12.1	91.9	-15.1	93.5	-19.0	95.6	(4)
(5)			WB	-5.9	74.6	5.3	1.5	-9.7	75.7	-12.8	76.6	-15.8	77.5	-19.6	78.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.9	22.9	23.7	30.3	40.1	50.2	59.3	66.8	66.5	59.8	49.2	39.2	29.5
	DBStd	17.11	10.34	9.44	8.31	6.54	6.19	6.27	4.54	4.56	6.24	6.90	8.23	9.07
	HDD50	3643	839	735	611	303	72	5	0	0	4	101	337	636
	HDD65	7548	1304	1155	1075	746	459	191	34	37	179	492	775	1101
	CDD50	1787	0	0	2	7	80	283	520	513	296	75	11	0
	CDD65	215	0	0	0	0	1	18	89	84	22	1	0	0
	CDH74	1193	0	0	2	2	29	163	486	415	95	1	0	0
	CDH80	199	0	0	0	0	5	29	81	63	21	0	0	0
Wind	WSAvg	10.7	11.7	12.0	12.2	11.8	10.6	9.8	9.1	8.7	9.4	10.5	11.4	11.8
Precipitation	PrecAvg	60.3	6.1	4.9	5.0	5.2	4.5	4.0	3.9	4.3	3.8	5.2	6.3	6.8
	PrecMax	80.2	12.3	8.4	9.8	9.3	9.4	12.3	7.8	15.6	6.5	9.4	10.9	12.1
	PrecMin	43.3	1.5	1.5	2.0	1.5	1.1	1.8	0.4	0.7	0.8	1.1	1.5	2.3
	PrecStd	9.3	2.3	1.9	1.9	1.9	2.0	2.0	2.0	2.8	1.5	2.0	2.3	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	51.1	58.1	65.9	78.3	83.8	86.3	85.4	82.5	71.6	61.8	55.4
		MCWB	52.5	48.9	49.6	54.4	60.6	69.1	71.5	70.6	70.4	62.5	59.7	54.9
	2%	DB	47.7	45.1	49.9	58.8	70.6	78.6	82.0	81.5	76.1	66.6	58.7	51.3
		MCWB	47.0	43.8	46.5	49.8	57.8	65.2	69.3	68.4	66.8	61.8	57.3	50.5
	5%	DB	42.7	40.9	45.9	54.9	65.8	74.5	79.1	78.6	72.5	63.2	56.2	47.6
		MCWB	41.6	39.2	42.4	47.9	54.8	62.8	67.4	67.2	64.8	59.6	54.8	46.8
	10%	DB	37.4	36.9	42.2	51.2	61.7	70.9	76.4	75.8	69.5	60.4	52.6	42.6
		MCWB	36.1	35.2	38.8	45.9	52.8	61.0	66.0	65.6	63.8	57.1	50.7	41.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.8	49.5	52.2	57.1	65.0	71.1	73.7	73.6	72.1	66.4	60.7	55.2
		MCDB	53.3	51.3	55.6	61.4	73.4	81.0	81.3	81.4	78.0	68.6	61.1	55.3
	2%	WB	47.3	44.1	47.3	53.3	60.3	68.1	71.8	71.4	69.3	63.3	57.9	50.9
		MCDB	47.7	44.7	48.8	55.7	66.4	75.4	78.6	77.4	73.4	65.0	58.4	51.4
	5%	WB	41.8	39.6	43.1	49.9	57.3	65.3	70.0	69.6	67.5	60.8	55.1	47.0
		MCDB	42.6	40.5	45.0	52.7	62.5	71.0	75.9	74.7	70.4	62.6	56.0	47.5
	10%	WB	36.3	35.6	39.2	46.6	54.5	62.9	68.2	67.8	65.4	57.6	51.1	41.5
		MCDB	37.2	36.7	41.4	50.4	59.5	67.9	73.5	72.8	68.3	59.7	52.3	42.4
Mean Daily Temperature Range	5% DB	MDBR	14.6	14.6	14.3	15.3	17.5	17.3	16.5	16.2	15.7	14.1	12.4	12.8
		MCDBR	21.1	17.4	19.4	22.3	24.8	23.1	20.7	20.1	18.7	17.2	16.0	17.8
		MCWBR	21.8	16.6	16.1	15.0	14.2	12.6	10.3	10.2	11.0	12.6	15.4	18.5
	5% WB	MCDBR	21.2	17.4	18.6	18.4	21.3	19.9	17.6	16.6	15.3	15.4	15.5	17.9
		MCWBR	22.1	17.7	17.4	15.2	14.2	12.4	10.4	9.7	10.6	13.6	15.9	19.0
Clear-Sky Solar Irradiance	taub	0.297	0.289	0.317	0.343	0.361	0.389	0.405	0.388	0.347	0.324	0.308	0.289	
	taud	2.466	2.519	2.480	2.448	2.439	2.378	2.354	2.400	2.493	2.555	2.557	2.540	
	Ebn at Noon	262	289	292	292	288	279	272	274	278	271	257	255	
	Edh at Noon	22	25	30	34	35	37	38	35	30	24	20	19	
All-Sky Solar Radiation	RadAvg	448	724	1103	1351	1560	1696	1699	1577	1270	820	467	347	
	RadStd	36	56	74	114	194	155	123	112	90	86	51	26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+1.91	+2.72	N/A	+0.83	+1.51	N/A	N/A	+101	+32
Regional (36 neighbors)	N/A	N/A	N/A	N/A	+0.65	+0.90	N/A	N/A	+90	+25

Nomenclature: See separate page