

WARFIELD, BC, Canada

WMO: 714010

Lat: 49.1123N

Lon: 117.7386W

Elev: 1860

StdP: 13.73

Time Zone: -8.00 (NAP)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.6	12.6	-0.8	5.6	10.2	4.1	7.3	15.3	13.9	25.3	12.3	26.6	3.9	320	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.9	94.2	63.0	90.5	62.1	86.7	60.9	65.4	85.9	63.7	84.1	62.3	82.1	4.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.1	80.1	68.0	57.3	75.1	67.6	55.6	70.5	66.1	31.2	86.1	29.9	84.0	28.8	82.4	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.7	9.5	DB	2.1	100.2	5.6	3.0	-1.9	102.4	-5.2	104.1	-8.3	105.8	-12.4	108.0	(4)
(5)			WB	2.0	68.3	5.7	2.5	-2.1	70.1	-5.4	71.6	-8.6	73.0	-12.7	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	28.2	31.0	39.0	47.4	56.6	62.4	70.6	69.8	59.9	46.1	35.3	27.7
	DBStd	16.50	7.45	6.70	6.20	6.09	7.06	6.49	6.20	5.45	6.61	6.46	6.76	6.87
	HDD50	2982	676	531	343	121	20	1	0	0	5	153	442	690
	HDD65	6685	1141	951	806	529	275	125	24	19	182	586	892	1155
	CDD50	2228	0	0	2	43	224	373	638	615	301	32	0	0
	CDD65	455	0	0	0	0	14	47	196	170	28	0	0	0
	CDH74	6110	0	0	0	19	292	710	2562	2127	399	1	0	0
	CDH80	2717	0	0	0	1	82	258	1270	977	129	0	0	0
Wind	WSAvg	3.9	3.8	4.1	4.2	4.6	4.3	4.0	3.8	3.7	3.8	3.5	3.6	3.6
Precipitation	PrecAvg	27.4	3.3	1.9	2.0	1.9	2.6	2.6	1.3	1.1	1.4	2.2	3.0	3.6
	PrecMax	35.7	5.7	4.0	4.6	3.3	5.6	4.4	3.3	3.4	5.2	3.7	5.7	6.0
	PrecMin	21.8	1.1	0.5	0.7	0.7	0.8	1.3	0.0	0.2	0.2	0.2	1.0	1.6
	PrecStd	4.2	0.9	0.8	1.0	0.7	1.4	0.7	1.0	0.9	1.1	0.9	1.2	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.1	48.3	62.6	77.0	87.1	93.7	99.4	97.5	89.6	70.1	52.9	43.4
		MCWB	38.3	40.5	47.2	54.6	58.9	64.3	64.0	63.1	60.3	54.4	48.5	39.1
	2%	DB	38.5	43.6	56.6	69.9	81.8	87.0	95.3	93.3	83.9	64.0	49.0	39.5
		MCWB	36.0	38.2	44.0	50.4	57.5	61.8	63.3	62.4	59.8	51.5	46.1	36.9
	5%	DB	36.7	40.9	52.2	64.7	76.4	81.9	91.8	89.6	78.4	59.7	46.1	37.0
		MCWB	35.1	36.7	42.3	48.2	55.1	59.3	63.0	61.5	57.5	49.8	43.4	35.5
	10%	DB	35.4	38.7	48.5	60.1	71.6	77.3	87.7	85.8	73.3	55.9	43.7	35.3
		MCWB	34.1	35.6	40.7	46.1	53.1	57.7	61.7	60.4	55.4	48.6	41.2	34.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.3	42.2	49.4	55.9	61.3	66.6	68.5	66.5	63.9	57.1	50.2	40.6
		MCDB	41.3	45.3	58.7	74.6	80.0	87.8	90.3	87.1	81.3	63.6	52.0	41.8
	2%	WB	36.8	39.2	46.2	52.1	58.6	63.0	66.1	64.4	60.9	54.2	46.8	37.4
		MCDB	37.9	42.3	53.8	66.8	76.3	82.1	86.5	86.1	77.4	60.6	48.5	38.2
	5%	WB	35.5	37.5	43.7	49.6	56.7	61.0	64.4	62.8	59.2	52.0	43.8	35.5
		MCDB	36.3	40.0	50.6	61.9	72.1	77.0	84.4	84.2	74.2	58.4	45.5	36.3
	10%	WB	34.3	36.0	41.6	47.3	54.8	59.3	62.8	61.5	57.3	49.4	41.2	34.1
		MCDB	35.1	38.2	47.4	57.7	67.6	73.0	83.2	81.7	71.1	55.2	43.0	34.9
Mean Daily Temperature Range	5% DB	MDBR	6.5	11.0	15.3	20.8	23.9	23.6	29.9	30.4	24.2	16.2	8.5	6.3
		MCDBR	6.7	13.5	22.4	30.2	32.9	33.0	36.7	36.5	32.6	23.3	11.4	7.4
		MCWBR	5.2	8.8	12.2	14.2	13.5	12.7	12.3	12.5	12.8	12.1	8.4	6.2
	5% WB	MCDBR	6.0	11.4	19.6	26.9	27.6	28.1	32.4	32.1	28.6	19.1	10.2	6.2
		MCWBR	4.8	7.7	11.6	13.4	11.9	11.6	11.9	11.6	11.8	10.4	8.1	5.5
Clear-Sky Solar Irradiance	taub	0.280	0.280	0.291	0.339	0.369	0.361	0.359	0.370	0.341	0.317	0.300	0.273	
	taud	2.308	2.332	2.397	2.377	2.360	2.420	2.437	2.400	2.476	2.531	2.458	2.366	
	Ebn at Noon	246	278	295	288	283	285	284	275	273	263	240	234	
	Edh at Noon	22	27	30	35	37	35	34	34	29	23	19	18	
All-Sky Solar Radiation	RadAvg	305	603	910	1386	1712	1806	2156	1808	1277	734	336	239	
	RadStd	42	74	116	125	140	166	163	139	129	96	47	32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140	N/A

Nomenclature: See separate page