

BEAVER ISLAND, NS, Canada

WMO: 714030

Lat: 44.825N

Lon: 62.339W

Elev: 52

StdP: 14.67

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.2	10.1	-2.2	4.9	9.6	1.3	5.9	12.5	47.6	31.8	42.8	32.9	19.5	320	0.837

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.3	69.6	65.4	68.0	64.6	66.6	63.5	67.2	68.7	65.7	67.2	64.5	65.9	12.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	97.9	68.2	65.1	92.9	66.7	63.8	88.8	65.5	31.7	68.7	30.6	67.4	29.6	66.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
40.1	35.4	30.8	1.2	74.1	4.8	2.7	-2.3	76.0	-5.1	77.6	-7.8	79.1	-11.3	81.1
			-0.9	69.5	5.6	2.1	-5.0	71.0	-8.3	72.2	-11.4	73.4	-15.5	74.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	27.0	26.1	30.6	37.4	44.1	51.7	59.1	62.7	59.7	51.5	42.4	33.5	(6)
	DBStd	13.67	8.35	7.33	5.96	3.75	3.65	3.97	3.60	3.14	4.12	5.22	6.46	7.51	(7)
	HDD50	3370	714	670	601	379	187	27	0	0	0	46	235	511	(8)
	HDD65	7718	1179	1090	1066	829	648	399	185	85	163	420	678	976	(9)
	CDD50	1147	0	0	0	0	4	78	282	394	291	91	7	0	(10)
	CDD65	19	0	0	0	0	0	0	2	13	4	0	0	0	(11)
	CDH74	6	0	0	0	0	0	0	1	4	1	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	15.7	18.7	18.2	17.7	15.8	13.5	12.7	11.4	12.3	14.6	16.8	18.1	18.8	(14)
(15) Precipitation	PrecAvg	60.8	5.4	4.3	4.6	4.4	4.3	4.8	4.6	4.6	4.6	5.9	6.3	6.9	(15)
	PrecMax	75.0	8.4	6.5	8.6	8.7	7.3	9.3	8.1	8.3	13.6	13.3	10.0	12.6	(16)
	PrecMin	48.2	2.8	1.6	1.9	1.6	2.0	1.9	2.2	2.3	1.5	2.1	4.1	5.0	(17)
	PrecStd	6.5	1.3	1.4	1.5	1.5	1.4	1.7	1.6	1.5	2.5	2.5	1.7	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.9	42.3	45.5	51.2	57.9	65.3	70.8	72.6	71.7	64.6	57.1	50.6	(19)
		MCWB	44.2	41.6	40.5	44.2	49.4	58.0	62.6	67.1	67.4	61.0	55.8	49.7	(20)
	2%	DB	42.4	39.1	41.3	46.1	53.2	61.2	67.3	70.2	68.6	62.6	54.9	48.1	(21)
		MCWB	41.6	38.0	39.0	41.9	48.6	56.6	63.3	66.2	64.4	60.4	53.6	47.1	(22)
	5%	DB	40.2	36.9	39.2	43.7	50.9	58.8	65.6	68.7	66.8	60.8	53.1	46.2	(23)
		MCWB	39.1	36.0	37.4	41.0	47.3	55.2	62.7	65.6	63.5	58.7	51.7	45.2	(24)
	10%	DB	38.2	35.3	37.4	41.9	49.0	57.0	64.0	67.4	65.4	59.0	51.4	44.0	(25)
		MCWB	37.0	34.3	35.6	39.8	46.0	54.3	61.9	64.6	62.6	56.5	49.8	42.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.3	40.5	42.8	45.6	52.5	61.1	65.9	69.3	69.7	63.0	56.5	49.6	(27)
		MCDB	44.6	40.7	44.3	48.3	54.9	63.5	67.3	71.0	71.8	63.6	56.9	49.8	(28)
	2%	WB	41.4	37.6	40.1	43.2	50.4	58.4	64.3	67.9	66.3	61.4	54.3	47.4	(29)
		MCDB	41.8	37.9	41.2	44.8	52.1	60.0	65.5	69.4	67.5	62.3	55.0	47.8	(30)
	5%	WB	38.9	35.8	37.9	41.7	48.5	56.3	63.3	66.6	64.8	59.4	52.3	45.5	(31)
		MCDB	39.5	36.1	39.0	42.9	49.9	57.7	64.5	68.2	66.0	60.6	53.1	46.1	(32)
	10%	WB	36.7	34.1	35.9	40.3	46.9	54.7	62.2	65.5	63.5	57.3	50.4	43.2	(33)
		MCDB	37.6	34.7	37.0	41.5	48.3	56.1	63.5	67.1	64.8	58.7	51.2	44.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	10.5	8.6	7.4	7.3	7.4	7.2	7.3	8.1	8.0	8.5	10.0	(35)
		MCDBR	12.9	10.2	10.1	10.4	10.7	11.1	9.6	8.9	8.4	8.5	8.9	10.8	(36)
	5% WB	MCWBR	13.6	10.6	8.8	7.8	7.6	7.8	6.4	6.4	6.8	8.3	9.9	11.6	(37)
		MCWBR	12.5	10.4	9.7	8.7	9.4	10.2	7.8	7.4	7.0	8.1	9.0	10.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.306	0.305	0.328	0.351	0.375	0.394	0.416	0.395	0.353	0.341	0.324	0.298	(40)
		taud	2.465	2.496	2.462	2.444	2.423	2.402	2.370	2.426	2.507	2.528	2.522	2.528	(41)
	Ebn at Noon		258	282	288	289	284	278	270	272	276	265	250	251	(42)
		Edh at Noon	22	26	30	34	36	36	37	34	29	25	21	19	(43)
(44) All-Sky Solar Radiation	RadAvg		423	699	1101	1356	1568	1692	1663	1548	1265	814	462	336	(44)
	RadStd		33	57	75	114	181	165	118	112	88	83	51	25	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.86	N/A	N/A	N/A	(47)

Nomenclature: See separate page