

FOURCHU HEAD, NS, Canada

WMO: 714160

Lat: 45.717N

Lon: 60.230W

Elev: 33

StdP: 14.68

Time Zone: -4.00 (NAA)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.7	4.8	-8.8	3.4	2.8	-4.1	4.4	6.8	47.3	30.8	41.7	31.1	12.1	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.4	69.4	61.2	66.7	62.1	64.9	61.4	64.7	66.9	63.5	65.6	62.2	64.5	14.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	88.9	66.1	62.5	84.7	65.2	61.1	80.6	63.8	29.8	66.9	28.9	65.7	28.0	64.8	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.9	32.6	28.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.8	23.0	21.7	27.3	34.0	40.7	48.7	57.7	61.3	56.4	48.3	39.8	29.4
	DBStd	14.43	8.48	8.78	6.26	3.48	4.11	4.05	4.16	3.20	4.23	5.28	6.05	7.56
	HDD50	4224	836	793	702	480	292	73	0	0	4	98	308	638
	HDD65	8840	1301	1213	1167	930	754	490	229	121	258	518	756	1103
	CDD50	867	0	0	0	0	2	33	240	350	196	44	2	0
	CDD65	10	0	0	0	0	0	0	4	6	0	0	0	0
	CDH74	27	0	0	0	0	3	0	17	7	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
	WSAvg	14.2	15.6	15.1	15.1	13.9	13.1	12.1	11.8	13.3	13.7	15.4	15.6	16.2
	PrecAvg	59.1	5.8	5.2	4.6	4.4	4.0	4.1	3.5	3.9	4.7	6.0	6.0	6.8
(15) Precipitation	PrecMax	72.9	8.9	7.2	8.7	7.4	7.0	6.8	6.7	9.0	12.1	10.5	9.5	14.0
	PrecMin	45.3	2.8	1.9	1.9	2.3	1.9	2.0	1.5	1.7	1.7	2.4	3.8	3.8
	PrecStd	6.0	1.5	1.5	1.7	1.3	1.4	1.5	1.2	1.3	2.4	2.2	1.6	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.8	40.5	42.3	48.7	58.5	68.0	76.2	74.0	68.2	61.1	54.6	46.0
		MCWB	40.7	39.0	34.9	41.3	47.5	56.6	63.5	62.1	60.7	58.4	52.5	44.2
	2%	DB	39.3	37.2	37.8	43.3	51.6	60.8	69.8	69.6	65.1	59.0	52.2	44.0
		MCWB	38.6	36.2	35.4	37.8	44.6	52.3	60.8	61.8	60.7	56.8	50.8	42.5
	5%	DB	37.0	35.1	36.2	40.1	47.2	56.6	65.3	67.4	63.8	57.6	50.6	41.8
		MCWB	36.1	34.2	34.2	36.6	42.8	52.0	61.0	63.0	60.4	55.2	49.2	40.3
	10%	DB	34.8	33.4	34.5	37.9	45.0	53.6	62.7	65.7	62.6	56.2	48.7	39.8
		MCWB	33.8	32.4	32.8	35.5	42.0	51.1	59.5	62.6	59.4	53.9	47.2	38.3
	0.4%	WB	41.2	39.2	38.6	43.2	50.4	58.4	66.4	66.8	63.7	59.3	53.6	44.9
		MCDB	41.8	39.9	39.2	47.3	55.7	65.3	72.1	68.9	65.1	60.8	54.5	46.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.7	36.6	36.3	39.2	45.8	55.0	63.8	65.7	62.6	57.4	51.3	43.0
		MCDB	39.2	37.3	37.2	41.2	48.7	59.2	67.1	67.7	64.6	58.8	52.1	44.1
	5%	WB	36.3	34.3	34.7	37.5	44.1	52.7	61.6	64.3	61.4	56.1	49.5	40.7
		MCDB	37.0	34.9	35.9	39.2	46.8	55.1	64.6	66.0	63.1	57.4	50.6	41.7
	10%	WB	34.1	32.5	33.2	36.1	42.3	51.3	60.0	63.3	60.3	54.7	47.5	38.3
		MCDB	34.7	33.1	34.3	37.7	44.3	53.4	62.4	65.2	62.0	56.1	48.7	39.5
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	13.6	9.9	7.5	8.3	8.2	8.2	7.4	9.6	8.9	9.0	10.6
		MCDBR	12.7	12.4	10.2	11.6	14.6	15.0	14.4	10.4	10.6	8.5	9.7	12.5
		MCWBR	13.6	13.0	8.6	8.6	9.2	9.0	8.1	7.1	8.4	8.6	10.0	13.0
	5% WB	MCDBR	12.6	11.9	9.2	9.4	13.0	11.9	11.6	7.9	9.1	7.7	9.1	12.6
		MCWBR	13.6	12.5	8.9	7.9	9.1	8.6	7.8	6.6	8.1	8.6	9.8	13.4
(40) Clear-Sky Solar Irradiance	taub		0.305	0.298	0.328	0.358	0.372	0.393	0.424	0.395	0.365	0.344	0.326	0.301
	taud		2.404	2.452	2.420	2.415	2.436	2.409	2.357	2.435	2.499	2.521	2.500	2.474
	Ebn at Noon		253	282	286	286	284	278	267	271	271	261	245	244
	Edh at Noon		23	26	31	35	35	36	38	34	29	25	21	20
(44) All-Sky Solar Radiation	RadAvg		364	635	1044	1338	1599	1696	1685	1529	1215	766	418	277
	RadStd		27	63	77	104	155	152	115	106	86	67	50	21

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page