

POINTE-DES-MONTS, QC, Canada

WMO: 714270

Lat: 49.326N

Lon: 67.367W

Elev: 6

StdP: 101.25

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.8	-21.5	-29.7	0.2	-23.1	-27.2	0.3	-20.7	19.0	-7.0	17.7	-7.8	5.5	270	0.818

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	19.6	16.1	18.4	15.6	17.4	14.9	17.3	18.7	16.3	17.7	15.4	16.8	4.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	11.8	18.1	15.6	11.1	17.1	14.7	10.5	16.3	48.7	18.9	45.8	17.7	43.3	16.9	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.3	11.6	-26.5	24.2	2.2	2.1	-28.1	25.7	-29.4	26.9	-30.6	28.1	-32.2	29.6		
(5)			-27.6	19.2	2.4	1.6	-29.3	20.3	-30.7	21.3	-32.1	22.2	-33.9	23.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-11.0	-9.8	-5.0	0.7	6.7	11.6	14.3	13.8	10.5	5.5	0.1	-6.4
	DBStd	9.53	5.99	5.55	4.82	3.09	2.67	2.39	1.97	2.33	2.47	2.53	3.80	5.25
	HDD10.0	3037	649	554	464	279	109	10	0	2	23	141	298	509
	HDD18.3	5723	908	787	722	529	362	201	125	141	236	398	548	768
	CDD10.0	356	0	0	0	0	5	59	134	119	37	1	0	0
	CDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	3	0	0	0	0	0	2	1	1	0	0	0	0
	CDH26.7	1	0	0	0	0	0	1	0	0	0	0	0	0
Wind	WSAvg	5.3	6.0	5.7	5.6	5.3	4.9	4.9	4.8	4.7	5.1	5.4	5.7	6.0
Precipitation	PrecAvg	1088	79	65	69	81	90	90	117	91	94	122	94	89
	PrecMax	1227	158	129	118	131	170	155	274	228	208	201	160	159
	PrecMin	851	28	34	23	27	30	43	65	38	36	54	26	49
	PrecStd	99	33	26	27	34	33	29	43	45	35	41	31	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	2.6	5.0	9.4	16.4	21.1	21.7	21.1	18.8	13.3	8.8	4.6
		MCWB	1.8	1.8	1.5	5.0	11.1	13.0	17.2	17.1	15.0	10.3	7.4	3.6
	2%	DB	0.7	0.6	3.0	6.9	13.6	18.0	19.8	19.3	16.2	10.9	6.9	3.0
		MCWB	0.1	-0.2	1.0	3.9	9.7	13.9	16.5	16.6	13.8	8.9	5.8	2.1
	5%	DB	-0.6	-0.7	1.6	5.5	11.9	16.4	18.6	18.1	15.0	9.8	5.8	1.7
		MCWB	-1.2	-1.3	0.2	3.0	9.0	13.0	16.0	15.8	12.8	8.0	4.8	0.9
	10%	DB	-2.1	-1.8	0.6	4.3	10.6	15.2	17.4	17.2	13.9	8.9	4.9	0.7
		MCWB	-2.8	-2.4	-0.5	2.3	8.0	12.4	15.1	15.2	12.1	7.4	4.0	-0.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.1	1.9	2.8	6.5	12.2	16.2	18.7	18.7	16.1	11.0	7.7	3.9
		MCDB	2.5	2.3	4.0	8.3	14.2	18.4	20.6	19.9	17.0	11.9	8.4	4.3
	2%	WB	0.3	0.0	1.3	4.6	10.6	14.8	17.4	17.4	14.2	9.4	6.0	2.2
		MCDB	0.7	0.5	2.3	6.2	12.6	16.7	19.0	18.7	15.4	10.4	6.6	2.6
	5%	WB	-1.2	-1.1	0.5	3.6	9.4	13.7	16.4	16.4	13.2	8.5	5.0	1.2
		MCDB	-0.8	-0.7	1.4	5.0	11.3	15.6	17.9	17.7	14.4	9.4	5.6	1.7
	10%	WB	-2.8	-2.4	-0.3	2.6	8.4	12.8	15.5	15.6	12.4	7.7	4.2	0.1
		MCDB	-2.2	-1.9	0.5	4.0	10.2	14.6	16.9	16.8	13.5	8.6	4.9	0.7
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.2	6.4	5.1	5.6	5.8	5.5	5.4	5.1	4.6	4.7	6.2
		MCDBR	8.0	6.1	5.9	6.7	8.0	8.3	7.2	6.4	6.2	5.5	4.6	4.9
		MCWBR	7.9	6.0	5.1	5.0	5.5	5.3	5.0	4.5	4.6	4.4	4.5	4.9
	5% WB	MCDBR	8.1	5.9	5.5	6.0	7.0	7.3	6.3	5.7	5.6	4.8	4.4	5.0
		MCWBR	8.2	5.9	5.1	4.9	5.3	5.1	4.9	4.3	4.6	4.3	4.5	5.1
Clear-Sky Solar Irradiance	taub	0.270	0.277	0.301	0.362	0.369	0.393	0.414	0.394	0.369	0.335	0.298	0.274	
	taud	2.355	2.317	2.324	2.269	2.373	2.362	2.345	2.400	2.443	2.505	2.492	2.395	
	Ebn at Noon	794	878	912	882	890	867	841	844	830	803	761	737	
	Edh at Noon	66	87	103	123	116	118	118	107	93	74	59	56	
All-Sky Solar Radiation	RadAvg	1.15	2.11	3.36	4.46	5.25	5.64	5.45	4.68	3.45	2.07	1.08	0.80	
	RadStd	0.13	0.21	0.22	0.40	0.33	0.39	0.54	0.27	0.27	0.17	0.13	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-1
(47) Regional (11 neighbors)	N/A	N/A	+1.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page